



Doug Slater
Director, Regulatory Affairs

Gas Regulatory Affairs Correspondence
Email: gas.regulatory.affairs@fortisbc.com

Electric Regulatory Affairs Correspondence
Email: electricity.regulatory.affairs@fortisbc.com

FortisBC
16705 Fraser Highway
Surrey, B.C. V4N 0E8
Tel: (778) 578-3874
Cell: (778) 214-3842
Fax: (604) 576-7074
Email: doug.slater@fortisbc.com
www.fortisbc.com

July 9, 2020

British Columbia Public Interest Advocacy Centre
Suite 803 470 Granville Street
Vancouver, B.C.
V6C 1V5

Attention: Ms. Leigha Worth, Executive Director

Dear Ms. Worth:

Re: FortisBC Inc. (FBC)

Project No. 1599088

Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)

Response to the British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1

On April 24, 2020, FBC filed the Application referenced above. In accordance with the British Columbia Utilities Commission Order G-107-20 setting out the Regulatory Timetable for the review of the Application, FBC respectfully submits the attached response to BCOAPO IR No. 1.

If further information is required, please contact the undersigned.

Sincerely,

FORTISBC INC.

Original signed:

Doug Slater

Attachments

cc (email only): Commission Secretary
Registered Parties

FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 1

1 **1.0 Reference: Exhibit B-1, pages 4 and 57**

2 **Preamble:** At page 4 the Application states:

3 “Prior to filing the Application, FBC sent notification letters to area
4 residents and stakeholders who have the potential to be directly affected
5 by the Project. Various channels were used to reach customers including
6 letters, updates on the Project website³, and a Project survey. FBC has
7 also notified local government authorities and responded to requests for
8 further information”.

9 At page 57 the Application states:

10 “The Key Stakeholders for the KBTA Project have been identified as:

- 11 City of Kelowna elected officials and staff;
- 12 Residents and businesses at the Tower Ranch subdivision and Tower
13 Ranch Golf & Country Club, and other residents adjacent to or in
14 close proximity to LEE; and
- 15 Indigenous Communities as identified through the Provincial
16 Consultative Areas Database.”

17 1.1 Are “key stakeholders” and “those directly affected by the Project” the same? If
18 not, what is the difference?

19

20 **Response:**

21 Key stakeholders is a term broadly applied to cover all parties that may be impacted directly by
22 a project, such as area residents and businesses in close proximity to a project site, as well as
23 parties that may be indirectly impacted, such as those with jurisdictional interests, such as a
24 municipality or First Nation. Therefore, “those directly affected by the Project” is a subset of key
25 stakeholders.

26 To determine area residents and businesses that would potentially be directly affected by the
27 Project, FBC referred to property mapping and billing information for residents and businesses
28 in closest proximity and adjacent to the Project location.

29 While not directly affected by the Project, FBC identified City of Kelowna elected officials and
30 staff as key stakeholders to ensure they were made aware of the Project since it is being
31 constructed within City limits. FBC obtained a list of Indigenous communities with interests in
32 the area of the Project through the Provincial Consultative Areas Database.



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 2

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20

1.2 Please explain how FBC determined which area residents and stakeholders would be “directly affected” by the Project.

Response:

Please refer to the response to BCOAPO IR1 1.1.

1.3 Did FBC consult parties other than those identified by the utility as “directly affected” to determine whether its assessment was correct?

Response:

FBC contacted those parties described in the Application as key stakeholders (including those directly impacted by the Project) and those discussions did not identify any further parties requiring notification. FBC is confident that its consultation efforts were as inclusive as required by the Project.



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 4

1 2.2.1 Will the dates when additional capacity is required for the area's
2 distribution substations be at all affected by which of the three
3 alternatives set out in the current Application (pages 27-32) are
4 chosen?

5 2.2.2 If yes, please explain how.

6
7 **Response:**

8 No, the alternative chosen will not affect the dates when additional capacity is required for the
9 area's distribution substations.

10

FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 5

1 **3.0 Reference: Exhibit B-1, page 14**

2 **Preamble:** At page 12 the Application states:

3 “Other sources demonstrate a consensus view of continued, consistent
4 growth in the Kelowna area. For example, in 2011 the City of Kelowna
5 adopted the Kelowna 2030 Official Community Plan, anticipating the
6 addition of 8,565 single / two unit homes and 11,520 multiple unit homes
7 by 2030. In 2018, the City of Kelowna further predicted that the total
8 number of new housing units required by 2040 will be between 23,000
9 and 25,000 units”.

10 3.1 Based on the additions referenced in the Kelowna 2030 Official Community Plan,
11 what does this translate into in terms of annual growth in number of homes in the
12 area through to 2030?

13
14 **Response:**

15 Based on the information in the Kelowna 2030 Official Community Plan, this translates to
16 approximately 1,000 new housing units per year through to 2030.

17
18

19
20 3.2 Similarly, what do the additions in number of new housing units between 2030
21 and 2040 translate into in terms of annual growth in number of homes?

22
23 **Response:**

24 FBC understands that the 2018 City of Kelowna prediction regarding new housing units required
25 by 2040 is for the period from 2018 to 2040. Therefore, the total number of units would translate
26 to approximately 1,000 to 1,100 housing units per year.

27



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 6

1 **4.0 Reference: Exhibit B-1, pages 15-16**

2 4.1 With reference to the load forecast methodology used, please explain why
3 some/all of the potential new load discussed at page 16 (lines 16-24) is not
4 already implicitly captured in the load forecast as set out in Table 3-5.

5
6 **Response:**

7 Only new commercial loads are “implicitly” captured in FBC’s load forecast, since commercial
8 load is forecast as a whole based on GDP growth rates from the Conference Board of Canada.
9 For the new load referenced on page 16, which is associated with potential industrial accounts,
10 FBC works with key account managers who work directly with customers to determine if a new
11 load should be included in the forecast or not. If a new industrial customer is not confirmed, it is
12 not included in the forecast. FBC has not included any new industrial accounts in this forecast.

13

FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 7

1 **5.0 Reference: Exhibit B-1, pages 17-20**

2 5.1 With respect to Figure 3-3, please provide a table setting out the actual annual
3 values of each of the five lines. For the lines setting out the Existing Summer
4 and Winter N-1 Transformer Limits and the New Summer Threshold please
5 provide a breakdown of the contribution of each transformer (i.e., each of the two
6 existing at LEE, the one existing at DGB and the planned new one).

7
8 **Response:**

9 Please refer to the response to BCUC IR1 11.3 for the table setting out the actual peak load
10 values represented in Figure 3-3. This response includes the full data set for Figure 4-1, which
11 is the same data set as Figure 3-3.

12 Please refer to the response to BCUC IR1 7.2 for a description of the existing N-1 Summer and
13 Winter N-1 Transformer Limits.

14 The new Summer Load Threshold is based on the following:

- 15 • The new LEE T2 transformer would have a normal summer rating of 190 MW.
- 16 • The LEE T3 and LEE T4 transformers are likely to be replaced before their ratings
17 become constraints. As described in the response to BCUC IR1 9.1, LEE T4 is expected
18 to be replaced between 2033 and 2038, while LEE T3 is expected to be replaced in
19 2045. The expectation is that these transformers would be rated at 120/160/200 MVA
20 and would therefore have the same 190 MW normal summer rating as the new LEE T2
21 and DGB T2. In this manner, it is expected that the transformers could continuously
22 support up to 570 MW of summer peak load in the event of a single terminal transformer
23 outage (3 x 190 MW = 570 MW).
- 24 • As described in the response to BCUC IR1 14.1, a decision about the future expansion
25 of the Kelowna transmission system will be required at the 550 MW load level; therefore,
26 FBC has established this as the New Summer Threshold on Figure 3-3 rather than the
27 theoretical transformer capability of 570 MW.

28
29

30

31 5.2 Given that it could take a year to procure and install a new transformer at LEE
32 (per page 19, lines 29-30), is it the normal ratings, the emergency limits or some
33 other values for each transformer that are considered when assessing the
34 Kelowna area system's ability to meet the N-1 planning criteria? In responding,
35 please explain why.



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 8

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34

Response:

Both the normal ratings and the emergency limits for a transformer are considered when assessing the ability to meet N-1 planning criteria.

FBC's operating procedures require the post contingency flow to be brought within the emergency rating within 15 minutes and to be reduced within the normal rating level within six hours. Please refer to Section 3.4.1 of the Application for further discussion related to assessment of N-1 scenarios and transformer ratings.

5.3 Please clarify whether the transformer capacities used in Figure 3-3 are based on the emergency limits or the normal ratings.

Response:

Figure 3-3 is based on normal ratings. Please refer to the response to BCUC IR1 7.2 for a description of the 315 MW and 370 MW existing summer and winter N-1 transformer limits.

5.3.1 If normal ratings, please reconcile with the fact that the 550 MW summer system capability after the next transformer addition is based on an incremental emergency capacity of 235 MW (per page 24).

Response:

As described in the response to BCOAPO IR1 5.1, the threshold at 550 MW includes an assumption that the existing LEE T3 and LEE T4 transformers will have been replaced in advance of these transformer ratings becoming a constraint.

Based on expected transformer ratings alone, the limit could be as high as 570 MW. This is due to the fact that LEE T2, T3 and T4 and DGB T2 would all be expected to be capable of continuously supplying 190 MW at summer peak. However, as described in the response to BCUC IR1 14.1, a decision about the future expansion of the Kelowna transmission system will be required at the 550 MW load level. Accordingly, this threshold has been established at 550 MW to recognize that changes to the system may be required.



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 9

1
2
3
4
5
6
7
8
9

5.3.2 If emergency ratings, please reconcile with the response to question 5.2.

Response:

Please refer to the response to BCOAPO IR1 5.3.

FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 10

1 **6.0 Reference: Exhibit B-1, pages 19 and 24**

2 **Preamble:** The Application states:

3 “Power flow simulation studies were used to analyse single contingency
4 scenarios. When either of the two existing LEE terminal transformers is
5 out of service, the loading on the remaining transformer is 191 MVA (91
6 percent of its emergency limit) when the total Kelowna area load reaches
7 315 MW, which is just marginally higher than the forecast summer peak
8 load forecast in 2021, as provided in Table 3-5. The loading on the
9 remaining LEE transformer can be lowered by adjusting the load supply
10 configuration in the Kelowna 138 kV system to transfer additional load to
11 DGB. After system reconfiguration, the flow on the remaining LEE
12 transformer is 168 MVA, which is 80 percent of the emergency limit and
13 100 percent of normal rating”.

14 The Application also states:

15 “The loss of one of the two transformers at LEE is the critical outage for
16 planning purposes. If DGB transformer were to fail, the system could
17 continue to supply all load within normal limits from LEE transformers and
18 138 kV lines”.

19 6.1 Given that the DG Bell transformer is 200 MVA and each of the LEE transformers
20 are only 168 MVA (per page 13), please explain why loss of one of the two
21 transformers at LEE is the critical outage for planning purposes. In responding
22 please indicate what the winter and summer supply capability to Kelowna area is
23 if the transformer at DG Bell is out of service and the basis for the value.

24 **Response:**

25 The loss of a LEE transformer is a more critical outage compared to the outage of the DGB
26 transformer because of the geographical distribution of load in Kelowna. More load is supplied
27 from LEE than from DGB.
28

29 If the transformer at DGB is out of service, the winter and summer supply capabilities for the
30 Kelowna area are as follows:

- 31 • Winter: 385 MW. At this load level, the flow on each of the LEE transformers is
32 approximately 100 percent of the winter normal rating of T3 and T4.
- 33 • Summer: 330 MW. At this load level, the flow on each LEE transformers is
34 approximately 99 percent of the summer normal rating of T3 and T4.
35



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 11

1 The basis of the above limits is the post contingency flow. Current operating procedures allow
2 the post contingency flow to be above the emergency equipment rating for only fifteen minutes
3 and above the normal equipment rating for only six hours and plans to reduce the loading must
4 be implemented within these time frames. Beyond the load levels given above, the post
5 contingency flows cannot be brought within the defined limits.

6
7

8

9 6.2 After the system reconfiguration, what would be the loading on the DG Bell
10 transformer?

11

12 **Response:**

13 After the system reconfiguration, the loading on the DGB transformer is 150 MVA. This is 60
14 percent of the emergency rating of 250 MVA and 75 percent of the normal rating of 200 MVA.

15

16

17

18 6.2.1 If this value is less than 200 MVA, please explain why.

19

20 **Response:**

21 The Kelowna area load is supplied by three 230/138 kV transformers, LEE T3 and T4 and DGB
22 T2. During the critical outage of a LEE transformer, the post contingency flow following system
23 reconfiguration on the remaining LEE transformer is 168 MVA and the DGB transformer is 150
24 MVA.

25 The flow on DGB transformer is less than 200 MVA because of the geographical distribution of
26 load in Kelowna. Under normal conditions, more load is supplied from LEE as compared to
27 DGB. While some load is transferred over to DGB following a contingency and system
28 reconfiguration to reduce the post contingency flow on the remaining LEE transformer, the load
29 supplied from LEE remains higher than DGB because of the geographical distribution of the
30 load.

31



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 13

1 **8.0 Reference: Exhibit B-1, pages 22-23**

2 8.1 Please outline the scope of the DR pilot currently underway in the Kelowna area
3 (i.e., is it open to all potential DR load in the area or just specific customers?) and
4 the basis for the 1.75 MW capacity target.

5
6 **Response:**

7 FBC estimated the DR potential of the largest 53 Commercial and Industrial (C&I) accounts in
8 the Kelowna area. C&I customers were targeted as the best candidates due to their familiarity
9 with demand rates and internal capacity to modify their loads in response to FBC triggered DR
10 Events.

11 Based on informal learning from a BC Hydro commercial DR pilot, FBC anticipated that
12 participation would be lower than the total potential and accordingly set the 1.75 MW winter
13 capacity target below the total DR potential.

14 For the 2020 summer DR phase, FBC has widened C&I recruitment across its electric service
15 territory to assess the potential to scale the DR pilot.

16 Other customer sectors (e.g., residential and small commercial) are billed on energy only rates
17 and are inherently more difficult to recruit. However, FBC is evaluating an additional DR pilot
18 phase that will target a specific area in Kelowna, which is primarily comprised of residential
19 customers.

20



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 15

1 **10.0 Reference: Exhibit B-1, pages 27-27 and 38**

2 **Exhibit A-3, BCUC 1.18.1 and 1.18.4**

3 10.1 With reference to the drawings provided in response to BCUC 1.18.1 and 1.18.4,
4 please demonstrate why “a ring bus configuration results in a more than 50
5 percent reduction in outage minutes per year as compared to a split bus
6 configuration” (per page 27).

7
8 **Response:**

9 Please refer to the diagrams below which demonstrate why a ring bus configuration results in a
10 reduction in outage minutes per year, as compared to a split bus configuration. The analysis
11 assumes the following circumstances:

- 12 • The fault occurs at the T3 connection to the 138 kV station bus; and
13 • The best case time for transferring transmission load between lines in the Kelowna 138
14 kV ring is six minutes.

15
16 The diagrams below illustrate that in a ring bus configuration 55L line remains in service,
17 reducing the customer outage minutes experienced to zero. Conversely, the split bus
18 configuration results in a minimum of 60,780 customer outage minutes. This example illustrates
19 a scenario where a ring bus configuration can potentially reduce outage minutes by 100
20 percent.

21



FortisBC Inc. (FBC or the Company)
 Application for a Certificate of Public Convenience and Necessity for the
 Kelowna Bulk Transformer Addition Project (the Application)

Submission Date:
 July 9, 2020

Response to British Columbia Public Interest Advocacy Centre representing the British
 Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations
 of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource
 and Advisory Centre (BCOAPO) Information Request (IR) No. 1

Page 16

1

Split Bus Configuration	Split Bus Configuration																																
<p>Normal Operating Conditions All Breakers are closed. All LEE Bus 2 BP Switches are normal open. SAU 50-BP and OKM 51-BP are normal open</p> <p>Fault Bus fault at the T3 connection.</p> <p>Protection Scheme Response Assumes no trip coils fail to operations. LEE CB11, CB12, CB55, and T3M trip.</p> <p>Outage Impact Loss of T3 and 55L</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td colspan="2" style="text-align: center;">Customer Outage Minutes</td></tr> <tr><td colspan="2" style="text-align: center;">55L Impacted Stations & Customers</td></tr> <tr><td colspan="2" style="text-align: center;">Hollywood Substation</td></tr> <tr><td>Customer Count</td><td style="text-align: right;">10130</td></tr> <tr><td>Restoration Source</td><td>Restore via 50L</td></tr> <tr><td>Restoration Time</td><td style="text-align: right;">6</td></tr> <tr><td colspan="2" style="text-align: center;">Split Bus Outage Minutes</td></tr> <tr><td>Total Customer Outage Minutes</td><td style="text-align: right;">60780</td></tr> </table>	Customer Outage Minutes		55L Impacted Stations & Customers		Hollywood Substation		Customer Count	10130	Restoration Source	Restore via 50L	Restoration Time	6	Split Bus Outage Minutes		Total Customer Outage Minutes	60780	<p>Normal Operating Conditions All bus breakers are normal closed. SAU 50-BP and OKM 51-BP are normal open</p> <p>Fault Bus fault at the T3 connection.</p> <p>Protection Scheme Response Assumes no trip coils fail to operations. LEE CB16, CB18, CB4, and CB5 trip</p> <p>Outage Impact Loss of T3.</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td colspan="2" style="text-align: center;">Customer Outage Minutes</td></tr> <tr><td colspan="2" style="text-align: center;">55L Impacted Stations & Customers</td></tr> <tr><td colspan="2" style="text-align: center;">Hollywood Substation</td></tr> <tr><td>Customer Count</td><td style="text-align: right;">10130</td></tr> <tr><td>Restoration Source</td><td style="text-align: center;">N/A</td></tr> <tr><td>Restoration Time</td><td style="text-align: right;">0</td></tr> <tr><td colspan="2" style="text-align: center;">Ring Bus Outage Minutes</td></tr> <tr><td>Total Customer Outage Minutes</td><td style="text-align: right;">0</td></tr> </table>	Customer Outage Minutes		55L Impacted Stations & Customers		Hollywood Substation		Customer Count	10130	Restoration Source	N/A	Restoration Time	0	Ring Bus Outage Minutes		Total Customer Outage Minutes	0
Customer Outage Minutes																																	
55L Impacted Stations & Customers																																	
Hollywood Substation																																	
Customer Count	10130																																
Restoration Source	Restore via 50L																																
Restoration Time	6																																
Split Bus Outage Minutes																																	
Total Customer Outage Minutes	60780																																
Customer Outage Minutes																																	
55L Impacted Stations & Customers																																	
Hollywood Substation																																	
Customer Count	10130																																
Restoration Source	N/A																																
Restoration Time	0																																
Ring Bus Outage Minutes																																	
Total Customer Outage Minutes	0																																

2

3



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 17

1 10.2 With reference to the drawings provided in response to BCUC 1.18.1 and 1.18.4,
2 please demonstrate why “a breaker failure on a split bus causes a larger outage
3 than on a ring bus” (per page 27).

4
5
6 **Response:**

7 Please refer to the diagrams below which demonstrate why a breaker failure on a split bus
8 causes a larger outage than on a ring bus configuration. The analysis assumes the following
9 circumstances:

- 10 • The fault occurs at the T3 connection to the 138 kV station bus;
- 11 • The best case time for transferring transmission load between lines in the Kelowna
12 138kV ring is six minutes; and
- 13 • The best case time for restoring a line to the system via a by-pass switch in the split bus
14 configuration is 2-hours.


15
16 The diagrams below illustrate that the customer outage minutes experienced in a ring bus
17 configuration are reduced to 31,014 minutes. Conversely, the split bus configuration results in a
18 minimum of 1,895,820 customer outage minutes. This example illustrates a scenario where a
19 ring bus configuration can potentially reduce outage minutes by 98 percent.

20



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 18

Split Bus Configuration



Normal Operating Conditions All Breakers are closed. All LEE Bus 2 BP Switches are normal open. SAU 50-BP and OKM 51-BP are normal open


Fault Bus fault at the T3 connection.

Protection Scheme Response Normal Protection Scheme: LEE CB11, CB12, CB55, and T3M trip. Bus Breaker (CB11) fails to operate. Secondary Protection Trips CB10 and CB17.

Outage Impact Loss of T3, 55L, and 50L

Customer Outage Minutes	
55L Impacted Stations & Customers	
Hollywood Substation	
Customer Count	10130
Restoration Source	Restore via 51L
55L Restoration Time	6
50L Impacted Stations	
Glenmore Substation	
Customer Count	9787
Recreation Substation	
Customer Count	5505
Restoration Source	Restore through 50-BP
50L Restoration Time	120
Split Bus Outage Minutes	
Total Customer Outage Minutes	1895820

Split Bus Configuration



Normal Operating Conditions All bus breakers are normal closed. SAU 50-BP and OKM 51-BP are normal open

Fault Bus fault at the T3 connection.

Protection Scheme Response Normal Protection Scheme: LEE CB16, CB18, CB4, and CB5. Bus Breaker (CB18) fails to operate. Secondary Protection Trips CB19

Outage Impact Loss 46L and T3

Customer Outage Minutes	
46L Impacted Stations & Customers	
Duck Lake Substation	
Customer Count	1559
Ellison Substation	
Customer Count	3610
Restoration Source	Restore via 50L
50L Restoration Time	6
Ring Bus Outage Minutes	
Total Customer Outage Minutes	31014



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 19

1 10.3 With reference to the drawings provided in response to BCUC 1.18.1 and 1.18.4,
2 please demonstrate why “the ring bus configuration is easier to maintain and
3 operate than split bus because any single breaker can be taken out of service
4 without the need for bus reconfiguration” (per page 27).

5
6 **Response:**

7 With a ring bus configuration, the operation and protection scheme of the station are unaffected
8 by an outage of any one element. Conversely, in a split bus configuration, removing a station
9 element from service leads to complicated offloading, switching and isolation procedures, which
10 could differ between each element, depending on the station set up.

11 The demonstration on the following page assumes the following circumstances:

- 12 • CB16 is undergoing maintenance;
13 • The best case time lapses for isolation and restoration; and
14 • Restoration takes approximately the same time as isolation.

15
16 The demonstration illustrates that in a ring bus configuration, the isolation and restoration
17 procedure is shorter and takes less time to implement at approximately 3.25 hours. Conversely,
18 the split bus configuration requires a minimum of 13 hours to perform all of the preparation and
19 implementation. This example illustrates approximately a time savings of approximately 75
20 percent.

21 Furthermore, the demonstration below illustrates that in a split bus configuration, two
22 transmission lines are protected on the same relay scheme under maintenance conditions. This
23 reduces the system reliability because a transmission fault would result in larger customer
24 outage impact for a longer duration of time. In comparison, a ring bus maintains an independent
25 transmission line protection scheme.

Split Bus Configuration

Normal Operating Conditions All Breakers are closed. All LEE Bus 2 BP Switches are normal open. SAU 50-BP and OKM 51-BP are normal open

Maintenance Zone CB16

Restoration Assumes Restoration Through 55-BP via 50L CB (CB17).
 Switchman contacts Control Centre
 SCC performs external contacts to inform switching to start.
 While maintaining communication between the site crew and Control Centre:

Isolation Procedure (Sample)

- On-site crew performs relay settings changes & test alterations.
- On-site crew closes LEE BP-55 (Energizes by-pass bus).
- On-site crew closes LEE BP-50 (Parallels 50L and 55L).
- Control Centre performs of paralleling confirmation.
- Control Centre opens CB16.
- On-site crew confirm CB16 open.
- On-site crew opens 16-1 and 16-2.

Reliability Impact 2 transmission lines are now protected by 1 relay scheme. Larger and longer customer outages in a transmission line fault.

	Best Case Scenario
Engineering P&C Prep. Time	4 hours
Crew Prep. Time	4 hours
Control Centre Prep Time	1 hour
On-site Isolation Time	2 hours
On-site Restoration Time	2 hours
Total Isolation/Restoration Time	13 hours

Split Bus Configuration

Normal Operating Conditions All bus breakers are normal closed. SAU 50-BP and OKM 51-BP are normal open

Maintenance Zone CB16

Restoration Continual supply via ring bus.

Protection Scheme Response

Switchman contacts Control Centre
 SCC performs external contacts to inform switching to start.
 While maintaining communication between the site crew and Control Centre:

- Control Centre opens CB16.
- On-site crew confirm CB16 open.
- On-site crew opens 16-1 and 16-2.

Reliability Impact All transmission line still protected by independent protection scheme.

	Best Case Scenario
Engineering P&C Prep. Time	0 hours
Crew Prep. Time	2 hours
Control Centre Prep Time	15 minutes
On-site Isolation Time	30 minutes
On-site Restoration Time	30 minutes
Total Isolation/Restoration Time	3.25 hours



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 21

1
2 10.4 With reference to the drawings provided in response to BCUC 1.18.1 and 1.18.4,
3 please demonstrate why “the ring bus configuration has less complicated
4 protection and switching schemes than split bus because each transformer and
5 transmission line has its own discrete node in the bus between two breakers”
6 (per page 27).
7

8 **Response:**

9 In a split bus configuration, there are multiple branches of the system (i.e., transformer and
10 transmission line) protected from the same node. As a result, the protection scheme is
11 configured to isolate the multiple branches of the system in fault. Under maintenance
12 conditions, this scheme requires numerous changes to isolate a single device.

13 In comparison, a ring bus configuration applies a single protection scheme to a single system
14 branch. As a result, in a fault, the system only isolates one branch. In a maintenance event,
15 single branches can be isolated without any changes required to the protection scheme.

16 These outcomes are demonstrated for the system in fault in the response to BCOAPO IR1 10.1
17 and under maintenance conditions in the response to BCOAPO IR1 10.3.

18

FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 22

1 **11.0 Reference: Exhibit B-1, page 26**

2 **Preamble:** The Application states:

3 “The ring bus configuration reduces safety risk as compared to split bus
4 because it provides a clear zone of isolation when working on equipment
5 that is free from complex transfer buses and switches”.

6 The Application also states:

7 “The ring bus configuration is less prone to human error when operating,
8 resulting in fewer instances of mis-operation than a split bus”.

9 11.1 It is noted that FBC has a number of terminal stations with a ring bus
10 configuration (per page 27). In the last five year how many safety incidents have
11 occurred at the LEE terminal station as compared to comparable terminal
12 stations with a ring bus configuration (please discuss both actual safety incidents
13 leading to injury/lost time as well as “near” incidents).

14
15 **Response:**

16 In the last five years, there have been no safety, near miss or human error incidents at LEE
17 terminal station. With comprehensive work methods, training, and the diligent safety focus of
18 personnel, it is possible to operate and maintain the existing LEE terminal station. Please also
19 refer to the response to BCUC IR1 17.5 for a discussion of additional measures for the LEE
20 terminal station.

21 The lack of incidents at LEE terminal station does not imply that the split bus configuration is low
22 risk. A safety incident in this type of terminal has a very high consequence potential. Therefore,
23 even if the frequency of past incidents or probability of future incidents is low, the risk is high.
24 Please also refer to the response to BCUC IR1 12.4 for a discussion of the reduction in safety
25 risk of a ring bus versus split bus configuration.

26
27

28
29 11.2 In the last five years what was the number of human error incidents at LEE
30 related to the split bus configuration and how does this compare with the number
31 of human error incidents at comparable stations with a ring bus configuration?
32

33 **Response:**

34 Please refer to the response to BCOAPO IR1 11.1.

FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 23

1 **12.0 Reference: Exhibit B-1, pages 28 and 38**

2 **Exhibit A-3, BCUC 1.18.1**

3 **Preamble:** The Application states:

4 “Construction would include the expansion of the existing 230 kV ring bus
5 by one breaker to accommodate the additional transformer. This involves
6 the addition of two new 230 kV circuit breakers (one of which will replace
7 an existing obsolete breaker).

8 The 138 kV bus would be reconfigured from a split bus to a seven
9 breaker ring bus. This portion of the work would include relocating three
10 existing breakers to new locations, salvaging four existing obsolete
11 breakers, and installing three new breakers. The total 138 kV breaker
12 count would decrease from ten to nine, as there are two 138 kV breakers
13 that are used for switching the existing capacitor banks in addition to
14 those in the new seven breaker ring.”

15 12.1 With reference to the simple line drawing of the current configuration of the LEE
16 terminal station (provided in response to BCUC 1.18.1), please identify the
17 equipment that, under Alternative A, will be: i) replaced, ii) relocated or iii)
18 removed.

19
20 **Response:**

21 In this response, FBC assumes the question is intended to reference the response to BCUC IR1
22 18.2. With reference to the simplified diagram provided in that response, under Alternative A
23 the following breakers would be:

- 24 • Replaced:
 - 25 ○ CB18 (138 kV)
- 26 • Relocated:
 - 27 ○ CB11 (138 kV)
 - 28 ○ CB15 (138 kV)
 - 29 ○ CB16 (138 kV)
- 30 • Removed:
 - 31 ○ CB1 (230 kV)
 - 32 ○ CB17 (138 kV)



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 24

- 1 ○ CBT3M (138 kV)
- 2 ○ CBT4M (138 kV)
- 3

FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 25

1 **13.0 Reference: Exhibit B-1, pages 35 and 53**

2 **Preamble:** The Application states: “The schedule risk is more complex and requires
3 transmission line outages for Alternative A”.

4 The Application also states: “Outage windows required for 138 kV
5 transmission lines can be accommodated; and Outage windows required
6 for modifications to 230 kV ring bus can be accommodated”.

7 13.1 Please describe the number and duration of transmission line outages that will be
8 required for Alternative A. Please also outline when during the project schedule
9 (per Figure 5-3) these are expected to be required.

10

11 **Response:**

12 The transmission line outages required under Alternative A are as follows:

- 13 • 50L Transmission circuit: 3-4 day outage for structure replacement and cutovers – to be
14 scheduled during Phase 4, Stage 1.
- 15 • 55L Transmission circuit: 3-4 day outage for structure replacement and cutovers – to be
16 scheduled during Phase 4, Stage 1 subsequent to 50L return of service.
- 17 • 58L Transmission circuit: 2-3 day outage for structure replacement and cutovers – to be
18 scheduled during Phase 4, Stage 1 subsequent to 55L return of service.
- 19 • 55L Transmission circuit: 1 day outage for cutovers to new A-Frame – to be scheduled
20 during Phase 4, Stage 4.
- 21 • 58L Transmission circuit: 1 day outage for cutovers to new A-Frame – to be scheduled
22 during Phase 4, Stage 4 subsequent to 55L return of service.
- 23 • 46L Transmission circuit: 1 day outage for cutovers to new A-Frame – to be scheduled
24 during Phase 4, Stage 5.
- 25 • 50L Transmission circuit: 1 day outage for cutovers to new A-Frame – to be scheduled
26 during Phase 4, Stage 7.

27

28 FBC expects that customers will be unaffected by the Transmission line outages required to
29 reconfigure the lines for Alternative A. All transmission line work will be completed with only one
30 transmission circuit de-energized at a time, and hence uninterrupted service to the area
31 Substations via the Kelowna Transmission Ring System. Transmission line outages would be
32 coordinated as best as possible to minimize risk exposure as the system operates in an N-1
33 condition. Cutovers would be scheduled during optimal conditions, such as non-peak load
34 situations and favourable weather forecast.



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 26

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34

13.2 Would Alternative B require transmission line outages?

13.2.1 If yes, please describe the number and duration of transmission line outages that will be required.

Response:

The transmission outages that would be required under Alternative B are as follows:

- 50L Transmission circuit: 4-5 day outage for structure replacement and cutovers.
- 46L Transmission circuit: 3 day outage for cutovers subsequent to 50L return of service.
- 55L Transmission circuit: 3-4 day outage for structure replacement and cutovers subsequent to 46L return of service; and
- 50L and 55L Transmission circuits: Common 4 hour brief outage for circuit tie-in conductor work. Common 50L/55L outage can be completed without interruption to customers.

Aside from the 50L and 55L common outage (which may be completed without interruption to customers), all transmission line work would be completed with only one transmission circuit de-energized at a time, and hence uninterrupted service to the area distribution substations via the Kelowna Transmission Ring System. Transmission line outages would be coordinated as best as possible to minimize risk exposure as the system operates in an N-1 condition. Cutovers would be scheduled during optimal conditions, such as non-peak load situations and favourable weather forecast.

13.3 To what extent will customers be affected by the transmission line outages required for Alternative A?

Response:

Please refer to the response to BCOAPO IR1 13.1.



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 27

1
2 13.4 To what extent would customers be affected by the transmission line outages
3 required (if any) for Alternative B?

4
5 **Response:**

6 Please refer to the response to BCOAPO IR1 13.2.1.

7

FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 28

1 **14.0 Reference: Exhibit B-1, pages 35-36**

2 **Preamble:** The Application states (page 35): “FBC also rejects Alternative C on the
3 basis of the financial evaluation”.

4 The Application states (page 36): “From a financial perspective, the rate
5 impact of Alternative A is approximately 0.10 percentage points higher
6 than Alternative B.”

7 The Application also states (page 36): “Of the three alternatives
8 considered, Alternative A provides the best technical solution.On
9 this basis, Alternative A is selected as the preferred solution for the KBTA
10 Project.”

11 14.1 How much higher would the rate impact from Alternative A need to be in order for
12 Alternative B to be considered the “preferred solution”?

13
14 **Response:**

15 FBC did not utilize a threshold rate increase to compare and select amongst project
16 alternatives. Rather, the determination of the preferred alternative for the KBTA Project is
17 based on a balanced approach as set out in Section 4.5 of the Application. In addition to the
18 financial analysis and rate impacts, the determination included the ability of the alternative to
19 meet the planning criteria, the safety and operability of the alternative, the impact on system
20 reliability, the potential for future expansion, and the associated project risk.

21 As demonstrated in Table 4-1, Alternative A is superior to Alternative B in all technical aspects
22 evaluated, is approximately equivalent in terms of project risk, and has a slightly higher rate
23 impact than Alternative B. On balance, Alternative A is a superior solution in FBC’s view.

24



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 29

1 **15.0 Reference: Exhibit B-1, pages 54-55**

2 15.1 If not considered confidential, please provide total value of the assets that will be
3 placed in-service each year (i.e., without the plant asset account detail).

4
5 **Response:**

6 The following table provides the total value of assets, including removal costs that will be placed
7 into service each year.

Item \$000's	2022	2023	2024	Total
Construction	1,340	20,206	774	22,320
Removal	711	257	-	968
Total	2,052	20,462	774	23,288

8

9



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 30

1 **16.0 Reference: Exhibit B-1, page 57**

2 16.1 To date, has any further information been requested by the City of Kelowna?

3 16.1.1 If yes, what has been requested and what has been provided?

4

5 **Response:**

6 Please refer to the response to BCUC IR1 31.1.

7



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 31

1 **17.0 Reference: Exhibit B-1, pages 4 and 58**

2 17.1 Is the Project survey referenced on page 4 the same survey as the on-line survey
3 referenced on page 58 (line 10)?

4 17.1.1 If not, to whom was the Project survey referenced on page 4 distributed,
5 overall, how many parties/persons were surveyed, what issues did the
6 survey address and how many responses were received?
7

8 **Response:**

9 Confirmed. The Project survey mentioned on page 4 of the Application and the on-line survey
10 mentioned on page 58 refer to the same survey available on the Project webpage.

11



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 32

1 **18.0 Reference: Exhibit B-1, Appendix F**

2 18.1 The Draft Order for the Project's approval provided in Appendix F makes
3 reference to both Quarterly Reports and a Final Report being filed with the
4 BCUC.

5 18.1.1 Is it FBC's intention that these Reports be available publicly?

6 18.1.2 If not, why not?

7 18.1.3 If yes, how does FBC propose to do so?

8
9 **Response:**

10 FBC does not intend to make the reports publicly available. FBC files its progress and final
11 reports for CPCN projects with the BCUC on a confidential basis. Included in the reports is
12 detailed cost information which has been determined by the BCUC to be confidential during the
13 regulatory proceeding because of the potential for its disclosure to prejudice FBC's negotiating
14 position when procuring contracts, including contracts for future projects. Ongoing scrutiny of a
15 project by external parties following BCUC approval is unnecessary under normal
16 circumstances; one of the BCUC's roles is to review the quarterly reports and, if necessary,
17 requests further information to monitor the progress of projects it has approved. Finally, FBC
18 provides information about its approved CPCN projects, including forecast costs, in its Annual
19 Reviews for rate setting purposes.

20



FortisBC Inc. (FBC or the Company) Application for a Certificate of Public Convenience and Necessity for the Kelowna Bulk Transformer Addition Project (the Application)	Submission Date: July 9, 2020
Response to British Columbia Public Interest Advocacy Centre representing the British Columbia Old Age Pensioners' Organization, Council of Senior Citizens' Organizations of BC, Active Support Against Poverty, Disability Alliance BC, and the Tenant Resource and Advisory Centre (BCOAPO) Information Request (IR) No. 1	Page 33

1 **19.0 Reference: Exhibit E-1 and Exhibit E-2**

2 19.1 To date two Letters of Comment have been posted on the Commission's
3 website, both addressing issues regarding aesthetic improvement. Please
4 outline FBC's plans to address the issues raised.

5
6 **Response:**

7 Please refer to the response to BCUC IR1 32.4 which describes FBC's intentions regarding
8 aesthetic improvements to the station.