

Diane Roy Vice President, Regulatory Affairs

Gas Regulatory Affairs Correspondence Email: gas.regulatory.affairs@fortisbc.com

Electric Regulatory Affairs Correspondence Email: <u>electricity.regulatory.affairs@fortisbc.com</u> FortisBC 16705 Fraser Highway Surrey, B.C. V4N 0E8 Tel: (604)576-7349 Cell: (604) 908-2790 Fax: (604) 576-7074 www.fortisbc.com

December 23, 2021

Residential Consumer Intervener Association c/o Midgard Consulting Inc. Suite 828 – 1130 W Pender Street Vancouver, B.C. V6E 4A4

Attention: Mr. Peter Helland, Director

Dear Mr. Helland:

Re: FortisBC Inc. (FBC)

2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 1

On August 4, 2021, FBC filed the Application referenced above. In accordance with the regulatory timetable established in British Columbia Utilities Commission Order G-314-21 for the review of the Application, FBC respectfully submits the attached response to RCIA IR No. 1.

If further information is required, please contact the undersigned.

Sincerely,

FORTISBC INC.

Original signed:

Diane Roy

Attachments

cc (email only): Commission Secretary Registered Parties FORTIS BC^{**}

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 1

1 **1.0 Reference Exhibit B-1, Volume 1, Page ES-1**

Executive Summary, Section 1 - Introduction

3 FortisBC Inc. states:

1.1.

"The analysis in this LTERP shows that FBC does not require any new supply-side resources until at least 2030, based on the Reference Case load forecast, existing resources and contracts in place, continued access to reliable and cost-effective market energy, and the proposed level of DSM. This is because optimization of market purchases and existing resources, including the power purchase agreement (PPA) with BC Hydro, provide FBC with enough energy and capacity until 2030 to meet customers' requirements in a cost-effective and reliable manner."

11 12

2

4

5 6

7

8

9

10

Please describe and quantify the load increase scenarios that could trigger the need for new supply-side resources prior to 2030.

13

14 **Response:**

FBC's LTERP, and corresponding load-resource balance, reflect the Reference Case load forecast. There are multiple potential load scenarios not reflected in the Reference Case load forecast that have the potential to trigger the need for new supply-side resources prior to 2030. These range from defined load scenarios such as increased efforts towards electrification, to a new large load connecting to FBC's system. These load scenarios can impact supply-side resource requirements, including the timing of when resources are required, as shown in Figure 11-4 of Section 11.3.4.

The table below quantifies FBC's projected available capacity, and therefore, the increases in load that would be required to trigger the need for new supply-side resources prior to 2030, regardless of the underlying reason. Projected available capacity is stated based on the Reference Case load forecast, after the base level of DSM, and assuming maximum PPA capacity (200 MW). Furthermore, 75 MW of market access for capacity purposes in June has been included.

Year	June (MW)	Summer (MW)	Winter (MW)
2021	46	35	54
2022	39	26	50
2023	41	29	50
2024	43	30	45
2025	37	23	86
2026	74	63	81
2027	68	57	73
2028	34	10	26

FORTIS BC^{*}

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Submission Date: December 23, 2021

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 2

Year	June	Summer	Winter
	(MW)	(MW)	(MW)
2029	27	1	17

1 On a long-term planning basis, FBC has adopted a capacity self-sufficiency requirement. On an

operational basis, if small gaps emerged through the years of 2021-2025, prior to the expiry of
 the RCA which adds approximately 50 MW of capacity in all months, FBC would expect to bridge
 the gap through market black purchases. Furthermore, the table above assumes the BBX

4 the gap through market block purchases. Furthermore, the table above assumes the BRX 5 contract is not renewed after 2027, although FBC may explore the viability of this option in the 6 future. Therefore, FBC anticipates a sustained and ongoing increase in load greater than 7 approximately 50 MW beyond the Reference Case load forecast would trigger the need for new 8 resources prior to 2030.

9

10

- 11 12
- 1.2. What level of EV uptake would cause FBC to require new supply-side resources earlier than 2030?
- 13 14

15 Response:

Please refer to the response to RCIA IR1 1.1 regarding the load level that would cause FBC torequire new supply-side resources earlier than 2030.

EV charging is forecasted to have a load impact of 9 MW in all months by the year 2025 and a load impact of 28 MW in all months by the year 2030. The Reference Case load forecast does not include any EV charging mitigation programs, which reduce the capacity impacts of EV charging. Therefore, the EV impacts embedded into the Reference Case forecast likely reflect a value closer to the upper bound of the requirement for new supply-side resources. If EV uptake grows at a faster rate than projected, FBC would correspondingly increase efforts to implement

24 other EV peak shifting options as outlined in Section 2.3.2 of the Application.

FORTIS BC^{**}

(IR) No. 1

Page 3

1	2.0	Refere	ence Exhibit B-1, Volume 1, Page ES-7							
2			Executive Summary, Section 3 - Long-Term Load Forecast							
3	FortisBC Inc. states:									
4 5 6 7 8 9		"The Reference Case winter and summer peak forecasts do not include any electric vehicle charging peak mitigation (i.e. shifting EV charging loads from peak periods). This is because FBC currently has no EV charging mitigation programs in place and has no certainty, at this point, how much EV charging it will be able to shift off peak periods. The Reference Case load forecast is also presented before any DSM measures – these are discussed in Executive Summary, Section 8"								
10 11		2.1.	Please confirm that FBC plans to implement a residential EV charging peak mitigation pilot program.							
12 13			2.1.1. If yes, what are the expected or desired outcomes of this pilot program?							
14	<u>Respor</u>	<u>ise:</u>								
15 16 17 18 19	FBC co mitigatio load in t peak mi demano	onfirms on pilo he lon itigatio I respo	that, as described in Section 2.3.2, it is expected that the EV charging peak t will help inform FBC on the effectiveness of software-based tools for shifting EV g term, as well as how best to engage customers for participation in an EV charging n program. The Company is also piloting a load-control pilot as part of the C&EM onse pilot described in Section 2.3.7.5.							
20										
21 22										
23 24 25		2.2.	Has FBC estimated the level of peak shifting that is likely to be achieved by fully implementing an EV charging peak mitigation program?							
26 27			2.2.1. If yes, please quantify.							
28	<u>Respor</u>	nse:								
29 30 31 32 33 34	As note light-dut EV cha demanc mitigatic at home	d in th ty EV o rging p l asso on prog e, resul	ie Section 2.3.2 of the Application, Guidehouse has estimated that 80 percent of charging will occur at home, and would potentially be eligible for participating in an beak mitigation program (i.e. 120 MW of the overall 150 MW of estimated peak ciated with EV charging by 2040). It is estimated that an EV charging peak gram may be able to shift up to 75 percent of this peak demand from EV charging lting in 90 MW that could potentially be shifted by 2040.							

- 34 at home, resulting in 90 MW that co
- 35

FORTIS BC^{*}

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 4

1 2

3

4

2.2.2. What technology changes or developments must be made to enable implementation of an effective EV peak-shifting program?

5 **Response:**

6 The proposed software-based peak-shifting approach, as described in Section 2.3.2, will 7 generally require only the installation of software by the customer and FBC. In the rare cases 8 where the customer's EV is not compatible with the software, FBC expects that compatible home 9 chargers will be available for purchase by the customer. The Company is also piloting a load-10 control pilot as part of the C&EM demand response pilot described in Section 2.3.7.5. This pilot 11 will likely require the customer to install a Level 2 charger that can be connected to WiFi and 12 controlled remotely.

- 13
- 14

15

162.2.3.Please quantify the anticipated capital and operating costs of fully17implementing an effective EV peak-shifting program. Would FBC expect18to recover the capital and operating cost of implementing an effective EV19peak-shifting program from EV users, or from all its customers (including20those who do not own or operate EVs)?

2122 **Response:**

At this time, FBC does not have comprehensive information on the anticipated capital and operating costs of fully implementing an EV peak-shifting program. However, it is expected that the planned EV charging peak mitigation pilot and the CE&M demand response pilot programs will help further develop these estimated costs. Given that the benefit of load-shifting activities for EV charging accrue to all customers, FBC would expect to recover costs from all customers similar to current cost recovery mechanisms for other DSM measures.



(IR) No. 1

1 3.0 Reference Exhibit B-1, Volume 1, Page ES-10

2 3

Executive Summary, Section 5 - FBC Existing Supply-Side Resources

4 FortisBC Inc. states:

5 "FBC will sell the remaining surplus WAX CAPA residual capacity to Powerex on a day-6 ahead basis, under the terms of the CEPSA, if and when the capacity is not required to 7 meet FBC load requirements. Brilliant Expansion (BRX) entitlement contracts with FBC 8 and BC Hydro expire at the end of 2027 and renewal is not assumed beyond that date. 9 The entire set of capacity and energy entitlements attributed to BRX will be assessed as 10 a future option to meet FBC's resource needs."

- 113.1.Please describe and quantify any cost or revenue impacts associated with the BRX12contract expiry.
- 13

14 **Response:**

15 FBC is unable to quantify such costs at this time as it is not yet known if FBC will be able to

- 16 contract for this power or not in the future. Furthermore, if FBC were to speculate on the nature
- 17 of these costs, it could disadvantage FBC in any future negotiations to contract for this power.

FORTIS BC^{**}

2

4 5

6

7

8

9

10

13

(IR) No. 1

Page 6

Exhibit B-1, Volume 1, Page ES-14 1 4.0 Reference

Executive Summary, Section 10 - Supply-Side Resource Options

FortisBC Inc. states: 3

"The PPA, battery storage and gas-fired power plants using conventional natural gas or renewable natural gas (RNG) as fuel are the lowest cost capacity resources available. Although FBC is currently comfortable with relying on market purchases for some of its energy needs, relying on market purchases for capacity over the long term can be risky in terms of availability. There is no guarantee that FBC will be able to access market capacity supply reliably and cost effectively. The month of June, however, is the exception to FBC requiring capacity self-sufficiency for LTERP planning purposes."

11 4.1. Why is Fortis not including carbon neutral natural gas (i.e., natural gas with carbon 12 offsets) in its list of available generation fuels?

14 **Response:**

15 Under the BC Government's Carbon Neutral program, legislated under the Climate Change 16 Accountability Act,¹ the Province has operated an emissions offset system since 2009 to attain 17 carbon-neutral government operations. Offsets under this regulated program are made in BC, 18 are incremental, and are validated and verified to Provincial standards. This regulated carbon 19 offset program currently does not extend to the private sector, and therefore any use of carbon 20 offsets in BC to create "carbon neutral" gas are voluntary and are at risk of not being recognized 21 by the provincial and federal governments. Until such time that a regulated carbon offset system 22 is in place provincially or federally, FBC cannot rely on carbon offsets to satisfy its CleanBC 23 targets.

24 Note that this also applies to the use of Renewable Energy Certificates (RECs) in BC to reduce 25 the carbon footprint of electricity, as the Province currently does not officially recognize the use 26 of RECs in BC.

27 28 29 30 4.1.1. If Fortis is able to secure supplies of carbon-neutral natural gas, how 31 would it change the analysis of fuel costs for the different capacity 32 resources? 33

34 Response:

35 If the Province were to officially recognize carbon offsets used to create abated gas, FEI may 36 include it into the broader RNG portfolio making both the product and tariff the same as RNG from

https://www2.gov.bc.ca/gov/content/environment/climate-change/planning-and-action/legislation#ccaa 1

(/	FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: December 23, 2021
FORTIS BC ^{**}	Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1	Page 7

a customer perspective. FEI has previously engaged with potential suppliers of abated natural
gas to understand various aspects including the regulatory framework, certification process,
supply models, and indicative costs. This preliminary market feedback indicated that abated
natural gas could be produced in relatively large volumes with low carbon intensity and at a lower
cost compared to RNG. As such, if FEI were to include abated natural gas into the broader RNG

6 portfolio, it would serve to lower the overall portfolio price.



Page 8

1 5.0 Reference Exhibit B-1, Volume 1, Page ES-16

Executive Summary, Section 11 - Portfolio Analysis

3 FortisBC Inc. states:

"First, based on the Reference Case load forecast, FBC has no need for incremental generation resources until 2030. If FBC is able to shift some level of EV charging from peak periods, the need for new resources could be pushed out until at least 2031. Under higher load scenarios, FBC may need new resources as early as 2025."

- 5.1. What are the potential peak shaving mechanisms considered and what are the earliest dates they could be operational?
- 9 10

2

4 5

6

7

8

11 Response:

In September 2021, FBC began working on a demand-response pilot program for residential electricity customers within the Kelowna area, which includes electric vehicle chargers within its scope. The program uses an automated demand-response signal that will be sent to the EV charger to shift its operation to non-peak times. FBC expects to begin customer recruitment for the pilot in late 2021 with DR events beginning in early 2022.

17 For a future phase of the demand response program, FBC is also exploring residential EV 18 charging load-shifting through software that will allow the customer to choose when they charge. 19 Under this approach, the software will let customers select when to charge and FBC will only need 20 to receive data validating that the EV load shifting actually occurred. At this time, FBC believes 21 this to be the leading approach for shifting residential EV charging load as it will accommodate 22 the majority of customers regardless of their installed charging station. Ideally, FBC aims to incent 23 residential customers to shift their EV charging behavior without necessarily requiring a demand-24 response capable EV charger.

25 FBC is also exploring demand response behavioral "nudges" through email and SMS via FBC's

existing *My energy use* portal. No decision on implementation has been made nor has a timeline been determined.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)



6.0

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Section 1.4.2 - BC Clean Energy Act Objectives

Page 9

1 CHAPTER 1: INTRODUCTION

2

Reference Exhibit B-1, Volume 1, Page 10

3 4

FortisBC Inc. states in Table 1-3 item 2(c):

5 "The requirement in section 19 of the CEA to take actions to meet this target applies only 6 to BC Hydro or a prescribed utility. FBC-owned resources and long-term contracts are 7 hydro-based. BC Hydro resources are currently nearly 98 percent clean. FBC alternative 8 and preferred portfolios include clean or renewable resources and the preferred portfolios 9 are at least 99 percent clean."

- 10 6.1. Does FBC's "99 percent clean" portfolio include energy purchased from BC Hydro?
- 11

12 Response:

FBC confirms that all portfolios include energy purchased from BC Hydro under the PPA throughout the planning horizon, with the exception of portfolios F4 and F5, which include PPA purchases up to the end of September 2033, when the PPA expires.

- 16
- 17
- 17
- 18
- 19 20

21

- 6.2. Please confirm that BC Hydro (via its subsidiary PowerEx) trades energy with jurisdictions that have less than "99 percent clean" energy.
- 22 <u>Response:</u>
- 23 Confirmed.
- 24
- 25
- 26
- 6.3. How does FBC ensure that energy purchased from BC Hydro remains "99 percent
 clean" and does not include traded energy from markets with much higher carbon
 intensity portfolios?
- 30

31 **Response:**

FBC cannot ensure that energy purchased from the PPA under BC Hydro remains "99 percent
 clean", as FBC receives a mix of BC Hydro's resources as a whole.² As such, FBC has applied

² BCUC Decision: PPA RS3808, 3.4 Embedded Cost Power, Page 13-14, May 6, 2014. <u>https://www.bcuc.com/Documents/Proceedings/2014/DOC_41321_05-06-2014_BCH_PPA-RS%203808-TS-No-2-and-3_Decision.pdf</u>



- an average grid emission factor reflective of BC Hydro's system as a whole in order to model the
 emissions associated with energy purchases under the PPA.
- 3 However, FBC can work with Powerex to ensure that energy purchased from the wholesale
- 4 market is clean electricity based on BC requirements. Please also refer to the response to BCUC
- 5 IR1 1.9.
- 6

FORTIS BC^{**}

3

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Submission Date: December 23, 2021

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1 $\,$

Page 11

1 CHAPTER 2: PLANNING ENVIRONMENT

2 7.0 Reference Exhibit B-1, Volume 1, Page 18 & 19

Section 2.2.1 – Climate Change

4 **FortisBC Inc. stated:**

"The following figure shows the projected future average temperature increases for winter 5 and summer months in Canada. The figures with titles including 'RCP2.6' relate to a low 6 7 GHG emission scenario while those including 'RCP8.5' relate to a high GHG emission 8 scenario. The figures indicate average temperature increases in BC in the order of 1 to 2 9 degrees Celsius for summer and winter periods from 2031 to 2050. The figures are not 10 specific to the FBC service area but do illustrate possible general trends for Canada and 11 BC in the future and provide a useful range for informing FBC's climate change load driver within its load scenarios (discussed in Section 4). While the figures relate to average 12 13 warming temperatures over time, they do not capture the increase in the weather and 14 temperature volatility that has occurred in recent years and which is expected to continue 15 in the future."



Figure 2-1: Projected Winter and Summer Temperature Changes¹⁸



2

3

7.1. What are FBC's anticipated winter peak demand and winter energy consumption reductions associated with RCP2.6 and RCP8.5, respectively?

4 **Response:**

5 For clarification, FBC has not explicitly included any winter peak demand and energy consumption 6 reductions within its Reference Case load forecast relating to the temperature changes in the 7 cited figures, but has instead captured potential impacts relating to these temperature changes 8 within its load drivers and load scenarios. As discussed in Section 3.2.6 of Appendix H – Load 9 Scenarios Assessment Report, the assumption relating to the climate change load driver for 10 Scenario 2 (Lower Bound) is that the average temperature on all days of the year increases by 2 11 degrees Celsius. In this scenario, this load driver decreases both energy and peak winter demand. 12 FBC did not use the impacts associated with the specific temperature changes associated with 13 RCP2.6 and RCP8.5 for this load driver. 14 As shown in Table 16 of Appendix H – Load Scenarios Assessment report, the expected annual 15 energy reduction associated with this temperature change is 30 GWh by 2040. For the winter 16 months of January, February and December 2040, the expected energy reduction is 41 GWh. 17 For the summer months of June, July and August 2040, the expected increase in energy is 54 18 GWh. As shown in Table 17 of Appendix H - Load Scenarios Assessment report, the expected 19 winter peak demand reduction associated with this temperature change is 30 MW by 2040. The 20 expected increase in summer peak demand associated with this temperature change is 34 MW 21 by 2040.

- 22
- 23
- 24 25

- 7.2. What are FBC's anticipated summer peak demand and summer energy consumption increases associated with these scenarios?
- 27 28 **Respo**
- 28 <u>Response:</u>
- 29 Please refer to the response to RCIA IR1 7.1.
- 30



1 8.0 Reference Exhibit B-1, Volume 1, Page 21

Section 2.2.1 – Climate Change

FortisBC Inc. presented Figure 2-3 which is reproduced below:

Figure 2-3: Projected Winter and Summer Precipitation Pattern Changes²¹



4 5

2

3

8.1. Please provide Figure 2-3 with details that are legible.

- 7 <u>Response:</u>
- 8 An enlarged, higher-resolution version of Figure 2-3 is provided below.

<i>C.</i> ;	FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: December 23, 2021
FORTIS BC ^{**}	Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1	Page 14

Figure 2-3 – Projected Winter and Summer Precipitation Pattern Changes



Baseline (1971-2000), 2050s and 2080s mean daily flows averaged over six Global Climate Models (GCMs) for Williston and Mica under the highest global emission scenario. The shaded areas denote the uncertainty bounds between all six GCMs for the respective periods.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Submission Date: December 23, 2021

FORTIS BC^{**}

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 15

1	9.0	Refer	ence	Exhibit B-1, Volume 1, Page 37
2				Section 2.3.2 – Electric Vehicles
3		Fortis	BC Inc.	states:
4 5 6 7		"The g the de leads perce	growth in emand fo the cou nt of all i	n EV sales in the FBC service area is expected to play a significant role in or electricity related to EV charging over the planning horizon. BC currently intry in EV sales: as of December 30, 2020, EV sales accounted for 9.4 light-duty vehicle sales in BC."
8 9		9.1.	ls FB0 encour	C incurring or planning to incur higher capital and operating costs to rage EV adoption than is mandated under government policy?
10 11 12			9.1.1.	If yes, please explain the business rationale for doing so and quantify the associated capital and operating costs.
13	Respo	onse:		
14 15 16 17 18	For cla Howe chargi of the (GGR	arity, the ver, the ng (DC <i>Clean I</i> R).	ere are r e Provin FC) stat Energy A	to mandated investment levels for FBC related to encouraging EV adoption. ce has encouraged public utility investment in public direct current fast ions by making such investment a prescribed undertaking under section 18 Act as set out in the Greenhouse Gas Reduction (Clean Energy) Regulation
19 20 21 22 23 24 25	FBC b adopti extent that is is reas recove benefi	elieves on sho possibl design sonable ered fro ts.	that inve uld be p le. For e ed to red to expe om all ra	estments by the Company related to supporting provincial objectives for EV baid for by the customers directly receiving the associated benefits to the example, customers using the FBC public DCFC network are charged a rate cover all incremental costs from station users over the life of the stations. It ect the costs of DSM measures to shift customer EV charging loads will be atepayers given the distributed nature of the capacity and infrastructure
26 27				
28 29 30		9.2.	Have F adoptic	BC's customers asked it to undertake additional spending to encourage EV
31 32			9.2.1.	If yes, please provide documentation.
33	<u>Respo</u>	onse:		
34	The fe	edback	c receive	ed from RPAG stakeholders has generally been focused on encouraging

35 FBC to mitigate EV load impacts and develop measures to shift EV demand, rather than asking

36 FBC to undertake additional spending to encourage EV adoption. It is expected, however, that





Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

1 EV peak mitigation programs will help support adoption of EVs by providing incentives for 2 customers that are able to shift their EV charging loads.

- 3
- 4
- •
- 5 6

7

8

9

9.3. Would FBC incur capital and operating costs beyond the level that is mandated under government policy if FBC could not recover those capital and operating costs from ratepayers?

10 **Response:**

For clarity, there are no mandated investment levels for FBC related to EV adoption. FBC does not expect to incur capital and operating costs at a level for which it would not be afforded a

13 reasonable opportunity to recover those costs from ratepavers.

- 14
- 15
- 16
- 9.4. What are the estimated incremental residential rate impacts in 2025, 2030, and
 2040 relative to approved 2021 rates, attributable to FBC's planned volitional (i.e.,
 greater than mandated) incremental capital and operating investments to
 encourage EV adoption?
- 21

22 Response:

For clarity, there are no mandated investment levels for FBC related to EV adoption. To date, FBC's investments have primarily focused on the deployment and operation of public DCFC stations; RS 96 has been designed to recover the costs of this program from EV drivers. In the response to BCUC IR1 14.1 from the Application for Approval of Rate Design and Rates for EV DCFC Service, FBC provided a sensitivity analysis (Table 3-4) for the rate impacts to all FBC customers if EV usage of the public DCFC stations varies from forecast.

FBC is still developing its plans and related forecasts for investments for other EV-related initiatives, including peak demand mitigation as well as incentive programs for fleet and workplace charging infrastructure. Where possible, EV-related programs will be designed to recover costs from EV drivers (as with FBC public DCFC stations) or will be designed to directly benefit all ratepayers (e.g. EV charging demand reduction programs).

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Submission Date: December 23, 2021



Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 17

1	10.0	Refer	ence	Exhibit B-1, Volume 1, Page 45
2				Section 2.3.4 – Small-Scale Distributed Generation
3		Fortis	BC Inc	. states:
4 5		"Smal from a	l-scale (a technic	distributed generation technologies present some challenges for FBC both cal standpoint and in terms of customer equity. These include the following:
6 7		•	Safety addres	⁷ – potential for back-feeding onto the distribution grid must be properly ssed.
8 9		•	Grid s genera	tability – distribution grid must be able to handle unpredictable distributed ation output without causing power quality problems for other customers.
10 11 12		•	Equity the co recove	- the structure of current rates can lead to net metering customers avoiding st of being connected to the FBC system – meaning those costs must be ered through the rates of non-net metered customers."
13 14 15 16 17 18		10.1.	Does dispate is not custor quanti	providing a net energy rate to energy-metered customers with onsite non- chable renewable generation resources such as rooftop solar (whose output coordinated with customer demand) effectively transfer additional costs to ners who have not installed such generation resources? Please explain and fy the costs under the current residential tariff structures.
19	<u>Respo</u>	onse:		
20 21 22 23 24 25 26 27 28 29	In any electri respon reside BCUC energy rate, t custor syster	Net Me city billi c syste nsibility ntial cu con De y costs he Res mer that n, but a	etering p ng, and em (as which stomers cember were \$0 idential require voids co	program where participating customers have the ability to reduce or eliminate the energy rates normally recover some of the fixed costs of operating the is the case with FBC), participating customers will avoid some cost will need to be recovered from other customers. In the case of FBC's s, this is demonstrated by the 2017 Cost of Service Analysis filed with the 22, 2017. It can seen in the cost summary that on a cost per kWh basis, 0.04185, while the demand (fixed) costs were \$0.10255. ³ As an energy-only rate notionally collects both of these costs in a blended energy rate. A es little or no energy from FBC still benefits from being connected to the FBC posts related to its operation.
30 31				
32 33 34 35		10.2.	Please terms econo	e describe and quantify the Equity issues associated with Net-Metering in of different residential ratepayer group sub-classifications (e.g., socio- mic indicators, residence type, etc.).

³ <u>https://docs.bcuc.com/Documents/Proceedings/2018/DOC_50507_B-1_FBC-2017-Rate-Design-Application.pdf</u> pdf page 197.



2 **Response:**

In the context of the referenced passage from the Application, FBC intended the customer equity challenge presented by net metering to encompass the shifting of costs from participating to nonparticipating customers. FBC has no information related to the varying impact that may result from socioeconomic or other factors. However, due to the initial capital outlay and building/property permissions required to install a solar system, it is reasonable to assume that most net metering customers own single-family dwellings and therefore have relatively higher incomes.

- 10 11 12 13 10.3. At what net-metering penetration level does FBC believe Equity issues will warrant 14 a re-evaluation of Net-Metering equity transfers between residential ratepayer sub-15 classes? Please quantify and explain. 16 17 Response: 18 FBC has not set any specific penetration level which would trigger a further examination of net 19 metering. However, FBC does intend to re-evaluate the Net Metering program during the next 20 Cost of Service Analysis expected in the 2024-2025 timeframe. Please also refer to the response
- 21 to BCUC IR1 11.2.

FORTIS BC^{*}

(IR) No. 1

Page 19

1	11.0	Refere	ence E	Exhibit B-1, Volume 1, Page 46
2			S	Section 2.3.4 – Small-Scale Distributed Generation
3		Fortis	BC Inc. s	tates:
4 5 6 7 8 9		"Custo decline net me Appen custor battery	omer partio ed to lowe etering fac dix N) sho ners are l / storage,	cipation has been trending upwards from 2012 to 2018 and then additions ar levels in 2019 and 2020. At this point, it is uncertain what the trend for cilities growth going forward will be. FBC's recent customer survey (see ows that 34 percent of residential customers and 49 percent of commercial likely to install rooftop solar panels, with similar percentages for installing in the next five years."
10 11 12 13	Respr	11.1.	Please of levels ar	discuss and quantify the correlation between customer socioeconomic of the adoption of onsite generation such as rooftop solar.
14 15	FBC c analys	loes no iis.	t have th	e customer demographic information required to provide the requested
16 17				
18 19 20 21 22	Respo	onse:	11.1.1.	Please cite external sources if FBC has not carried out its own analysis for its service area.
23 24	FBC i demoç	is awar graphic	e that th study of n	e California Public Utilities Commission commissioned an extensive net metering customers. ⁴
05				with a Lowronce Darkelov National Laboratory found the fellowing endured

25 Further, a 2020 study by the Lawrence Berkeley National Laboratory found the following annual 26 income distribution of 2018 residential solar adopters (USD): 15 per cent have household income below \$50,000; 33 per cent are between \$50,000 to \$100,000; 24 per cent are between \$100,000 27 28 to \$150,000; and the remaining 28 per cent are above \$150,000.⁵

29 Together, these results indicate that adoption of residential solar generation generally increases 30 with income.

31

⁴ https://www.cpuc.ca.gov/-/media/cpucwebsite/files/uploadedfiles/cpuc website/content/utilities and industries/energy/reports and white papers/nemre portwithappendices.pdf

⁵ https://eta-publications.lbl.gov/sites/default/files/solar-adopter_income_trends_report.pdf



Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 20

- 11.2. Does FBC response to the above question imply that implementation of nondispatchable renewable generation by customers with the requisite access to capital imply an expected cross-subsidy from poorer customers to wealthier customers?
- 6 7

1 2

3

4

5

11.2.1. If not, please explain why not.

8 <u>Response:</u>

9 Given that participating net metering customers will avoid some cost responsibility which will need 10 to be recovered from other customers (as discussed in the response to RCIA IR1 10.1), and that

11 most net metering customers own single-family dwellings and therefore have relatively higher

- 12 incomes (as discussed in the response to RCIA IR1 10.2), FBC considers there is a potential for
- 13 cross-subsidy from poorer customers to wealthier customers.
- 14
- 15

16

17 11.3. What will be the total cumulative percentage of residential customers with rooftop
 18 solar panels (and/or battery storage) in five (5) years, assuming that the expected
 19 new installations are all completed?

20 21 **<u>Response:</u>**

Currently, less than one percent of residential customers have net metering systems. Therefore, if all 34 percent of residential customers cited in the preamble were to install solar panels, the cumulative percentage would be in the 34 to 35 percent range. FBC does not expect that all of the customers surveyed will actually complete installations, but does not have a basis for speculating on the number that can or will.

FORTIS BC⁻

(IR) No. 1

December 23, 2021

Submission Date:

Page 21

1 **12.0** Reference Exhibit B-1, Volume 1, Page 47

Section 2.3.5 New Emerging Large Loads

3 FortisBC Inc. states:

4 "The prospect of decarbonizing the FEI natural gas system has spurred potential 5 development of green energy projects such as hydrogen and renewable natural gas 6 production. FBC is currently working with customers in these sectors, which could become 7 some of FBC's largest energy consumers in the coming years. Carbon capture and 8 storage may also emerge as technologies that help with the goal of decarbonization in the 9 future and could provide additional electricity demand within the FBC service area."

- 10 12.1. What are FBC's and/or FEI's plans to establish carbon capture and storage within
- 11 12

2

FBC's service territory?

13 Response:

FEI and FBC are currently monitoring carbon capture and storage technology, including the potential for pilot projects; however, neither FEI nor FBC have immediate plans to establish this technology within FBC's service territory. Please also refer to the responses to BCOAPO IR1 16.1 and 16.2.

- 18
- 19
- 20

21

22

23

12.2. What are FBC's and/or FEI's plans to establish renewable natural gas production within FBC's service territory?

24 **Response**:

FEI already has an RNG production facility at the Glenmore Landfill in Kelowna, which is within
 FBC's service territory.⁶ FEI is also working with potential suppliers within FBC's service territory,
 such as REN Energy for example, to establish large-scale RNG production.

With the recent changes to the GGRR, FEI will also be able to invest in the purchase, transportation, and production of green hydrogen produced from clean electricity, in addition to RNG. Therefore, FEI will be in a stronger position to support new RNG and green hydrogen production opportunities and enable development of potentially significant production capacity within FBC's service territory.

FEI's plans to further establish renewable gas supply within FBC's service territory will continue
 to leverage an ongoing partnership with the University of British Columbia Okanagan Campus to
 advance technology development in support of new RNG and hydrogen production pathways and

⁶ <u>https://www.fortisbc.com/services/sustainable-energy-options/renewable-natural-gas/meet-our-renewable-natural-gas-suppliers#tab-3</u>

also enable the distribution and use of hydrogen in the natural gas system through blending withmethane.

3 On the community side, both FEI and FBC are actively building strong partnerships with 4 Indigenous communities and local governments in FBC's service territory to identify project 5 opportunities. 6 7 8 9 12.3. What are FBC's and/or FEI's plans to establish hydrogen production within FBC's 10 service territory? 11 12 **Response:** 13 Please refer to the response to RCIA IR1 12.2. 14 15 16 17 12.4. What are the competitive advantages of carbon capture and sequestration, 18 hydrogen production and renewable natural gas production projects locating in 19 FBC's service territory rather than BC Hydro's territory (e.g., geotechnical 20 formations, municipal subsidies?) 21 22 **Response:** 23 There are no specific competitive advantages for these projects by locating within FBC's service

23 There are no specific competitive advantages for these projects by locating within FBC's service 24 territory. FEI continues to develop multiple RNG projects in BC annually and is actively 25 investigating the feasibility of developing various small-scale and large-scale hydrogen projects 26 in BC. Each project is considered individually and FBC understands that various factors are 27 assessed in order to find high-quality projects that balance socio-economic benefits through 28 investment and jobs in BC while delivering the lowest-cost renewable gas.



2

FortisBC Inc. (FBC or the Company)Submission Date:
December 23, 20212021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side
Management Plan (LT DSM Plan) (Application)Submission Date:
December 23, 2021Response to Residential Consumer Intervenor Association (RCIA) Information Request
(IR) No. 1Page 23

13.0 Reference Exhibit B-1, Volume 1, Page 56

Section 2.4.2 – Pacific Northwest Electricity Generation

3 FortisBC Inc. provided Figure 2-12 which is reproduced below:





4 5

- 13.1. Please provide a chart showing the annual energy produced by the different resources shown in Figure 2-12.
- 6 7

8 Response:

9 Please find the requested chart⁷ below from the Northwest Power and Conservation Council.

⁷ <u>https://www.nwcouncil.org/energy/energy-topics/power-supply.</u>







FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Submission Date: December 23, 2021



2

4

5

6 7

8

9

10

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 25

1 14.0 Reference Exhibit B-1, Volume 1, Page 66

Section 2.4.5 – Summary

3 FortisBC Inc. states:

"Increased renewable penetration across the region may increase the surplus energy available through wind and solar resources, however, declining snowpack levels, persistent drought, and seasonal water shortages due to climate change could decrease the surplus hydropower available during spring freshet and summer periods. FBC will continue to monitor the price and availability of wholesale market energy, as well as any regional developments that would affect the Company's ability to purchase from the wholesale market."

- 14.1. Has FBC modeled the reliability impacts of a range of penetration scenarios for
 different renewable generation resources in the Pacific Northwest?
- 13
- 14
- 15
- 14.1.1. If yes, please provide documentation.
- 14.1.2. If no, please explain why not, in consideration of the reasonably foreseeable risk of negative reliability and market price and availability
- 16 consequences associated with increased penetration rates of non-dispatchable electric17 generation resources.
- 18

19 Response:

FBC has not modeled the reliability impacts for different renewable generation resources in thePacific Northwest for the following two reasons:

- FBC has represented the requirement for capacity self-sufficiency within the LTERP, and as a result, selects incremental new resources to meet forecasted capacity gaps. As mentioned in Appendix K – Resource Options Report of the Application, the renewable generation resource options that FBC considered could potentially be available in the FBC service area or within BC. FBC did model the reliability impacts for selected resource options, which is discussed further in Appendix M – Planning Reserve Margin report.
- 28 2. FBC has access to the Mid-C market in the Pacific Northwest through the CEPSA agreement with Powerex, effective as of May 1, 2015. The CEPSA provides increased and reliable market access to purchases that are comparable or better than FBC can achieve outside of the CEPSA. While FBC agrees that it is not prudent to rely on market capacity in the long term, market energy should remain available at reasonable prices.

Please also refer to the response to RCIA IR1 17.1, which discusses regional reliability
 assessments and the external entities that are responsible for ensuring regional resource
 adequacy.

 FortisBC Inc. (FBC or the Company)
 Submission Date:

 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)
 Submission Date:

 Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1
 Page 26

1 15.0 Reference Exhibit B-1, Volume 1, Page 71 & 72

Section 2.5.2 – Electricity Market Price Forecasts

3 FortisBC Inc. states:

4 *"The Mid-C market annual price forecasts in real Canadian dollars per megawatt-hour* 5 *(MWh) are presented in the following figure."*



Figure 2-18: Mid-C Electricity Annual Price Forecasts

6 7

8

9

10

2

15.1. Regarding Figure 2-18, please superimpose representative daily, monthly, and seasonal volatility ranges upon the Base, High and Low Mid-C Annual Price Forecast curves, and provide the information in tabular format.

11 <u>Response:</u>

12 Provided below is an updated Figure 2-18 and the corresponding data in tabular format below. 13 Note that the volatility ranges are shown around the Base forecast only. Each range is shown as 14 a minimum and a maximum. For example, there is a Daily Minimum and a Daily Maximum that 15 represents the lowest as well as the highest daily price from the volatility analysis. Since this is a 16 daily number compared to an annual number, the range will be very large. Monthly volatility is 17 similar in this regard, except that, since this is now a monthly number compared to the annual 18 number, the range is smaller. Finally, the annual volatility number is quite close to the original 19 forecast High and Low values.

Daily volatility is calculated as the average over the years 2016 to 2020 of the standard deviation of the daily price variance from the monthly mean.



- 1 Monthly volatility did not use a standard deviation analysis but rather the observed minimum and
- 2 maximum deviation of monthly prices from 2016 to 2020. The monthly price was calculated as
- 3 the average daily price in that month.
- 4 The seasonal volatility was not calculated, and rather the monthly volatility process was repeated
- 5 but using the annual values instead.
- 6 The ranges are then applied above and below the Base Mid-C price forecast. Note that all the
- values shown in the table below use the left side axis, with the exception of the Daily Max whichuses the right side axis.



FORTIS BC^{*}

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Submission Date: December 23, 2021

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1 $\,$

Page 28

	High	Low	Base	Daily Min	Monthly Min	Annual Min	Daily Max	Monthly Max	Annual Max
2021	\$42	\$27	\$32	-\$40	\$9	\$26	\$1,956	\$92	\$44
2022	\$36	\$22	\$28	-\$34	\$4	\$21	\$1,676	\$87	\$39
2023	\$39	\$23	\$29	-\$36	\$6	\$23	\$1,764	\$89	\$41
2024	\$40	\$23	\$29	-\$36	\$6	\$23	\$1,776	\$89	\$41
2025	\$39	\$22	\$30	-\$37	\$6	\$23	\$1,785	\$89	\$41
2026	\$42	\$22	\$30	-\$37	\$6	\$23	\$1,792	\$89	\$41
2027	\$42	\$22	\$29	-\$36	\$6	\$23	\$1,761	\$89	\$41
2028	\$44	\$22	\$29	-\$36	\$6	\$23	\$1,781	\$89	\$41
2029	\$45	\$22	\$30	-\$37	\$7	\$23	\$1,807	\$89	\$42
2030	\$46	\$22	\$31	-\$38	\$8	\$24	\$1,864	\$90	\$43
2031	\$49	\$23	\$32	-\$40	\$9	\$26	\$1,944	\$92	\$44
2032	\$47	\$23	\$32	-\$39	\$8	\$25	\$1,908	\$91	\$43
2033	\$47	\$23	\$32	-\$40	\$9	\$26	\$1,943	\$92	\$44
2034	\$44	\$22	\$30	-\$38	\$7	\$24	\$1,840	\$90	\$42
2035	\$45	\$22	\$31	-\$38	\$8	\$24	\$1,877	\$90	\$43
2036	\$45	\$22	\$31	-\$38	\$8	\$24	\$1,877	\$90	\$43
2037	\$44	\$22	\$30	-\$38	\$7	\$24	\$1,838	\$90	\$42
2038	\$46	\$23	\$32	-\$39	\$8	\$25	\$1,906	\$91	\$43
2039	\$49	\$24	\$33	-\$41	\$10	\$27	\$2,019	\$93	\$45
2040	\$46	\$23	\$32	-\$39	\$8	\$25	\$1,906	\$91	\$43

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Submission Date: December 23, 2021



Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

1	16.0	Reference	Exhibit B-1, Volume 1, Page 75 & 76
2			Section 2.5.5 – BC Hydro PPA Rates Scenarios
3			Exhibit B-1, Volume 1, Page 72
4			Section 2.5.2 – Electricity Market Price Forecasts
5		On Pages 75	to 76 FortisBC Inc. states:
6		"In order to e	estimate the potential costs for the BC Hydro PPA in the future, FBC has
7		developed PF	PA scenarios based on annual percentage increases in BC Hydro rates and
8		BC Hydro's L	RMC. The percentage increases in the PPA Tranche 1 energy and capacity
9		rates are the	same as those applicable to BC Hydro's customers
10			

11 The following figure shows the PPA rate scenarios for Tranche 1 Energy, which is at a 12 rate of \$50.73 per MWh as of April 1, 2021.





On Pages 72 FortisBC Inc. provided Figure 2-18 which is reproduced below:







2

3

4

5

16.1. Please explain the business rationale for FBC to continue purchasing power under either Tranche 1 or Tranche 2 of the BC Hydro 3808 PPA, if the Mid C price forecast shown in Figure 2-18 is realistic?

6 Response:

A one-to-one comparison of the long-term PPA Tranche 1 energy price (as shown in Figure 2-21), and the Mid-C electricity price forecast (as shown in Figure 2-18), does not provide the full picture of the interaction between these two resources or of the potential displacement of PPA energy with market energy. Several other factors must be considered and are discussed further below. At this time, FBC does not currently take, nor does it plan to take, any Tranche 2 energy under the PPA because of its significantly higher cost.

First, the PPA is a bundled product, and as such, when FBC requires PPA capacity in order tomeet demand, FBC must also take the corresponding amount of energy.

Second, the long-term Mid-C price forecast is a simplified representation of future prices. As in any long-term market price forecast, certain assumptions about supply and demand factors have been made based on current information. While FBC believes that overall the price forecast is realistic, FBC recognizes that the forecast does not reflect the short/medium-term volatility of the wholesale electricity market.

Finally, the flexibility of the BC Hydro PPA makes it a valuable energy and capacity resource that provides many benefits to FBC. It ensures access to a maximum of 200 MW of capacity and

22 1,752 GWh of energy on an annual basis; however, there are provisions within the contract that



- 1 allow FBC to shape and scale up or scale down its usage, along with corresponding costs, based
- 2 on requirements. This flexibility provides access to firm power when required and the ability to
- 3 mitigate power purchase expense when the market is favourable or when loads are lower than
- 4 forecast. The PPA also acts as a price ceiling during times of sustained high market prices.

FORTIS BC^{**}

(IR) No. 1

Page 32

1	17.0	Refere	ence	Exhibit B-1, Volume 1, Page 80						
2				Section 2.5.7 – Adders to the Market Price Forecast						
3	FortisBC Inc. states:									
4 5 6 7 8		"Second, the growth of renewable energy will help further diversified electricity generation capacity in the region. This has resulted in low market electricity prices, which are reflected in the market price forecasts. Market purchases, at least in the short to medium term, continue to remain well below the cost of other supply-side resource options, discussed in Section 10.2."								
9 10 11 12		17.1.	Please the reg dispate	describe and quantify the reliability benefits of increasing the diversity of gional electricity generation capacity by adding significant volumes of non- chable resources.						
13	<u>Respo</u>	onse:								
14 15 16 17 18 19	There supply Pool (I adequ proces activiti	are at , namel NWPP) ate, eff ss of de es withi	least tw ly the No . The N icient, e evelopin in the re	b external entities in the region that aim to ensure reliable regional power orthwest Power and Conservation Council (NPCC) and the Northwest Power IPCC issues the Northwest Power Plan, which has the goal of ensuring an economic, and reliable power system for the region. The NWPP is in the g a Resource Adequacy Program for the Pacific Northwest ⁸ to coordinate gion and has performed a comprehensive review of resource adequacy.						
20 21 22 23	FBC h region resour (E3). ⁹	as not i 's gene ces pul	internall ration ca blished	y conducted regional studies that investigate or quantify the reliability of the apacity and changing landscape, rather, FBC has reviewed credible external through the NPCC, NWPP, as well as Energy + Environment Economics						
24 25										
26 27 28 29		17.2.	What FBC's	is the optimal proportional penetration of non-dispatchable resources in system? Please explain and quantify.						

⁸ Northwest Power Pool, Exploring a Resource Adequacy Program for the Pacific Northwest, An Energy System in Transition, October 2019. https://www.nwpp.org/private-media/documents/2019.11.12_NWPP_RA_Assessment_Review_Final_10-23.2019.pdf

⁹ Energy + Environmental Economics (E3), Resource Adequacy in the Pacific Northwest, March 2019. https://www.ethree.com/wp-content/uploads/2019/03/E3 Resource Adequacy in the Pacific-Northwest_March_2019.pdf



1 Response:

- The optimal proportional penetration of non-dispatchable resources (also referred to as intermittent resources in the Application) is dependent on the mix of the incremental resources assumed, or more specifically, the correlations among the incremental resources. As increasing amounts of correlated intermittent resources are added into the portfolio, the capacity value for each additional MW installed decreases in a non-linear relationship.
- 7 As illustrated in the response to BCUC IR1 30.1, FBC first determines the optimal portfolio, then 8 tests the resulting portfolio for reliability using the Planning Reserve Margin (PRM) model. If the 9 portfolio does not meet the Loss of Load Expectation (LOLE) target of 0.1 days per year, additional 10 capacity requirements are added to all months proportional to the monthly contribution to the LOLE starting in the first year of the planning horizon the LOLE target was not met. The lowest 11 12 acceptable level of power supply reliability is a portfolio that results in a LOLE value slightly less 13 than 0.1 days per year in the terminal year of the planning horizon. 14 15
- 10
- 16 17

18

19

- 17.3. What is the maximum penetration of non-dispatchable resources that will provide at least a minimally acceptable level of power supply reliability? Please explain and quantify.
- 20
- 21 Response:
- 22 Please refer to the response to RCIA IR1 17.2.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)



3

5 6

7

8

9

10

12

13

14

15

16

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 34

1 CHAPTER 3: LONG-TERM LOAD FORECAST

- 2 18.0 Reference Exhibit B-1, Volume 1, Page 82
 - Section 3.1 Introduction
- 4 FortisBC Inc. states:

"The BAU is the forecast used for annual rate setting which is then extended out for the 20-year planning horizon. The Reference Case load forecast builds on the BAU forecast by including electric vehicle charging load, and new industrial loads with high confidence of materializing, which are discussed in detail in Appendix F, Section 3.1.3 and 3.4. The Reference Case load forecast is the resulting forecast used for planning purposes in this LTERP."

- 11 18.1. Please confirm that the BAU forecast assumes no incremental EV adoption.
 - 18.1.1. If not confirmed, please explain, and quantify the level of EV adoption assumed in the BAU forecast.
 - 18.1.2. If confirmed, please provide the basis for FBC's expectation that EV adoption will not increase as part of a BAU scenario.

17 <u>Response:</u>

18 Confirmed. The first two years of the BAU forecast is used for rate setting purposes which is 19 updated on an annual basis, as explained in the response to BCUC IR1 3.1. The BAU forecast 20 assumes all loads and trends will continue at their current levels. In the case of EV charging, the 21 future load is not intrinsic in the historical actual load, and therefore must be accounted for 22 incrementally in the Reference Case load forecast. If incremental EV charging growth was added 23 to both the BAU forecast and the Reference Case forecast it is possible that double counting 24 would occur. FBC expects that, as EV adoption grows, an increasing amount of EV charging load 25 will be present in the BAU forecasts and the resulting incremental load identified in the Reference 26 Case will be diminished.



1 19.0 Reference Exhibit B-1, Volume 1, Page 88

Section 3.4.2 – Peak Demand Forecast

3 FortisBC Inc. states:

"The BAU forecast summer peak demand forecast increases from 628 MW in 2021 to 744 4 5 MW in 2040, increasing at an average annual growth rate of 0.9 percent.

6 The Reference Case summer peak is forecast to increase from 638 MW in 2021 to 911 7 MW in 2040, at an average annual growth rate of 1.9 percent.



Figure 3-5: Summer Peak Forecast (MW)

8

- 9
- 19.1. Regarding Figure 3-5, are reference case system losses included in the annual peak demand bars?

If yes, please provide updated Figures 3-4 and 3-5 with reference case

losses shown separately, similar to what was done in Figure 3-3.

- 10
- 11
- 12
- 13 14

If not applicable, please explain why not. 19.1.2.

15 **Response:**

19.1.1.

16 Peak demand is calculated using FBC's historical actual system peaks and the gross load growth

17 rate. The gross load growth rate implicitly includes losses since the gross load is equal to the net

18 load plus losses. FBC is unable to show the peak demand losses individually because the

19 historical peaks are not broken down by class but are instead based on the total system demand.

- 20 Therefore, the losses at peak demand cannot be calculated for individual classes.
- 21
FORTIS BC

(IR) No. 1

Page 36

1 CHAPTER 4: LOAD SCENARIOS

2	20.0	Reference	Exhibit B-1, Volume 1, Page 98 & 99
3			Section 4.1.1 – Load Drivers
4			Exhibit B-1, Volume 1, Page 19
5			Section 2.2.1 – Climate Change
0			

6 FortisBC Inc. states:

"Nine specific load drivers were included to develop the load scenarios. These drivers are
believed to have the potential for the most substantial impact on future loads. The nine
load drivers are...:

6. ...Climate Change: Increasing average annual temperatures, increases in average temperatures during the 10 hottest days of the year, and decreases in average temperatures during the 10 coldest days of the year."

13 On Page 19 FortisBC Inc. provided Figure 2-1 which is reproduced below:

Figure 2-1: Projected Winter and Summer Temperature Changes¹⁰



14

Please explain and quantify why increasingly high average winter temperatures as
 per Figure 2-1 which show RCP2.6 and RCP8.5 winter temperature anomalies will
 produce decreasing average temperatures during the ten (10) coldest days of the
 year? Please provide the longest possible historical climate records for FBC's



3

service area that demonstrate statistically significant low temperature anomalies over the "10 coldest days of the year".

4 <u>Response:</u>

As discussed in Section 2.2.1, while the figures relate to average warming temperatures over time, they do not capture the increase in the weather and temperature volatility that has occurred in recent years and which is expected to continue in the future. Therefore, while overall annual warming of average temperatures is expected, there is also the possibility for colder cold snaps

9 and warmer hot spells due to the volatility associated with climate change.

- 10 Environment Canada data for Penticton airport (YYF) includes minimum temperatures from 1986
- 11 to present day.¹⁰ The plot below shows the minimum temperatures by year.



12

13 The plot shows:

The median minimum daily temperature for each year as the black horizontal line in each box;

¹⁰ Minimum temperature data for 1987 is not available.



- The 25th and 75th percentiles define the size of the shaded box;
- The "whiskers" cover data that is up to 1.5 times warmer or colder than the shaded region;
 and
- The minimum temperature outliers are shown as discrete data points by the red dots.

5 For this IR response, the minimum temperature outliers are most relevant. FBC notes in the 20-6 year period from 1985 through 2005 that 13 outliers were recorded (i.e., an average 0.65 outliers 7 per year). In the 14-year period from 2006 through 2020, 19 outliers were recorded (i.e., an 8 average 1.4 outliers per year). While FBC does not have any specific data in this regard relating 9 to the 10 coldest days of the year, the increased frequency of temperature outliers per year 10 provides some evidence that low temperature anomalies have increased in recent years.



1 21.0 Reference Exhibit B-1, Volume 1, Page 103

Section 4.1.3 - Load Scenarios Results

2 3

FortisBC Inc. presents the following:

3,000 Sc. 1 Upper Bound 2,500 Sc. 2 Lower Bound Sc. 3 Deep Electrification Scenario Impact (GWh) 2,000 Sc. 4 Diversified Energy Pathway Sc. 5 Distributed Energy Future 1,500 1,000 500 0 -500 -1,000 2020 2021 2023 2025 2025 2025 2026 2028 2028 2028 2031 2031 2033 2035 2035 2035 2035 2035 2037 2038 2039 2040

Figure 4-1: Annual Energy Impacts by Scenario

4



6

- 21.1. Please confirm that the Reference Case has a 0 GWh scenario impact for all years.
- 7

If not, please restate Figure 4-1 with the Reference Case added and 21.1.1. explain why FBC did not include the Reference Case.

8 9 Response:

10 Not confirmed. As discussed in Section 4.1.1, the load scenarios developed by Guidehouse 11 should be considered incremental to the BAU forecast but not the Reference case forecast. 12 Therefore, in Figure 4-1, the BAU load forecast has a 0 GWh impact for all years. The figure 13 below includes the annual energy included in the Reference Case load forecast which is 14 incremental to the BAU forecast. As shown in Figure 3-3, this incremental annual energy is 15 primarily related to EV charging.



FortisBC Inc. (FBC or the Company)Submission Date:
December 23, 20212021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side
Management Plan (LT DSM Plan) (Application)Submission Date:
December 23, 2021Response to Residential Consumer Intervenor Association (RCIA) Information Request
(IR) No. 1Page 40





FORTIS BC^{*}

2

(IR) No. 1

Page 41

1 22.0 Reference Exhibit B-1, Volume 1, Page 111

Section 4.3 - Conclusion

3 FortisBC Inc. states:

"As part of its load scenario analysis, FBC explored two boundary scenarios and three 4 5 intermediate scenarios as well as stakeholder scenarios. Load driver penetrations in the 6 boundary scenarios help FBC understand the potential impact that each of these load 7 drivers could have under extreme, but plausible, penetration scenarios, providing upper 8 and lower limits for the other intermediate scenarios. The intermediate scenarios, which 9 include combinations of load drivers that increase and decrease load, may be more 10 reasonable potential future pathways. However, at this point in time, there is too much uncertainty to know which of the scenarios, if any, will occur in the future." 11

12 22.1. Please comment upon the impact the two boundary scenarios have on the FBC13 recommendations.

15 **Response:**

14

16 The two boundary scenarios include load drivers that only increase or only decrease load and do 17 not include load drivers that might offset each other in terms of their load impacts. Therefore,

18 these boundary scenarios provide 'bookends' or reasonable limits that FBC expects the other.

19 more reasonable potential future pathways, represented by the intermediate scenarios, will fall

- 20 within. As such, they do not directly impact the recommendations discussed in Section 4.3.
- 21 22 23 24 22.1.1. If the boundary scenarios informed the FBC recommendations, please 25 enumerate and quantify the impacts, along with a rationale as to why scenarios with "too much uncertainty to know which of the scenarios, if 26 27 any, will occur in the future" are impactful. 28 29 Response: 30 Please refer to the response to RCIA IR1 22.1.

FORTIS BC^{*}

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 42

1 CHAPTER 5: EXISTING SUPPLY-SIDE RESOURCES

- 2 23.0 Reference Exhibit B-1, Volume 1, Page 116
- 3

Section 5.4 - Waneta Expansion Capacity Purchase Agreement

4 **FortisBC Inc. states:**

"The amount of residual capacity provided under the WAX CAPA is greater than FBC's 5 6 current capacity requirements in most months and, as a result, FBC sells the surplus 7 capacity to mitigate power purchase expense. FBC has contracted to sell a 50 MW block 8 of WAX CAPA residual capacity to BC Hydro under the Residual Capacity Agreement 9 (RCA), entered into as of July 15, 2013. The BCUC approved the RCA in Order G-161-10 14. The RCA expires September 30, 2025, and for the purposes of the 2021 LTERP, FBC 11 is assuming that it is not renewed. FBC will sell the remaining surplus WAX CAPA residual 12 capacity to Powerex Corp. (Powerex) on a day-ahead basis, under the terms of the 13 Capacity and Energy Purchase and Sale Agreement (CEPSA), dated February 17, 2015, 14 if and when the capacity is not required to meet FBC load requirements. The BCUC 15 accepted the CEPSA for filing in Order E-10-15. The CEPSA currently expires on September 30, 2022, but can be renewed on an annual basis through September 30, 2025 16 17 by mutual agreement. For the purposes of the 2021 LTERP, FBC is assuming that the 18 CEPSA will continue indefinitely after 2025 in its current form."

- 19
- 23.1. Are FBC's expected winter and summer capacity surpluses until 2030 largely dependent upon expiry of the RCA in September 2025?
- 20 21

22 Response:

23 FBC has sufficient capacity resources with or without the WAX RCA contract, in non-June months, 24 from 2021 through 2027. With the WAX RCA expiring in September 2025, the first non-June 25 capacity gap based on the Reference Case load forecast occurs in July 2030. If the WAX RCA were to be extended through the planning horizon (in other words, the 50 MW block of WAX CAPA 26 27 residual capacity were continued to be sold to BC Hydro), the first non-June capacity gaps would 28 occur beginning in July 2028. Therefore, FBC's expected winter and summer capacity surpluses 29 are largely dependent upon FBC's overall portfolio of resources, and the WAX RCA accelerates 30 the capacity gap by two years.

- 32
- 33
- 34
- 23.1.1. Please quantify the impact the continuing RCA beyond September 2025 would have on FBCs resource capacity deficiency.
- 35 36



Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 43

1 Response:

- 2 Please refer to the response to RCIA IR1 23.1.
- 3
- 4
- 5 6

7

8

23.2. What are the lost revenue implications if Powerex decides to not renew the CEPSA after Sept 30, 2022? Please quantify.

9 **Response:**

The terms of the CEPSA agreement between FBC and Powerex are confidential, and as such, FBC cannot disclose revenue calculations under this contract. FBC does believe, however, that the CEPSA agreement provides improved market access at comparable or lower cost than could be obtained elsewhere. If Powerex decides not to renew the CEPSA agreement, FBC expects that there could be negative impacts to revenue.

- 15
- 16
- 17
- 23.3. Does FBC expect any other impacts if the CEPSA is not renewed? Please explain
 and quantify.
- 20

21 Response:

22 If the CEPSA is not renewed, in addition to the potential negative impact on revenue, FBC expects 23 that there is the potential for the cost of power to increase and its availability could decrease, 24 requiring higher PPA purchases to obtain the required amount of energy. FBC would also have 25 to reconsider its position on the security of market access depending on what new arrangements, 26 if any, could be put into place. FBC would also have to consider if there are any implications to 27 the PRM calculations that rely on market capacity access through the CEPSA. However, even in 28 the absence of the CEPSA agreement, FBC expects that Powerex would remain a valued 29 supplier.

In addition, FBC would also have more onerous operational requirements in the absence of the
 CEPSA. The commercial arrangements under the CEPSA allow FBC to schedule deliveries prior
 to the Preschedule deadline, which reduces the burden on FBC's real-time system operators.
 FBC is able to optimize its system on a day-ahead basis, while still maintaining the ability to
 purchase energy hourly in real-time to address changes in load or resources.

Finally, in absence of the CEPSA, FBC would face increased scheduling and contract risk. Interchange schedules require complex management and they do not always succeed due to time

37 pressures to manage the process or due to the loss of the transmission path. Schedules from



Powerex are very reliable due to the increased percentage of FBC market purchases being scheduled on a day-ahead basis. The risk of contract disputes also increases in the absence of the CEPSA due to the notification requirements under the CPA that FBC would have to make to BC Hydro, which are outside of industry standard scheduling practice. With FBC's market needs purchased and scheduled through Powerex, the risk for disputes around scheduling rights with BC Hydro under the CPA is lessened. It is likely that FBC would require additional staff, or even

7 implement a dedicated trading group to manage the increased complexities.

FORTIS BC^{**}

35

(IR) No. 1

Page 45

1	24.0 Defer	anaa Exhibit P.1. Valuma 1. Daga 116						
1	24.0 Refer	ence Exhibit B-1, Volume 1, Page 116						
2	Section 5.5 BC Hydro Power Purchase Agreement							
3	Forti	sBC Inc. states:						
4 5 6 7	"Unde 200 N Septe and 1	"Under the PPA, FBC's customers have access to BC Hydro supply up to a maximum of 200 MW and 1,752 GWh of annual energy. The term of the PPA continues through to September 30, 2033. In 2020, the PPA supplied 18 percent of FBC's energy requirement and 18 percent of the Company's peak capacity needs.						
8 9 10 11 12	"FBC April GWh MWh firm e	s access to BC Hydro's embedded cost energy (at a rate of \$50.73 per MWh as of 1, 2021) under the PPA is limited to 1,041 GWh (Tranche 1 Energy). Above 1,041 and up to the maximum of 1,752 GWh, the energy cost increases to \$95.09 per (Tranche 2 Energy), which is tied to BC Hydro's proxy for long run marginal cost for nergy and is equal to BC Hydro's RS 1823 Tier 2 rate."						
13 14 15	24.1.	Please provide comments on how (if at all) Site C coming into service in 2025 may impact the renegotiation of the BCH PPA.						
16	Response:							
17 18 19	As discussed the current P resources, in	in the response to RCIA IR1 24.3, the renegotiation of the BCH PPA will consider if PA energy and capacity available to FBC from BC Hydro, based on its portfolio of cluding Site C, is still the appropriate amount.						
20 21 22 23	24.2.	Will Site C potentially enable FBC to access a larger Tranche 1 or Tranche 2 if it						
24		chooses?						
25 26 27 28	Posnonso	24.2.1. If so, please quantify the potential impact on Tranche 1 and Tranche 2 sizing.						
20	Response.							
29	Please refer	to the response to RCIA IR1 24.1.						
30 31								
32 33 34	24.3.	Has FBC requested its ratepayers' "fair share" of BC Hydro's \$50.73/MWh embedded cost energy (and the associated capacity), given that FortisBC's						

customers are BC taxpayers and in consideration of the critical role that BC/BC



2

3

(IR) No. 1

Treasury has played in financing development of BC Hydro's generating resources?

4 **Response:**

5 FBC is satisfied that at this time FBC ratepayers are receiving their "fair share" of BC Hydro's 6 embedded cost of energy and the associated capacity. This was the subject of significant 7 discussion in the May 6, 2014 BCUC decision approving the current PPA with BC Hydro.¹¹ The

8 discussion begins at Section 7.2.1.1 on page 42 and concludes on page 54.

9 The BCUC determined on page 49 that, "...the Panel finds it would have been fair under the 10 Bonbright Principles evaluation, all else being equal, for the capacity limit and associated energy

11 to increase to 232 MW..." However, the BCUC then goes on to state that, "This finding does not

12 mean that the New PPA, when considered in its entirety, is unfair to FortisBC... As FortisBC

13 notes, the 'flexibility of the PPA is ...very valuable.' "

14 Further, the BCUC states on page 51, "The Commission Panel determines it is reasonable that 15 the maximum amount of associated energy that should be available at embedded costs rates 16 (Tranche 1 cap) ought to be approximately 60 percent of the total available associated energy." 17 Then on page 52, "The Commission Panel finds that based on 200 MW of capacity, the Tranche 18 1 cap of 1,041 GWh/year appears to be appropriate as it represents approximately 60 percent of 19 associated energy."

20 The current PPA is approaching the half way point of its 20-year life. FBC expects that the

21 question of the appropriate PPA capacity available as well as the Tranche 1 energy cap (if any) 22 will once again require careful consideration in the negotiation of the future renewal of the PPA.

¹¹ https://www.ordersdecisions.bcuc.com/bcuc/decisions/en/111742/1/document.do

FORTIS BC^{**}

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Submission Date: December 23, 2021

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 47

1 CHAPTER 6: TRANSMISSION AND DISTRIBUTION SYSTEM

2	25.0	Reference	Exhibit B-1, Volume 1, Page 136 & 137
3			Section 6.5.4.3 - Potential System Impacts
4		FortisBC Inc	. states:
5		"The values i	n the table below are high-level estimates and may change as more detailed
6		analysis for e	ach of the projects is conducted in the future."

Project	Cost (\$ Millions)
Static VAR Compensator (SVC)	30
DG Bell 230 kV Ring Bus	10
Kelowna Bulk Transformer Capacity Addition	21
Re-conductor 51L & 60L (DG Bell-OK Mission)	9
Ellison Second Distribution Transformer Addition	8
Benvoulin Second Transformer Addition	8
Saucier Second Distribution Transformer Addition	7
DG Bell 138 kV Breaker and Voltage Transformer Addition	1
DG Bell Second Distribution Transformer Addition	6
FA Lee Distribution Transformer Addition	8
Duck Lake Second Transformer Addition	6
Glenmore Third Transformer Addition	6
Hollywood Third Transformer Addition	8
Total	128

Table 6-5: Planned Projects (1-in-20 Peak Demand Forecast by 2040)

7 8

9

"Table 6-6 includes additional projects required to meet the additional peak demand requirements of the Kelowna area at the 550 MW level."



FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: December 23, 2021
Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1	Page 48

Table 6-6: Additional Projects Required to meet 550 MW Peak Demand by 2040 (\$ millions)

Project	Cost (\$millions)
New Distribution Stations	60
New Distribution feeders	40
Meshing Kelowna 138 kV Transmission System	20
138kV Transmission Line Re-conductor	40
138kV Transmission Line Addition	30
Project	Cost (\$millions)
Ashton Creek to Vaseux Lake (ACK-VAS) 500 kV Transmission Line	500
DG Bell Second 230/138 kV Transformer Addition	20
Total	710

1

- 25.1. Can any of the projects listed in Table 6-5 and Table 6-6 be deferred or eliminated by any of the proposed LTERP solutions?
- 5

2 3

4

- 6 7

- 25.1.1. If yes, please identify the impacted T&D project(s), the expected length of the spending deferral and the net impact on the LCOE and LCOC of the relevant proposed LTERP resources if credited with the T&D deferral.
- 8 9 <u>Response:</u>

10 FBC confirms some transmission-level projects could potentially be deferred by resources 11 contained in FBC's proposed LTERP solutions. FBC performed the following high-level analysis 12 using the winter peak demand forecast and portfolio C3 to estimate the potential deferral 13 opportunities for the applicable projects in Table 6-5 and 6-6. In this instance, FBC selected 14 portfolio C3 as it is the most likely portfolio to have the greatest impact on these projects given its 15 larger amounts of dispatchable resources relative to the other portfolios. For clarity, the North 16 Okanagan (NOK) region in the second table below refers to Kelowna and immediate surrounding 17 areas.

The following table includes the resources contained in portfolio C3 that were considered in the analysis. The solar resources in portfolio C3 located in FBC's service territory provide zero dependable capacity during the winter peak. The wind resource contained in portfolio C3 is located in BC Hydro's service area and, therefore, power would be delivered over existing interties to the FBC system.



FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Submission Date: December 23, 2021

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 49

Resource ID	Installed Capacity (MW)	Dependable Winter Capacity (MW)	Modelled In-Service Year
DistBattery6	25	25.0	2030
RNG_SCGT2	100	100.4	2031
RNG_SCGT1	48	47.6	2035

1 FBC assumed the generation resources would be connected to the transmission system;

2 therefore, no distribution level projects are affected. The projects in Table 6-5 and Table 6-6 that

3 could be deferred are shown in the table below. The "Meshing Kelowna 138kV Transmission

4 System" project is not included in the table as it is required for reliability purposes and therefore

5 cannot be deferred by adding generation resources. Also, both "138kV Transmission Line Re-

conductor" and "138kV Transmission Line Addition" projects are required to support growth and,
 given the uncertainty as to where load growth will occur, these projects were not included in the

8 deferral calculation.

Project	NOK Load Level (MW)	Base In- Service Year	Deferred In- Service Year	Project Cost (\$000s) 2020\$	NPV Base ¹² (\$000s)	NPV Deferred ¹³ (\$000s)	T&D Deferral Credit ¹⁴ (\$000s)
Static VAR Compensator	430	2034	2054	30,000	18,064	8,751	9,312
DG Bell 230 kV Ring Bus	430	2034	2054	10,000	6,021	2,917	3,104
Ashton Creek to Vaseux Lake (ACK- VAS) 500kV Transmission Line	550	2047	2070	500,000	187,964	81,682	106,282
DG Bell 230/138 kV Second Transformer Addition	550	2047	2070	20,000	7,519	3,267	4,251

9 The total transmission and distribution deferral credit based on the four projects in the table above

10 is approximately \$123 million. This deferral credit was allocated to the resources in portfolio C3

11 based on the proportion of the total dependable winter capacity provided. The UCCs of these

¹² Equation: Project Cost * (1 + 3.69%)^(2020 – Base In Service Year)

¹³ Equation: Project Cost * (1 + 3.69%)^(2020 – Deferred In Service Year)

¹⁴ Assumed Credit = NPV Deferred - NPV Base



FortisBC Inc. (FBC or the Company)
2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side
Management Plan (LT DSM Plan) (Application)Submission Date:
December 23, 2021Response to Residential Consumer Intervenor Association (RCIA) Information Request
(IR) No. 1Page 50

- 1 capacity resources are restated in the table below. The UECs were not stated as they are
- 2 considered not applicable for capacity-oriented resources.

Resource ID	Dependable Winter Capacity (MW)	Portion of Dependable Winter Capacity (%)	Allocated Deferral Credit (\$000s)	UCC without Deferral Credit (\$/kW-Year)	UCC with Deferral Credit (\$/kW-Year)
DistBattery6	25.0	14	17,767	226	171
RNG_SCGT2	100.4	58	71,353	148	90
RNG_SCGT1	47.6	28	33,829	131	108
Total	173.0	100	122,949		

- 3 The LRMC of portfolio C3, as stated in Table 11-2, is \$81 per MWh. With the inclusion of the
- 4 deferral credits from the table above, the LRMC of portfolio C3 would decrease to \$72 per MWh.
- 5 Portfolio C3 has more impact on transmission and distribution deferrals than portfolio B2 as
- 6 RNG_SCGT2 is not included in portfolio B2.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)



3

5 6

7

8

9

10

11

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1 $\,$

Page 51

1 CHAPTER 10: SUPPLY-SIDE RESOURCE OPTIONS

2 26.0 Reference Exhibit B-1, Volume 1, Page 162 & 163

Section 10.2.1 - Technical Attributes

4 **FortisBC Inc. states:**

"In this way, battery storage is similar to pumped hydro storage, which has a limited capacity generation period before the reservoir must be re-filled to provide capacity again. This is in contrast to some other peaking resources, such as a Simple Cycle Gas Turbine (SCGT) plant. An SCGT plant can provide capacity for any peak demand duration period as long as the fuel source, including conventional natural gas or RNG, is consistently available. Therefore, capacity duration is an important factor when assessing peaking resource options."

Please confirm that storage technologies are net energy loads rather than net
 energy supply resources, and that storage devices act as both capacity supply
 resources and net energy loads.

15

- 26.1.1. If not confirmed, please explain.
- 16
- 17 Response:
- 18 Confirmed.
- 19
- 20
- 21 22

23

- 26.2. What are the expected and best-case round-trip energy efficiencies for the storage technologies included in this application?
- 24
- 25 **Response:**

The expected round-trip energy efficiencies for pumped hydro storage and battery storage resources are assumed to be 75 percent and 90 percent, respectively.



Submission Date:

1 27.0 Reference Exhibit B-1, Volume 1, Page 164 2 Environmental Attributes

2 3

FortisBC Inc. states:

"Environmental considerations are an important objective of the CEA and energy policy in 4 5 BC. Environmental attributes describe the estimated environmental impact of the various 6 resource options. While DSM resources are assumed to have no negative environmental 7 impacts, some supply-side resources can. For the purposes of this LTERP and the 8 portfolio analysis in Section 11. FBC has characterized resource options as either clean 9 or renewable, or not, according to what the CEA defines as clean or renewable resources 10 generated in BC. The CEA defines clean or renewable resources as including biomass, 11 biogas, geothermal heat, hydro, solar, ocean, wind or any other prescribed resource. An 12 SCGT plant using RNG as fuel is considered a clean resource option as biogas and 13 biomass are considered clean or renewable per the CEA definition. For the purposes of 14 this LTERP, FBC also considers energy and capacity under the PPA to be clean and 15 renewable, although there is a carbon footprint associated with the PPA as the resource 16 is 98 percent clean. For non-renewable resources, FBC has considered both direct GHG 17 emissions from burning fossil fuels (i.e. scope 1 emissions) and indirect GHG emissions 18 associated with the production of the fossil fuel (i.e. scope 3 emissions). Other environmental attributes, such as plant land or water footprint, have also been considered. 19 20 Based on the regional electricity generation source mix as discussed in Section 2.4.2, market purchases could include a mix of clean or renewable and non-clean or renewable 21 22 resources. For the purposes of this LTERP, as discussed in Section 2.5.7, FBC has 23 applied a clean adder to its market purchase prices to serve as a proxy for the purchase 24 of only clean and renewable power from the market."

- 25 27.1. Please confirm that FBC considers any natural gas purchased with a clean adder26 to be clean?
- 27 28

29

27.1.1. If no, please explain why not, and describe what would have to change for FBC to consider such resources to be clean.

30 Response:

Not confirmed. The 'clean market adder' in the portfolio scenarios applies to electricity purchases, rather than natural gas fuel for a resource option. In order for FBC to consider natural gas to be carbon neutral, and therefore having zero reportable GHG emissions in the portfolio, the portfolio scenario needed to assume RNG was used as fuel for the SCGT plants.

35

36



- 27.2. What is the forecast cost of clean adders by year over the planning period?
- 1 2

3 Response:

4 The clean market adder for electricity purchases was developed by IHS Markit. IHS Markit has 5 requested that FBC not disclose the yearly forecasted values publicly due to the commercial

6 sensitivity. The clean market adder was estimated by IHS Markit to be approximately \$2 per MWh

7 on a levelized basis over the planning horizon. The actual cost of a clean market adder will be a

8 point of negotiation between FBC and Powerex or a third party.

9 The implied premium for renewable natural gas is the difference between the forecast prices of

10 renewable natural gas and conventional natural gas in Appendix E.



3

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 54

1 28.0 Reference Exhibit B-1, Volume 1, Page 165 & 166

Section 10.3 - Resource Options Evaluation

FortisBC Inc. states:

Resource Option ¹⁷⁹	Portfolio Analysis Short Name	Туре	Number of Plants in FBC Portfolio Analysis	Average Dependable Capacity (MW)	Annual Energy (GWh)
PPA Tranche 1 Energy	PPA	Baseload	N/A	N/A	Up to 1,041
PPA Tranche 2 Energy	PPA	Baseload	N/A	N/A	Up to 711
PPA Capacity	PPA	Baseload	N/A	Up to 200	N/A
Market Purchases	Market	Baseload	N/A	Up to 75	Up to 3,241
Wood-Based Biomass	Biomass	Baseload	3	9 - 30	73-237
Geothermal	Geothermal	Baseload	4	15 - 75	130 - 657
Gas-Fired Generation (CCGT)	CCGT	Baseload	3	67 - 279	528 - 2,201
Small hydro with storage	Hydro	Baseload	4	8 - 50	77 - 443
Gas-Fired Generation (SCGT) - NG	SCGT	Peaking	3	48 - 100	75 - 158
Gas-Fired Generation (SCGT) - RNG	RNG_SCGT	Peaking	3	48 - 100	75 - 158
Pumped Hydro Storage	PSH	Peaking	2	100 - 1,000	N/A
Onshore Wind ¹⁸⁰	Wind	Intermittent	13	21 - 133	196 - 1,239
Resource Option ¹⁷⁹	Portfolio Analysis Short Name	Туре	Number of Plants in FBC Portfolio Analysis	Average Dependable Capacity (MW)	Annual Energy (GWh)
Run-of-River Hydro	RoR	Intermittent	3	2-6	16 - 52
Utility Scale Solar	Solar	Intermittent	11	4 - 107	28 - 754
Distributed Solar181	DistSolar	Intermittent	2	0.2	2 15

Peaking

Peaking

How was the dependable capacity limit for market purchases determined?

1

1

39

24

N/A

N/A

Table 10-1: Resource Options Type and Size Summary

4

5

6

7

28.1.

8 Response:

9 Please refer to the response to BCUC IR1 1.3.

Battery Storage¹⁸²

Distributed Battery

Storage¹⁸³

10

- 11
- 12 13

28.2. Has FBC evaluated an option to purchase additional market capacity access?

Battery

DistBattery

14 28.2.1. If yes, please provide documentation. FORTIS BC^{**}

1 28.2.2. If no, explain why not. 2 3 Response: 4 Please refer to the response to RCIA IR1 30.1 which discusses whether or not FBC has 5 investigated the availability and cost of acquiring long-term firm transmission, which would be 6 needed for additional market capacity access. 7 8 9 10 28.3. Why hasn't FBC evaluated RNG-Fired CCGT as a resource option? 11 12 Response: 13 FBC did not consider RNG-Fired CCGTs as a resource option given that the cost of RNG fuel 14 would make a baseload gas plant less favourable relative to other energy-oriented resource 15 options available. 16 17 18 19 28.3.1. What are the practical technical limitations (if any) to using RNG in a 20 CCGT facility? 21

(IR) No. 1

- 22 Response:
- 23 Given that RNG is indistinguishable from conventional natural gas from a combustion perspective,
- 24 FBC does not expect any technical limitations associated with using RNG in a CCGT facility.

FORTIS BC^{*}

2

FortisBC Inc. (FBC or the Company) Submission Date: 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side December 23, 2021 Management Plan (LT DSM Plan) (Application) Response to Residential Consumer Intervenor Association (RCIA) Information Request

(IR) No. 1

Page 56

1 29.0 Reference Exhibit B-1, Volume 1, Page 166

Section 10.3 - Resource Options Evaluation

3 FortisBC Inc. states:

"Table 10-2 shows the unit energy and capacity costs for the resource options (in real 4 5 \$2020). The range of unit costs reflects the different plant sizes available for some of the 6 resource options. No UEC is presented for capacity resources including SCGT gas-fired 7 generation, Pumped Hydro Storage or battery storage because these resources are 8 primarily used for providing capacity and not energy. There is no UCC value for market purchases as FBC has assumed capacity self-sufficiency for the purposes of this LTERP 9 for the reasons discussed in Section 2.4.4." 10

Resource Option	UEC (\$/MWh)	UCC (\$kW-year)
Low DSM	\$33	N/A
Base DSM	\$38	N/A
Med DSM	\$40	N/A
High DSM	\$45	N/A
Max DSM	\$58	N/A
PPA Tranche 1 Energy	\$49 - \$60	N/A
PPA Tranche 2 Energy	\$80 - \$95	N/A
PPA Capacity	N/A	\$101 - \$123
Market Purchases	\$28 - \$49	N/A
Wood-Based Biomass	\$121 - \$173	\$682 - \$719
Resource Option	UEC (\$/MWh)	UCC (\$kW-year)
Geothermal	\$114 - \$176	\$863 - \$1,377
Gas-Fired Generation (CCGT) - NG	\$90 - \$109	\$150 - \$287
Gas Fired Generation (SCGT) - NG	N/A	\$131 - \$148
Gas Fired Generation (SCGT) - RNG	N/A	\$131 - \$148
Small Hydro with Storage	\$101 - \$163	\$687 - \$1,271
Pumped Hydro Storage	N/A	\$102 - \$540
Onshore Wind	\$68 - \$91	\$509 - \$734
Run-of-River Hydro	\$111 - \$173	\$817 - \$1,330
Utility Scale Solar	\$99 - \$134	\$686 - \$863
Distributed Solar	\$137 - \$141	\$829 - \$882
Battery Storage	N/A	\$267
Distributed Battery Storage	N/A	\$226

Table 10-2: Supply-Side Resource Options Unit Cost Summary

12

- 13 14
- 15 16
- Table 10-1 (see above) shows that Market Purchases provide up to 75 MW of 29.1. capacity. Please explain why no UCC value is provided for the Market Purchases resource option shown in Table 10-2.



Request Page 57

1 <u>Response:</u>

FBC does not consider the market to be a reliable source of capacity over the planning horizonand therefore it is not a long term resource option. Please also refer to the response to BCUC

(IR) No. 1

- 4 IR1 1.3.
- 5
- 6
- 7
- 8 9
- 29.2. Why has FBC not included the UEC for SCGT-NG and SCGT-RNG?

10 **Response:**

FBC does not consider RNG SCGT or NG SCGT resources to be a practical source of large volumes of energy over the planning horizon. SCGT plants are capacity-oriented resources intended to serve the energy at the top of the load duration curve representing the peak hours only, rather than across all hours in the months. Furthermore, the UEC of a SCGT resource can

- 15 vary greatly depending on the capacity factor assumed.
- 16 The value of an SCGT resource is the dispatchable capacity reliably available during peak hours. 17 In other words, an SCGT is better suited to responding to unexpected system events, or when 18 scheduled energy is curtailed, rather than continually generating large volumes of energy. In the 19 event of a cold snap or heat wave, when several hours in a row are peak hours of the month or 20 even year, a SCGT unit is able to run continuously. An SCGT plant can also provide power to 21 localized load centres thereby supporting system transmission in contingency events if sited in a
- 22 favourable location.
- 23
- 24
- 25
- 26 27

29.3. Please provide the UEC and UCC for SCGT-NG with Clean Adders.

28 **Response:**

29 The following table provides the UEC and UCC ranges for NG-SCGT and RNG-SCGT resources.

30 As discussed in the response to RCIA IR1 27.1, the clean adder is not applicable for fuel used in

31 SCGT plants but rather to purchased market energy. An RNG-SCGT unit is assumed to run

32 exclusively on RNG, whereas the SCGT unit (or SCGT-NG as identified in the question) is

33 assumed to run exclusively on conventional natural gas.

Resource	Capacity Factor (%)	Size (MW)	UEC (\$2020/MWh)	UCC (\$2020/kW-Year)
RNG-SCGT	18	48 - 100	\$356 - \$367	\$131 - \$148
NG-SCGT	18	48 - 100	\$173 - \$184	\$131 - \$148



2 The UEC has been calculated based on the average annual energy available from these resource 3 types. Depending on the portfolio scenario, the dispatch of the SCGT units varies. In all scenarios 4 investigated, the effective capacity factor (based on the modelled dispatch) is much lower than 18 percent. Although the price of RNG is considerably greater than conventional natural gas, the 5 6 UECs are comprised of both fixed and variable costs that do not change with the price of fuel, 7 such as the cost of the turbine/generator unit as well as interconnection, operations, and 8 maintenance costs. Furthermore, the fuel costs of SCGT-NG units include the cost of carbon 9 (based on the carbon price forecast), which decreases the differential between the two UECs.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

FORTIS BC[~]

2

4 5

6

7

8

9

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

1 30.0 Reference Exhibit B-1, Volume 1, Page 170

Section 10.4 - Market Purchases

3 FortisBC Inc. states:

"There is also no guarantee that FBC will be able to access market capacity supply reliably, especially if there is no access to long-term firm transmission. FBC relies on Line 71 to access US market supply, and there can be transmission constraints both on Line 71 and on the US transmission south of the border that can interrupt that supply when FBC needs it for capacity purposes, as discussed in Section 5.5. Therefore, FBC does not believe that market supply can be relied on as a long-term capacity resource option."

- 30.1. Has FBC investigated the availability and cost of acquiring long-term firm
 transmission?
- 12 30.1.1. If yes, please provide documentation.
- 13
- 30.1.2. If no, please explain why not.

14

15 **Response:**

16 It is FBC's understanding that firm transmission rights to cross the BC/US border (i.e., WECC 17 transmission Path 3) are fully subscribed. FBC has not investigated the cost and availability of 18 acquiring any of this long-term firm transmission. FBC's confidential preliminary work on the 19 feasibility of building additional transmission facilities determined that there were no feasible 20 independent solutions at this time. Any new transmission facilities would require a very long lead 21 time with no guarantee of successful approval or completion.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)



Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 60

1 CHAPTER 11: PORTFOLIO ANALYSIS

2**31.0** ReferenceExhibit B-1, Volume 1, Page 1783Section 11.2 - Long Run Marginal Cost

4 FortisBC Inc. states:

"The LRMC values represent the cost to FBC of incremental resources needed to meet incremental load requirements over the planning horizon. The LRMC includes both energy and capacity generation components. FBC's LRMC values are outcomes of the portfolio analysis and are dependent upon which demand-side and supply-side resource options are included within a particular portfolio."

- 31.1. Please explain how a \$/MWh value captures the impact of FBC's forecast capacity
 requirements, especially considering that capacity deficiencies are identified as the
 primary driver of new FBC resource additions.
- 13

5

6

7

8

9

14 **Response:**

15 A portfolio approach in determining the LRMC recognizes multiple resources collectively meeting

16 the energy and capacity requirements over the planning horizon, rather than any one individual

17 resource. The LRMC should be viewed as a price signal and not considered in isolation from

other planning considerations, such as energy and capacity profiles of the other resourcescontained in the portfolio.

20 The LRMC has traditionally been stated on a unit energy cost basis as energy is what is ultimately

sold and consumed by the customer. It is not possible to have available energy without capacity
 generating it, but it is possible to have available capacity that is not producing energy. Capacity
 is the ability to reliably deliver energy in peak hours of need. FBC agrees with the observation

that generation capacity requirements are an important cost driver in the portfolio.

FORTIS BC^{*}

2

(IR) No. 1

Page 61

1 32.0 Reference Exhibit B-1, Volume 1, Page 182

Section 11.3.2 Market Access versus Self-Sufficiency

3 FortisBC Inc. states:

"FBC did explore a portfolio that did not have a self-sufficiency requirement for both energy 4 5 and capacity. However, since accessing market capacity to meet expected load utilizes 6 the same resource (i.e. transmission to the US market) that is used to provide reliability to 7 ensure planning reserve margin targets are met (discussed in Section 11.3.10), it is not 8 an appropriate portfolio in FBC's view. Furthermore, relving on capacity from the US 9 market for long-term planning is not appropriate given the risks FBC has identified in 10 Section 2.4.4. FBC recognizes that market capacity may be available from within B.C., 11 thereby avoiding this issue. However, FBC has no information at this time about what, if 12 any, B.C.-based market capacity resources may be available."

- 32.1. Has FBC attempted to initiate or held discussions with BCH to either purchase
 electricity from Site C, or to co-invest in Site C?
- 15

16

17

- 32.1.1. If yes, please describe the results or status of these discussions
- 32.1.2. If no, please explain why such discussions were not investigated.

18 **Response:**

FBC has not directly asked to participate in Site C either through an ownership or power purchase
 agreement. In FBC's view, the best way to potentially participate in any increased resources BC

21 Hydro may have available is either through a revised PPA agreement or an additional agreement

to purchase power. These potential agreements would not be tied directly to any one project.

23 FBC has had high-level discussions with BC Hydro in regards to purchasing increased amounts 24 of power from BC Hydro as a resource option. However, no detailed discussions have yet been 25 held. FBC expects that it will have had preliminary discussions with BC Hydro in regards to either 26 renewing and potentially expanding the PPA or entering into additional contracts with BC Hydro 27 prior to the next expected FBC LTERP in 2026. These are reasonable topics to consider as part 28 of the half-way mark review of the PPA which FBC intends to undertake in 2023. By that time, 29 FBC believes the 2021 LTERP and BC Hydro 2021 IRP processes will be concluded and BC 30 Hydro will also have additional certainly as to their available resources.



3

FortisBC Inc. (FBC or the Company) Submission Date: 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side December 23, 2021 Management Plan (LT DSM Plan) (Application) Response to Residential Consumer Intervenor Association (RCIA) Information Request Page 62 (IR) No. 1

1 33.0 Reference Exhibit B-1, Volume 1, Page 186

Section 11.3.5 – EV Charging Shifting

FortisBC Inc. provides Figure 11-5 which is reproduced below:



Figure 11-5: Portfolios based on Different Percentages of EV Charging Shifting

- 4 5
- What is the estimated probability that FBC will achieve 50% EV Charging Shifting 33.1. by 2030?
- 6 7

8 Response:

9 EV drivers are not generally expected to be concerned about starting charging later in the day in 10 non-peak periods provided their vehicles are charged before they need them the next day. Given 11 this anticipated load flexibility, FBC believes there is a high probability of shifting at least 50 12 percent of EV charging load off-peak by 2030.

- 13
- 14
- 15 16
- What is the most likely level of EV Charging Shifting that FBC expects to achieve 33.2. by 2030, if other than 50%?
- 17 18

19 Response:

20 As shown in the response to RCIA IR1 33.3, there is significant opportunity to shift EV charging

21 to a non-peak period. FBC expects that EV users will not generally be concerned about starting

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: December 23, 2021
Personance to Decidential Concurrent Interviener Accessition (PCIA) Information Decuest	



conse to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

- charging later in the day during non-peak periods, provided their vehicles are charged before they
 need them the next day. As such, FBC considers 50 percent a reasonable minimum level of peak
 demand shifting related to residential EV charging to be achieved by 2030, with a potential
 maximum of 75 percent as discussed in Section 2.3.2.
- 5
- 6
- 7
- 8 9
- 33.3. Please provide a daily chart showing the expected charging load shape for a household with a typical EV (i.e., Tesla 3 or equivalent), with and without EV charging shifting.
- 10

11 Response:

- The following figures show representative household load profiles with a typical light-duty EVcharge session requirement of approximately 20 kWh using a 6 kW Level 2 charger.
- 14 In the first figure, there is no EV charging shifting, the charge session begins at 5:30 pm and ends
- 15 shortly after 8 pm. In the second figure, 100 percent of the EV charging is shifted from the evening
- 16 to the early morning hours (12:30 am to shortly after 4 am).
- 17 As noted in the response to RCIA IR1 33.2, FBC expects to shift 50 percent of the EV charging
- 18 load through its software-based incentive approach.
- 19







FortisBC Inc. (FBC or the Company)Submission Date:
December 23, 20212021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side
Management Plan (LT DSM Plan) (Application)Submission Date:
December 23, 2021Response to Residential Consumer Intervenor Association (RCIA) Information Request
(IR) No. 1Page 64







(IR) No. 1

1 34.0 Reference Exhibit B-1, Volume 1, Page 190

2

3

Section 11.3.8 - Portfolios Considered for Preferred Portfolios

FortisBC Inc. states:





Could the SCGT portfolio elements in C3 and B2 potentially offset or defer the

corresponding to the elimination or deferral of the TL project.

If yes, please restate the LRMC values in figure 11-7 with a capital credit

need for the ACK-VAS 500 kV TL Project if advantageously sited?

4

- 5
- 6
- 7
- 8
- 9

34.1.2. If no, please explain why not.

10 11 Response:

34.1.

12 Please refer to the response to RCIA IR1 25.1.

34.1.1.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)



Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 66

1 CHAPTER 12: STAKEHOLDER, INDIGENOUS, AND CUSTOMER ENGAGEMENT

2	35.0	Refere	ence l	Exhibit B-1, Volume 1, Page 203	
3			ę	Section 12.1 Resource Planning Advisory Group	
4		FortisBC Inc. states:			
5 6		"More interes	specifica st in the w	ally, some of the feedback and areas of stakeholder and rights holder orkshops included the following items:	
7					
8 9		•	Inclusio portfolio	n of Indigenous collaboration/opportunities as a portfolio attribute in the evaluation rating framework;	
10 11		•	Conside custome	ration of potential changes to the CEA and a clean energy requirement for ers resulting in a clean portfolio option;	
12					
13 14		•	Conside achieva	eration of using percentage of Conservation Potential Review (CPR) ble potential to determine DSM portfolios;"	
15 16		35.1.	Please on the is	confirm that RPAG members provided differing viewpoints and feedback sues discussed during the RPAG sessions.	
17 18 19			35.1.1.	If confirmed, please explain how FBC balances differing feedback and viewpoints to avoid bias when incorporating RPAG feedback into FBC's planning decisions.	
20 21 22			35.1.2.	If not confirmed, please explain why FBC did not select RPAG members with a diverse set of viewpoints and feedback.	
23	Respo	onse:			
24	Confir	med. F	BC balar	nces differing feedback and viewpoints provided by the RPAG through its	

Confirmed. FBC balances differing feedback and viewpoints provided by the RPAG through its
 LTERP objectives, which ultimately guide FBC in its long-term resource planning decisions. FBC
 gives higher priority to feedback that is aligned with the LTERP objectives as set out in section
 1.2, as compared to feedback that is not.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)

2

3

4

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 67

1 36.0 Reference Exhibit B-1, Volume 1, Page 207

Section 12.3 Direct Customer Surveys

Exhibit B-1, Volume 1, Page 215

Section 13.2 2021 LTERP Action Plan

5 FortisBC Inc. states on pg. 207:

6 "In terms of EV ownership, 43 percent of residential and 37 percent of commercial 7 customers indicated that they are likely to purchase or lease an EV within the next three 8 years. The preferred approaches for managing EV charging by those indicating they are 9 likely to buy or lease an EV include incentives for charging during off-peak times and 10 rebates to customers who buy EV chargers that automatically charge during off-peak 11 times. The survey also indicates that 34 percent of residential and 49 percent of commercial customers are likely to install rooftop solar panels on their home or business 12 13 in the next five years, with similar percentages indicating a likelihood of also installing battery storage. Preferred incentives include rebates for installation of equipment and FBC 14 15 purchasing surplus energy from solar panel owners."

16 FortisBC Inc. states on pg. 215:

17 "As discussed in Section 2.3.2, EV growth is continuing within the FBC service area and 18 EV charging, if left unmitigated, could significantly increase peak demand on the system. 19 This could lead to the requirement for additional capacity generation resources and/or 20 transmission and distribution infrastructure, increasing rates for customers. FBC's 21 preference is to implement a software-based incentive program in order to encourage 22 shifting home EV charging from peak demand periods while requiring minimal customer 23 involvement. As part of this initiative, FBC intends to implement an EV charging pilot 24 project as part of a wider residential demand-response pilot. Section 4.6.3 of the LT DSM 25 Plan discusses this further."

- 36.1. Does FBC expect that 43 percent of residential customers will purchase or leasean EV in the next three years?
 - 36.1.1. If no, what percentage of customers does FBC expect will purchase or lease an EV in the next three years, and what is that determination based upon?
- 31

28

29

30

32 **Response:**

It is likely that the actual number of residential customers purchasing or leasing an EV in the next
three years will be less than 43 percent, as intent indicated through a survey does not always
translate to action. FBC's expectation of annual EV sales aligns with the current legislated ZEV *Act* sales targets discussed in Section 2.3.2.



1 2		
3 4 5 6 7 8	36.2.	Please confirm that "43 percent of residential customers indicated that they are likely to purchase or lease an EV with the next three years" means that FBC considers EV ownership mainstream and part of baseline planning conditions (i.e., although the uptake magnitude has uncertainty, uptake is considered a baseline condition).
9 10 11	_	36.2.1. If not confirmed, at what residential EV ownership threshold does EV ownership become part of FBC's baseline planning conditions?
12	<u>Response:</u>	
13 14 15	Commed.	
16 17 18 19 20 21	36.3. Response:	Given that "43 percent of residential customers indicated that they are likely to purchase or lease an EV with the next three years" explain why the pilot project represents an adequate plan to evaluate expected EV uptake.
22 23 24 25 26	Although the adoption rates vehicles. FE charging volu under the Cle	survey results are useful for assessing customer sentiment, FBC believes actual s will be lower than 43 percent due to barriers related to both cost and availability of BC is actively monitoring EV uptake through annual ICBC EV registration data, imes on FBC's public charging network, as well as through rebates administered anBC program for FBC customers.
27 28 29	Regardless of EV within the is a pilot proje	f the percentage of customers indicating that they are likely to purchase or lease an next three years, the appropriate first step in the implementation of any new program ect, which can later be scaled up based on effectiveness and need.
30	Please also re	efer to the response to RCIA IR1 36.1.
31 32		
33 34 35	36.4.	Does FBC expect that 34 percent of residential customers will install rooftop solar panels on their home or business in the next five years?"

		FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: December 23, 2021
FORTIS BC [*]		Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1	Page 69
1		36.4.1. If no, what percentage of customers does FBC expect v	vill install rooftop
2		solar panels in the next three years, and what is th	e basis for that
3		determination?	
4			
5	Response:		
6	Please refer	to the response to RCIA IR1 11.3.	
7			
0			
9			
10	36.5.	Please confirm that "34 percent of residential customers are	ikely to install
11		rooftop solar panels on their home or business in the next five ye	ars, with similar
12		percentages indicating a likelihood of also installing battery store	age" means that
13		FBC considers residential rooftop solar panel installations to be	mainstream and
14		part of baseline planning conditions (i.e., although the uptake	magnitude has
15		uncertainty, uptake is considered a baseline condition).	
16		36.5.1. If not confirmed, at what threshold does residential solar	oanel installation
17		become part of FBC's baseline planning conditions?	
18			
19	Response:		

Not confirmed. FBC does not expect that solar PV installations will reach the level indicated by the survey results and notes that only 0.5 percent of customers have net metering installations (which are required for grid-connected solar installations) today. Many customers aspire to install solar, but clearly barriers (primarily economic) exist to actual implementation.

24 Customers on the Net Metering tariff are part of the residential and commercial classes and, 25 therefore, their load impacts are naturally embedded into the LTERP BAU load forecast. In the 26 next resource plan, FBC will re-evaluate the residential (IPSS-RES) and commercial (IPSS-COM) 27 rooftop solar and storage load drivers, included in the load scenarios rather than the Reference 28 Case load forecast, as presented in Section 2.1 and Section 2.2 of Appendix H. The decision to 29 include a customer-based rooftop solar load driver in the Reference Case forecast in the future 30 will depend on clear signals from the operating environment that future adoption rates will be significantly higher than historical rates. For example, the decision to include EV charging load 31 32 in the Reference Case load forecast was based on regulatory requirements, specifically the ZEV 33 Act legislated light-duty EV sales targets (as discussed in Section 2.3.2). No equivalent signal 34 has been provided to indicate customer net metering rooftop solar should be included in the Reference Case load forecast at this time. 35

FORTIS BC^{**}

2

(IR) No. 1

Page 70

Submission Date:

1 37.0 Reference Exhibit B-1, Volume 1, Page 210

Section 12.4.3 Engagement Sessions

FortisBC Inc. states: 3

"Community representatives also raised concerns about past grievances relating to the 4 5 construction of existing hydroelectric generation facilities in the province. Representatives 6 in the meeting expressed that communities were not properly reimbursed for the lands 7 and culturally significant sites impacted or disrupted through the construction of these 8 facilities. It was raised to FBC that the inability to resolve these grievances makes it 9 challenging for communities to discuss energy planning issues and opportunities for the 10 future. Later in the meeting, another representative identified the need for FBC to continue 11 discussions with the communities on beneficial opportunities and how future benefits can 12 be paired to reconcile past grievances."

- 13
- 37.1. Please describe FBC's plans to reconcile past grievances, or the plan to develop a plan to reconcile past grievances.
- 14 15

16 Response:

17 As stated in Section 12.4.3, key concerns were raised by Indigenous community representatives 18 during LTERP engagement sessions about past grievances relating to the construction of 19 hydroelectric generation facilities in the province. These comments were directed broadly at 20 historic grievances pertaining to all hydroelectric generation facilities constructed in the province 21 of BC, not exclusively FBC-owned and operated hydroelectric generation facilities. FBC is committed to reconciliation with Indigenous peoples and continually engages with Indigenous 22 23 groups to strengthen relationships and to identify actions necessary to work towards 24 reconciliation. As additional supply-side resources are considered for future utility planning, FBC 25 will continue to engage with Indigenous groups to minimize impacts of FBC operations and to 26 identify how beneficial opportunities can be paired to reconcile past grievances, such as those 27 identified by community representatives during the LTERP engagement sessions.

- 28
- 29
- 30
- 31 32

33

- 37.2. Please describe which, if any, of the recommended 2021 LTERP Action Plan items, or sub-items therein, require reconciliation of past First Nation grievances to reach completion within the planning period.
- 34 35 Response:

36 Action Plan items 9 and 10 in Section 13.2 of the Application outline the importance of community

- 37 engagement and input into the ongoing resource planning process and in monitoring potential
- 38 available power supply opportunities moving forward. Reconciliation is directly applicable to these

BC™	FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: December 23, 2021
	Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1	Page 71

Action Plan items and actions toward reconciliation broadly apply to the entire LTERP Action Plan
 and FBC energy planning process.

3 With respect to RCIA IR1 37.2.1, various risks are posed by unreconciled grievances with 4 Indigenous communities. As discussed above, feedback and input provided by Indigenous 5 community representatives is an integral part of the LTERP development process. To the extent 6 that unreconciled grievances create challenges for Indigenous community representatives to 7 engage with FBC on energy planning and to share community energy plans or priorities, FBC's 8 ability to accurately capture community feedback and integrate this information into FBC's energy 9 planning process will be limited. Unreconciled grievances may also pose implementation risks for future FBC infrastructure projects or other supply-side resource considerations identified in the 10 11 LTERP. Given the importance of community input and feedback in the LTERP process as 12 described in Section 13.2 of the Application, FBC commits to continued engagement with 13 Indigenous groups, including identifying actions necessary to work towards reconciliation, and to 14 identify beneficial opportunities associated with supply-side resource options, planned 15 infrastructure projects, and future FBC operations and programs.

16

FORTIS

- 17
- .,
- 18
- 19 20
- 37.2.1. For any Action Plan items identified, please describe the risk posed by unreconciled grievances.
- 21
- 22 **Response:**
- 23 Please refer to the response to RCIA IR1 37.2.
FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)



Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Submission Date:

December 23, 2021

Page 72

1 38.0 Reference Exhibit B-1, Volume 1, Page 215

- 2 Section 13.2 2021 LTERP Action Plan
- 3

4

Exhibit B-1, Volume 1, Appendix N, Page 8

Customer Survey - Highlights

5 FortisBC Inc. states on pg. 215:

6 "EV growth is continuing within the FBC service area and EV charging, if left unmitigated, 7 could significantly increase peak demand on the system. This could lead to the 8 requirement for additional capacity generation resources and/or transmission and 9 distribution infrastructure, increasing rates for customers. FBC's preference is to 10 implement a software-based incentive program in order to encourage shifting home EV 11 charging from peak demand periods while requiring minimal customer involvement. As part of this initiative, FBC intends to implement an EV charging pilot project as part of a 12 13 wider residential demand-response pilot. Section 4.6.3 of the LT DSM Plan discusses this further." 14

FortisBC Inc. states in Appendix N: 15

16 "Many customers view this – and things like giving their utility some control of their 17 thermostat – as a form of surveillance. A significant amount of customer education is 18 probably still needed to allay customer concerns in this regard."

19 FortisBC Inc. states in Volume 2, pg. 26:

"The Company currently has a residential DR pilot phase out to tender. It will seek to 20 21 control and shift key household end-uses such as: space cooling, hot water and possibly 22 other devices such as pool pumps. Importantly, the scope includes controls of residential 23 home EV charging, which has been identified as the largest demand growth factor in this 24 LTERP."

25 26

27

38.1. What percentage of its customers does FBC expect will see utility control of, and visibility into, EV charging as "surveillance"?

28 Response:

29 FBC demand response programs are expected to be implemented on a voluntary basis. A leading 30 approach to shifting EV charging load involves providing a phone app that allows the customer to 31 control charging times on their own. If the customer opts-in to the incentive program, FBC would 32 receive information about when charging occurs in order to provide an incentive for charging 33 during off-peak periods. Customers that see this program as "surveillance" will presumably not 34 participate. FBC expects that most customers will realize that the program must verify results in 35 order to provide incentives.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)



Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 73

38.2. Why has FBC chosen control of residential home EV charging as the preferred approach to shifting home EV charging from peak demand periods?

5 6

1 2

3 4

7 Response:

8 FBC has not finalized an approach to EV demand response; however, demand response via
9 control of residential home EV charging is one approach to residential EV peak load shifting, as
10 described in Section 2.3.2.

As described in the response to RCIA IR 1.5.1, FBC believes that a leading alternative at this time for residential EV charging load-shifting is to use a software-based approach that will allow customers to choose when to charge their vehicles and to receive an incentive when charging

- 14 occurs outside of peak periods.
- 15
- 16
- 17
- 38.3. Are there other methods of shifting charging from peak demand periods and if yes,
 why were those options not chosen for advancement?
- 20

21 Response:

Aside from the hardware-based approach discussed in Section 8.2, there are other methods not included in the FBC demand response pilot that could shift EV charging from peak demand periods. These methods include:

- Behavioral nudges: Utilities can either send incentivized or non-incentivized behavior nudges through email, text message, or smart home appliance notifications to encourage customers to displace peak load. Participation is voluntary.
- FBC did not evaluate this method as it would likely need integration into FBC's *My energy use* portal, which has only recently come online. FBC may look to explore
 this intervention in a future pilot or program.
- Vehicle software-based demand response: Instead of having a demand-response program that sends signals to the vehicle charger, most electric vehicles have internal software that can control the period of charging or provide validation of when charging occurred.
- As discussed in the response to RCIA IR1 5.1, this approach for shifting residential
 EV charging loads offers a number of advantages, and will be further investigated
 in 2022 for a potential pilot.



1 2	Time-of-use rates: Utilities can set a time-of-use rate to encourage customers to displace peak load through price signals					
3 4 5	 Rate design is not a DSM intervention, so FBC did not evaluate this as part of the pilot. Any consideration of time-of-use rates would be as a part of a broader rate design exercise. 					
6 7						
8 9 10 11 12	38.4. Given that customers see utility control of residential home functions "as a form of surveillance", what are the primary barriers FBC foresees to the wider adoption of direct control of residential home EV charging?					
13	Response:					
14	FBC is aware of the following main barriers to the wider adoption of automated demand response:					
15 16	Incentive – The demand-response incentive must be high enough to offset the customer's inconvenience.					
17 18 19	 Inconvenience – Customers that have currently adopted electric vehicles disproportionally come from a demographic with higher incomes. Thus, for some customers no amount of reasonable incentive will change charging behaviour. 					
20 21 22 23 24	 Vehicle Charging Protocols for Demand Response – There are many different EV charging protocols (for example Open Intercharge Protocol, Open Automated Demand Response, Open Smart Charging Protocol) that makes integration with demand-response platforms challenging. FBC is not aware of a demand-response platform that can integrate with all demand-response protocols at this time. 					
25 26 27 28	• Awareness – The concept of demand-response programs is still relatively new to the British Columbia market. Educational and marketing campaigns will be necessary to educate customers on how demand response works, how it helps the utility, and how it may impact them as a customer.					
29 30 31 32	As a result, FBC's leading approach to residential EV charging load-shifting is through software that will allow the customer to choose when they charge. Although this approach does not require direct load control, it still requires FBC to receive data regarding when the charging actually occurred in order to validate and provide appropriate incentives. FBC believes this approach					

addresses both the inconvenience and available DR protocol concerns noted above. A softwarebased approach for leveraging both available EV original equipment manufacturer (OEM) application programming interfaces (APIs) as well as any already customer-installed smart chargers for validating EV load-shifting will allow FBC to implement a program that ensures as many customers as possible can participate without requiring additional hardware. FORTIS BC^{**}

Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 75

How will "customer education" mitigate the concerns that underpin customer 38.5. perceptions of direct control being "surveillance"?

6

1 2

3 4

5

7 Response:

8 Customer education will inform customers how demand response works, how it helps the utility, 9 and how it may impact them as a customer. As part of customer education, it will be important to 10 explain the limits of utility intervention to hopefully allay some potential concerns associated with 11 utility control of select devices. With better awareness of demand response, the customer will 12 have the opportunity to make an informed decision whether to voluntarily participate in the 13 program or not. 14

- 15
- 16
- 17
- 18
- 19
- 38.5.1. Are there any lessons FBC learned when implementing the Advanced Metering Infrastructure that can be applied to direct control of residential home EV charging?
- 20

21 Response:

22 The role of customer education was an important consideration prior to the FBC Advanced 23 Metering Infrastructure implementation and is applicable to future programs like direct control of

24 residential home EV charging.

25



Response to Residential Consumer Intervenor Association (RCIA) Information Request (IR) No. 1

Page 76

1 VOLUME 2, CHAPTER 4: DEMAND-SIDE MANAGEMENT PROGRAMS

2	39.0	Reference	Exhibit B-1, Volume 2, Pages 14-15
3			Section 3 DSM Scenario Development
4			Exhibit B-1 Volume 2, Pages 19-21
5			Section 4.1 Residential Sector
6			Section 4.2 Low-Income Household Programs
7		FortisBC Inc	c. presents the following on pg. 14 & 15:

Table 3-1: Key DS	M Scenario Data
-------------------	-----------------

2010/201	DSM Scenario				
Category	Low	Base	Med	High	Max
Energy Savings, GWh	0				
Average per annum (*21 - *40)	21.0	21.8	22.4	23.4	25.2
Average per annum (*21 - *29)	26.8	28.0	29.4	31.4	34.5
Total (2021 to 2040)	421	435	449	468	503

8

	DSM Scenario				
Category	Low	Base	Med	High	Max
Capacity Savings, MW					
Total (2021 to 2040)	61.6	64.0	65.6	68.1	72.7
Resource Cost, 2020 (\$000s)					
Average Cost (\$/MWh)	\$38	\$44	\$49	\$57	\$75
Incremental cost compared to base case (\$/MWh)	N/A	-	\$183	\$190	\$234

9

10 FortisBC Inc. states on pg. 19 – 21, the following Residential Sector Programs:

- 11 1) Residential Sector Programs:
- 12 a. Home Renovation Rebates
- 13 b. Retail Rebates
- 14 c. Now Home Rebates
- 15 d. Rental Apartment Program
- 16 2) Low-Income Household Programs:
- 17 a. Self-Install
- 18 b. Direct Install
- 19 c. Other Initiatives
- 2039.1.Please provide an enhanced Table 3-1 for the Low, Base and Med DSM Scenarios21that shows the Energy Savings, Capacity Savings, Average Cost, and Incremental22Cost Compared to the Base Case for each of the Residential Sector Programs and23each of the Low-Income Household Programs.



1

2 **Response:**

- 3 Programs are identified, at a high-level, to include cost-effective measures identified in the 2021
- 4 Conservation Potential Review. The LT DSM Plan does not include the granularity of program
- 5 design, participation or budgeting at a program-level.
- 6 Within the 2021 Conservation Potential Review, Low-Income Residential customers are 7 considered part of the Residential sector. The following table presents energy and capacity
- 8 savings for cost-effective measures for the five DSM Scenarios in the Residential sector.

Category	DSM Scenario (Residential sector only)						
	Low	Base	Med	High	Max		
Energy Savings, GWh							
Average per Annum (2021 to 2040)	4.8	5.3	5.3	5.3	5.3		
Average per Annum (2021 to 2029)	5.6	6.0	6.1	6.1	6.1		
Total (2021 to 2040)	95	105	107	107	107		
Capacity Savings, MW							
Total (2021 to 2040)	20.7	22.7	23.0	23.0	23.0		

9 The average and incremental costs compared to the base case was not analyzed at a sector

- 10 level. Individual measure assumptions are included in Appendix A of the LT DSM Plan,11 Appendices B1 and B2.
- 12
- 13
- . 0
- 14
- 39.2. Given that BC Hydro is trying to increase its electrical load, what discussions has
 FBC had with BC Hydro to supply additional load to BC Hydro rather than to
 continue pursuing DSM?
- 18
- 19 **Response:**
- 20 FBC has not met with BC Hydro to discuss supplying more power to FBC in place of FBC pursuing
- 21 DSM programs. The Clean Energy Act emphasizes the deployment of demand-side measures to
- 22 meet growing electricity demand in British Columbia. FBC's objective for DSM activities is to offer
- 23 customers in its service area a range of programs, within a cost-effective portfolio of measures,
- 24 which address the majority of end uses for each major customer sector. The rebate, or level of



- 1 incentive, FBC is willing to offer customers gives consideration to the avoided costs of electricity,
- 2 which includes power from BC Hydro under the PPA.

3