



**Diane Roy**  
Vice President, Regulatory Affairs

**Gas Regulatory Affairs Correspondence**  
Email: [gas.regulatory.affairs@fortisbc.com](mailto:gas.regulatory.affairs@fortisbc.com)

**Electric Regulatory Affairs Correspondence**  
Email: [electricity.regulatory.affairs@fortisbc.com](mailto:electricity.regulatory.affairs@fortisbc.com)

**FortisBC**  
16705 Fraser Highway  
Surrey, B.C. V4N 0E8  
Tel: (604)576-7349  
Cell: (604) 908-2790  
Fax: (604) 576-7074  
[www.fortisbc.com](http://www.fortisbc.com)

April 21, 2022

British Columbia Utilities Commission  
Suite 410, 900 Howe Street  
Vancouver, B.C.  
V6Z 2N3

Attention: Mr. Patrick Wruck, Commission Secretary

Dear Mr. Wruck:

**Re: FortisBC Inc. (FBC)**

**2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application) – Project No. 1599244**

**FBC Information Request No. 1 to the Residential Consumers Intervener Association (RCIA) on its Intervener Evidence**

---

In accordance with the regulatory timetable established in BCUC Order G-24-22 for the review of the Application, attached please find information request No. 1 to RCIA on its Intervener Evidence.

If further information is required, please contact the undersigned.

Sincerely,

**FORTISBC INC.**

***Original signed:***

Diane Roy

Attachments

cc (email only): Registered Parties

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: April 21, 2022
FortisBC Inc. (FBC) Information Request (IR) No. 1 to Residential Consumer Intervenor Association (RCIA)	Page 1

1   **TOPIC:           Purpose and Background**

2   **1.0   Reference:   Midgard Evidence submission page 7**

3       Based on these three (3) materially similar definitions of resiliency, the definition of  
4       resiliency that will be used in the remainder of this paper is the one (1) provided by the  
5       US Department of Energy because it is the simplest and most direct: *“The ability of a*  
6       *power system and its components to withstand and adapt to disruptions and rapidly*  
7       *recover from them.”*

8       **Reference:   FBC LTERP Response to BCSEA IR1 6.3**

9       6.3   Does Action Item 3 mean that FBC’s resource portfolio is not sufficiently flexible  
10       and adaptable to unexpected changes in loads?

11       *Response:*

12       This action item does not mean that FBC’s current resource portfolio is not sufficiently  
13       flexible and adaptable to unexpected changes in loads. Planning and operations should  
14       not be confused. FBC has significant flexibility to deal with unplanned loads or unit  
15       outages on an operational basis as confirmed by the PRM calculations.

16       **Reference:   FBC LTERP Section 11.3.8**

17       The resiliency attribute includes operational flexibility and geographic diversity.  
18       Operational flexibility refers to the ability of the portfolio to manage higher than expected  
19       energy and capacity loads. These loads may occur over a short period of time such as  
20       occurred this past June 2021 with record setting daily loads or over a longer period of  
21       time due to unexpected load growth.

22       Geographic diversity reflects whether or not the portfolio resources are located within or  
23       near the Kootenay or Okanagan regions of FBC’s service area. As discussed in Section  
24       5.1, FBC’s existing generation resources are located within the Kootenay region, while  
25       most of FBC’s customer load requirements are in the Okanagan. Therefore, adding  
26       resource options to the Okanagan improves FBC’s resource diversity. All three portfolios  
27       in the table below have ‘high’ geographic diversity ratings given that they contain solar  
28       resources, which are located in the Okanagan, as well as battery and SCGT plants,  
29       which could be located in either region and most likely closer to key load growth centres,  
30       like Kelowna.

31       **Questions:**

32       1.1   **In general, does the RCIA agree that a portfolio with battery storage and**  
33       **two SCGT plants located near the Kelowna area, could add resiliency, as**  
34       **defined by the US Department of Energy, to FBC’s current resource**  
35       **portfolio?**

36       1.1.1 **If not, why not?**

37

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: April 21, 2022
FortisBC Inc. (FBC) Information Request (IR) No. 1 to Residential Consumer Intervenor Association (RCIA)	Page 2

1    **2.0    Reference:    FBC LTERP Section 6.2.2**

2    There are a total of eight transmission interconnections between the FBC system and  
3    the systems of neighbouring transmission entities, including BC Hydro. FBC  
4    transmission interconnections improve reliability by providing the flexibility to move  
5    energy between FBC and other utilities (primarily BC Hydro), to transfer FBC's own  
6    resources from the point of generation in the Kootenays to its major load centre in the  
7    Okanagan, to import market power and also provide economic benefits based on the  
8    ability to share generation operating reserves. FBC's ability to import and export  
9    electricity from other members of the Western Interconnection improves system  
10   reliability and has economic benefits for FBC by allowing the Company to access  
11   transmission and generation resources that it would not otherwise be able to access.

12    **Questions:**

13    **2.1    In general, does the RCIA agree that multiple transmission**  
14    **interconnections help provide system resiliency?**

15    **2.1.1    If not, why not?**  
16

17    **3.0    Reference:    FBC LTERP Section 6.3.2**

18    FBC's planning criteria require that the system be planned, designed and operated to  
19    serve all customer loads both during normal operations and during contingency  
20    operations (i.e. one or more system elements out of service). The most basic criterion is  
21    that the system infrastructure must be sufficient to meet all reasonably forecast customer  
22    demand with all system components (e.g. transmission lines and transformers) in  
23    service. This is referred to as "all elements inservice" or N-0 operation. The next, more  
24    limiting, condition is single contingency (N-1) operations where FBC's planning criteria  
25    state that the transmission system infrastructure must also be sufficient to meet all  
26    reasonably forecast customer demand even with the single most limiting transmission  
27    component out of service. Exceptions are allowed for customer loads supplied radially  
28    by the faulted element or affected area. For double contingency (N-2) and higher  
29    conditions, the criteria allow planned and controlled disconnection of customer loads.  
30    Remedial Action Schemes may be employed during system operations to minimize the  
31    scope of customer outages for N-2 contingencies. These planning criteria are consistent  
32    with those used by other utilities in the Western Interconnection.

33    **Questions:**

34    **3.1    In general, does the RCIA agree that planning criteria requirements to N-1**  
35    **and higher system reliability standards provide system resiliency?**

36    **3.1.1            If not, why not?**  
37

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: April 21, 2022
FortisBC Inc. (FBC) Information Request (IR) No. 1 to Residential Consumer Intervenor Association (RCIA)	Page 3

1    **4.0    Reference:    FBC LTERP Response to BCUC IR1 24.1**

2    24.1    Please discuss how FBC has been building climate resiliency using its standards  
3            and practices over time. Please provide specific examples.

4            *Response:*

5            There are several ways in which FBC has been building climate resiliency using its  
6            standards and practices over time.

7            FBC performs an annual inspection for all transmission and distribution lines, and  
8            conducts repairs for any urgent work identified. Condition assessments are completed  
9            on an eight-year cycle for transmission and distribution lines and on a six-year cycle for  
10           substations. Rehabilitation work to repair the aging infrastructure is completed in the  
11           following years.

12           FBC has also been working to harden the power system to withstand higher wind  
13           speeds and other environmental factors through updated designs and material selection.  
14           A recent example is the rehabilitation work on the 63kV transmission line 27L to account  
15           for increased snow loading as this is a frequent environmental factor that impacts this  
16           line.

17           Substations that fall within a flood zone are redesigned and raised above the flood level  
18           when the stations are rebuilt. A recent example includes the Ruckles Substation  
19           Upgrade, which raised the site above the 1 in 200-year flood level and successfully  
20           avoided flooding damage in 2018.

21           FBC continues to enhance its system protection by upgrading distribution recloser  
22           protection to detect and clear faults faster, as well as providing communications-assisted  
23           system automation.

24           FBC is conducting assessments to analyze the vulnerability of its system to the impacts  
25           of climate change. FBC is currently working with an external consultant to develop  
26           wildfire risk modeling. The assessment is expected to be complete in 2022. After this  
27           project is complete, FBC will begin to further assess the risks related to flooding and  
28           extreme weather in more detail.

29           **Reference:    FBC LTERP Response to BCUC IR1 24.3**

30           24.3    Please discuss whether FBC is aware of current standards that integrate  
31            considerations of the impacts of climate change on electric utilities.

32            24.3.1    If yes, please identify the standard(s) and whether FBC has considered  
33                    adoption of the standard(s).

34            24.3.2    Please discuss whether FBC is aware of other electric utilities that have  
35                    adopted the standards identified.

36            *Response:*

37            FBC follows industry practices, and IEEE and CSA standards (including CSA C22.3 No.  
38            1 Overhead Systems, CSA C22.3 No. 7 Underground Systems, and CSA C22.3 No.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: April 21, 2022
FortisBC Inc. (FBC) Information Request (IR) No. 1 to Residential Consumer Intervenor Association (RCIA)	Page 4

1 60826 Design Criteria of Overhead Transmission Lines). FBC is aware that these  
2 organizations are working on updating the standards related to integrating  
3 considerations of climate change impacts. Once completed, FBC intends to consider,  
4 and adopt if appropriate, the updated standards as guidelines. However, FBC intends to  
5 be proactive regarding the resiliency of its system in light of climate change impacts  
6 regardless of the timing of standards development.

7 **Reference: FBC LTERP Response to BCUC IR1 24.4**

8 24.4 Please discuss what progress FBC has made to date in analyzing the need for the  
9 above noted adaptation measures in FBC's service territory.

10 *Response:*

11 FBC is in the process of developing a roadmap for climate change adaptation. Wildfires,  
12 flooding, and extreme weather events (including windstorms) are considered the highest  
13 risks for the FBC service territory.

14 To mitigate the impacts of flooding, substation construction takes into account floodplain  
15 data to ensure that stations are raised to an appropriate height. FBC is also researching  
16 and assessing, through pilot programs, the use of alternative materials for poles in areas  
17 impacted by flooding.

18 FBC is developing an internal business case to assess various mitigation strategies for  
19 wildfires. Some of these solutions will be dependent on the results of the wildfire risk  
20 modeling currently under development with an external consultant. These strategies  
21 include, but are not limited to, application of fire-retardant gel to wood poles, current-  
22 limiting fuses, fire-protection mesh, and updates to FBC's reclosing policy.

23 Similar business cases will be developed for flooding and extreme weather events  
24 (including windstorms) once similar assessments for these climate change impacts are  
25 completed.

26 **Questions:**

27 4.1 **In general, would the RCIA agree that the type of work and plans regarding**  
28 **system enhancements described in the IR responses in the question**  
29 **preamble above play a role in providing system resiliency?**

30 4.1.1 **If not, why not?**  
31

32 **5.0 Reference: FBC LTERP Response to CEC IR1 28.3**

33 28.3 Please identify any redundancy in the supply that can respond to outages of  
34 certain facilities.

35 *Response:*

36 FBC's available energy and dependable capacity from the FBC CPA entitlements,  
37 BPPA, BRX, and WAX (net of RCA) are subject to generation outages at the

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: April 21, 2022
FortisBC Inc. (FBC) Information Request (IR) No. 1 to Residential Consumer Intervenor Association (RCIA)	Page 5

1 corresponding facilities. FBC has several options to respond to outages, and replace lost  
2 power. On a short-term, operational basis, FBC can call on operating reserve to cover  
3 any power lost for the first 60 minutes of any outage. For any outages longer than 60  
4 minutes in duration, FBC has the option of purchasing replacement power from the  
5 wholesale market, via its CEPSA contract with Powerex. FBC may also choose to  
6 reduce the amount of surplus WAX capacity that it sells to Powerex under the CEPSA,  
7 and retain that capacity for its own use. Furthermore, FBC can also increase its usage  
8 under the PPA contract with BC Hydro, as FBC is rarely using the full 200 MW of PPA  
9 capacity available, and has never used the full amount of energy available under the  
10 contract.

11 **Reference: FBC LTERP Response to CEC IR1 38.2**

12 38.2 Please provide a discussion of the full capability FBC would need to have in order  
13 to fill this gap in the event that contingency requirements were necessary because  
14 of a failure of any particular source of capacity needed.

15 *Response:*

16 In the response to CEC IR1 38.1, FBC provided a list of FBC's resources and the  
17 corresponding capacity (in MW) that FBC used to meet its capacity needs in June 2021.  
18 During that period, FBC's available capacity exceeded the load level during the heat  
19 dome event. Although there can be no "planning" for such an unprecedented event, this  
20 illustrates the depth and flexibility of FBC's capability to meet unplanned load on an  
21 operational basis.

22 The magnitude of the load was itself a severe contingency requirement. If further  
23 resource contingency events had occurred (such as FBC generator outages), FBC  
24 would have been able to call on Operating Reserve for 60 minutes. After that, even  
25 higher market purchases would have been required, if available. If the market resources  
26 were unavailable, then there would have been no other recourse but to exercise the  
27 Imbalance Agreement with BC Hydro, which allows FBC to rely on BC Hydro supply on  
28 an emergency basis. If that had also been insufficient due to BC Hydro's inability to  
29 provide the needed capacity, then FBC would have had no choice but to manually curtail  
30 load.

31 The largest capacity resource used to meet the June 2021 heat dome event was market  
32 supply of 265 MW. Of this, 239 MW was required to meet load. Therefore, if the market  
33 had been unavailable, 239 MW of additional generation resources within FBC's service  
34 area would have been required to meet the peak load demands.

35 **Questions:**

36 5.1 **In general, would the RCIA agree that the ability, if qualified, to call on tools**  
37 **such as Operating/Contingency Reserve (under the NWPP Reserve Sharing**  
38 **Program) and exercising the Imbalance Agreement, if there were no other**  
39 **recourse, provides resiliency?**

40 5.1.1 **If not, why not?**

41

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: April 21, 2022
FortisBC Inc. (FBC) Information Request (IR) No. 1 to Residential Consumer Intervenor Association (RCIA)	Page 6

1 **TOPIC: Scenario Planning**

2 **6.0 Reference: Midgard Evidence submission page 13**

3 However, adequately evaluating system resiliency requires testing alternative resource  
4 portfolios against future “extreme” or “surprise” scenarios, that incorporate one (1) or  
5 more significant discontinuities from BAU.

6 **Reference: FBC LTERP Response to CEC IR1 21.2**

7 21.2 Please provide the probability of the peak weather events observed over the  
8 summer of 2021.

9 *Response:*

10 FBC estimates the probability of meeting or exceeding the average daily temperature  
11 experienced on June 29, 2021 is about 0.00025 percent.

12 To calculate this probability, FBC used temperature records from the Penticton airport  
13 from 1941 to 2021. FBC examined the data and calculated the average daily  
14 temperature for the warmest day each summer (referred to as the “maximum mean daily  
15 temperature”, or MMDT<sup>1</sup>). FBC then used the average and standard deviation to  
16 construct a normal distribution of MMDTs to determine the probabilities of experiencing a  
17 peak summer temperature at or below any selected MMDT. Based on this calculation,  
18 the probability of the peak summer temperature being 33.6 degrees Celsius or lower is  
19 99.99975 percent. Therefore the probability of meeting or exceeding the MMDT  
20 experienced in 2021 is (1.0 - 0.9999975) or 0.00025 percent.

21 FBC notes:

- 22
- Many different return periods have been reported in the public discourse.
  - The method presented assumes the weather experienced in June 2021 is anomalous. If this event is not anomalous then there is no reliable objective method to calculate the return period based on a single data point.
  - Probabilities this small should only be considered as directional as precision cannot be guaranteed and should not be expected.
- 26  
27

28 **Questions:**

29 **6.1 Would RCIA agree that the “heat dome” experienced in 2021 was an**  
30 **example of a “surprise event”?**

31 **6.2 Would RCIA agree that the return period of the “heat dome” event is**  
32 **greater than 500 years?**

33 **6.2.1 If not, what is the return period for this event?**

---

1 The MMDT can be thought as the “hottest day of the summer”.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: April 21, 2022
FortisBC Inc. (FBC) Information Request (IR) No. 1 to Residential Consumer Intervenor Association (RCIA)	Page 7

1           6.3     **Should the utility identify a consistent return period for anomalous events**  
2                     **for resiliency modelling?**

3                     6.3.1   **If so, what return period should be used for modelling anomalous**  
4                                 **events that are presumably outside of the historic experience of the**  
5                                 **utility?**

6                     6.3.2   **If not, why not?**

7           6.4     **Based on RCIA’s experience, does it have any recommendations to provide**  
8                     **to FBC on how to incorporate anomalous events into its forecasts?**  
9

10   **Topic:           Modern Portfolio Theory and Capital Asset Pricing Model Portfolio Theory**

11   **7.0     Reference:    Midgard Evidence submission page 18-19**

12           Markowitz’s theory demonstrates that the performance of a portfolio improves with the  
13           combination of noncorrelated assets. In other words, if an incremental asset is added to  
14           a portfolio, then the risk adjusted performance of the resulting overall portfolio will  
15           improve if the attributes which influence the new asset’s performance are uncorrelated to  
16           the prior portfolio’s performance attributes. The extent of improvement is inversely  
17           related to the level of performance attribute correlation. As stated by Markowitz [4], the  
18           only reason the overall risk adjusted performance of a combined portfolio would not  
19           improve is if individual assets are perfectly correlated. An uncorrelated financial asset  
20           portfolio would likely perform better than a correlated portfolio when faced with a market  
21           discontinuity – in other words, it would be more resilient to a significant forced  
22           perturbation.

23           **Reference:    FBC LTERP Section 5.1**

24           FBC owns the Corra Linn, Upper Bonnington, Lower Bonnington, and South Slocan  
25           generating plants (collectively, the FBC Plants) located on the Kootenay River between  
26           Nelson and Castlegar, BC. The FBC Plants supplied approximately 44 percent of FBC’s  
27           energy requirements and approximately 28 percent of the Company’s peak demand in  
28           2020.

29           **Reference:    FBC LTERP Section 5.8**

30           FBC meets its energy and capacity requirements primarily through a portfolio of FBC-  
31           owned entitlement resources, long-term entitlement purchase agreements, and  
32           purchases under the BC Hydro PPA. Any remaining energy needs are met through short  
33           to medium term market, IPP, and other resource purchases.

34           **Reference:    FBC LTERP Section 11.3.9.1**

35           The preferred portfolios include a diverse mix of resource options, including the PPA,  
36           market energy, battery storage, SCGT plants using RNG, solar, wind and run of river  
37           generation.

FortisBC Inc. (FBC or the Company) 2021 Long-Term Electric Resource Plan (LTERP) and Long-Term Demand-Side Management Plan (LT DSM Plan) (Application)	Submission Date: April 21, 2022
FortisBC Inc. (FBC) Information Request (IR) No. 1 to Residential Consumer Intervenor Association (RCIA)	Page 8

1           **Questions:**

2           7.1     **Does the RCIA agree that a portfolio of resources, such as those in FBC's**  
3                 **mix of existing resources and those included in the preferred portfolios**  
4                 **includes a mix of 'noncorrelated' resources, thus providing resiliency?**

5                 7.1.1           **If not, why not?**

6