



Sarah Walsh
Director, Regulatory Affairs

Gas Regulatory Affairs Correspondence
Email: gas.regulatory.affairs@fortisbc.com

Electric Regulatory Affairs Correspondence
Email: electricity.regulatory.affairs@fortisbc.com

FortisBC
16705 Fraser Highway
Surrey, B.C. V4N 0E8
Tel: (778) 578-3861
Cell: (604) 230-7874
Fax: (604) 576-7074
www.fortisbc.com

March 12, 2024

British Columbia Utilities Commission
Suite 410, 900 Howe Street
Vancouver, BC
V6Z 2N3

Attention: Patrick Wruck, Commission Secretary

Dear Patrick Wruck:

Re: FortisBC Inc. (FBC)

FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)

Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1

On December 22, 2023, FBC filed the Application referenced above. In accordance with the regulatory timetable established in BCUC Order G-17-24 for the review of the Application, FBC respectfully submits the attached response to BCUC IR No. 1.

FBC requests that the Live Excel Spreadsheet included as Attachment 4.1 be filed on a confidential basis and held confidential by the BCUC in perpetuity, pursuant to section 18 of the BCUC's Rules of Practice and Procedure regarding confidential documents as set out in Order G-72-23. Confidential Attachment 4.1 contains commercially sensitive and market competitive information regarding detailed performance and utilization of FBC's EV DCFC service for each individual station which, if publicly disclosed, could potentially jeopardize the market competitiveness of FBC's individual stations, which could result in higher costs for customers. FBC, therefore, requests that Attachment 4.1 be filed on a confidential basis in perpetuity and that it only be made available to interveners upon executing a Confidentiality Declaration and Undertaking form acceptable to the BCUC.

For convenience and efficiency, if FBC has provided an internet address for referenced reports instead of attaching the documents to its IR responses, FBC intends for the referenced documents to form part of its IR responses and the evidentiary record in this proceeding.

If further information is required, please contact the undersigned.

Sincerely,

FORTISBC INC.

Original signed:

Sarah Walsh

Attachments

cc (email only): Registered Interveners

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 1

1 **1.0 Reference: BACKGROUND**

2 **Exhibit B-1, FortisBC Inc. (FBC) Electric Vehicle (EV) Direct Current**
3 **Fast Charging (DCFC) Energy-Based Rate Application (Application),**
4 **Section 1.1.1, pp. 2–4**
5 **Temporary Dispensation**

6 On pages 2 and 3 of the Application, FBC states:

7 [...] On December 18, 2023, FBC applied to Measurement Canada’s temporary
8 dispensation program for its existing EV DCFC charging stations and expects to
9 receive approval early in 2024. FBC’s ability to implement the energy-based rates
10 applied for in this Application is contingent on FBC receiving approval for
11 temporary dispensation from Measurement Canada.

12 On page 4 of the Application, FBC indicates that FLO Services Inc. (FLO) will implement
13 changes to FBC’s EV DCFC stations and network to support energy-based rates. FLO
14 requires at least 4 weeks for implementation. FBC proposes that the effective date of its
15 energy-based rates be provided in a compliance filing with the British Columbia Utilities
16 Commission (BCUC) for endorsement of the revised RS 96 tariff reflecting its energy-
17 based rates.

18 1.1 Apart from the minimum 4 weeks for FLO’s network changes, please briefly
19 discuss how long FBC expects to transition to the proposed energy-based rate
20 after receiving temporary dispensation approval from Measurement Canada (e.g.
21 with considerations to the time needed for processing a customer notice, mobile
22 app change, billing system configurations, etc.).

23
24 **Response:**

25 FBC does not expect further time will be needed for the transition beyond the time required for
26 FLO’s implementation of its network changes (i.e., beyond the minimum four weeks). As
27 discussed in Section 4.1 of the Application, FBC will undertake the other transitional activities
28 such as communication to customers and billing system configurations at the same time as FLO’s
29 implementation work.

30 FBC clarifies that its reference to a “minimum” of four weeks reflects that FBC is proposing to
31 implement the energy-based rate on the 1st day of the month following when FLO’s
32 implementation is complete (as opposed to implementing the rate midway through a month).
33 Thus, FBC would likely implement the rate a certain number of days or weeks after FLO completes
34 its implementation, depending on when in the month FLO’s implementation is complete.

35
36
37



FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 2

1 1.2 Please explain whether FBC will implement energy-based rates (i) for all stations
2 at once or (ii) in multiple phases where both energy-based and time-based rates
3 will coexist for a certain period.
4

5 **Response:**

6 FBC intends to implement energy-based rates for all stations at once.
7
8

9
10 1.3 Please confirm, or explain otherwise, in the event one or more of FBC's DCFC
11 stations do not qualify for temporary dispensation, whether FBC will continue to
12 charge time-based rates for those stations.
13

14 **Response:**

15 FBC expects that all of its DCFC stations will receive temporary dispensation as they all meet the
16 requirements set out by Measurement Canada.

17 However, in the unlikely event that one or more of the stations do not qualify for temporary
18 dispensation, FBC will work with Measurement Canada and FLO to implement the changes
19 necessary to enable these stations to receive temporary dispensation. In this unlikely scenario,
20 FBC would seek BCUC approval to continue to charge the existing time-based rates for those
21 individual stations for which temporary dispensation was not received and would file an updated
22 revised RS 96 tariff that includes both time-based and energy-based rates as part of the
23 compliance filing to the BCUC's decision on this Application.

24



1 **2.0 Reference: BACKGROUND**

2 **Exhibit B-1, Section 1, p. 1**

3 **Customer Bill Impacts on Transition to Energy-Based Rate**

4 On page 1 of the Application, FBC states:

5 Currently, the rates at FBC’s EV DCFC stations are approved under Rate
 6 Schedule (RS) 96 on a permanent basis pursuant to BCUC Order G-350-21, dated
 7 November 30, 2021. The current time-based charging rates are \$0.26 per minute
 8 for the 50 kW stations and \$0.54 per minute for the 100 kW stations.

9 2.1 Please complete the following tables for the three scenarios listed below to
 10 illustrate the customer bill impact for various EV models at different direct current
 11 (DC) charging acceptance rates, assuming all the EVs start at a 10% state of
 12 charge. Include any additional assumptions used.

13 **Scenario 1 - 2019 Nissan Leaf (40 kW DC Charging Acceptance Rate)**

Power Level	Charge Duration	Total kWh Dispensed	Existing Time-Based Rate (cents/min.)	Total Charging Bill (\$)	Proposed Energy-Based Rate (cents/kWh)	Total Charging Bill (\$)	Bill Impact (%)
(A)	(B)	(C)	(D)	(E = B*D /100)	(F)	(G = C*F /100)	(H = (G/E - 1)*100)
50 kW	30 min.		26		42		
100 kW	30 min.		54		42		

15 **Scenario 2 - 2019 Kia Soul (77 kW DC Charging Acceptance Rate)**

Power Level	Charge Duration	Total kWh Dispensed	Existing Time-Based Rate (cents/min.)	Total Charging Bill (\$)	Proposed Energy-Based Rate (cents/kWh)	Total Charging Bill (\$)	Bill Impact (%)
(A)	(B)	(C)	(D)	(E = B*D /100)	(F)	(G = C*F /100)	(H = (G/E - 1)*100)
50 kW	30 min.		26		42		
100 kW	30 min.		54		42		

17 **Scenario 3 - 2022 Audi Q4 E-Tron (125 kW DC Charging Acceptance Rate)**

Power Level	Charge Duration	Total kWh Dispensed	Existing Time-Based Rate (cents/min.)	Total Charging Bill (\$)	Proposed Energy-Based Rate (cents/kWh)	Total Charging Bill (\$)	Bill Impact (%)
(A)	(B)	(C)	(D)	(E = B*D /100)	(F)	(G = C*F /100)	(H = (G/E - 1)*100)
50 kW	30 min.		26		42		
100 kW	30 min.		54		42		

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 4

1 **Response:**

2 Concurrently with these IR responses, FBC has filed an Evidentiary Update to the Application
3 which updates FBC's proposed energy-based rate from \$0.42 per kWh to \$0.39 per kWh. As
4 explained in the Evidentiary Update, the change to the proposed energy-based rate is primarily
5 due to an update to the BC Low Carbon Fuel Standard (BC-LCFS), which became effective on
6 January 1, 2024¹ and has changed the calculation related to carbon credits. FBC describes the
7 changes and the impact on the calculation of the energy-based rate in the Evidentiary Update.
8 Additionally, as part of the Evidentiary Update, FBC has updated the rate calculation to include
9 actual data for the full year of 2023 (the data included in the Application only included actuals up
10 to November 2023).

11 FBC has accordingly responded to this IR using the updated proposed energy-based rate of \$0.39
12 per kWh. Further, to respond to this IR, FBC used the charge curves and usable battery capacity²
13 information publicly available from the EV-Database (<https://ev-database.org/>) for the three EV
14 models identified by the BCUC.

- 15 • 2019 Nissan Leaf: <https://ev-database.org/car/1106/Nissan-Leaf#charge-table>
- 16 • 2019 Kia Soul: <https://ev-database.org/car/1749/Kia-e-Soul-64-kWh>
- 17 • 2022 Audi Q4 E-Tron: <https://ev-database.org/car/1527/Audi-Q4-e-tron-45-quattro>

18 FBC applied the same methodology for the analysis of all three EV models. FBC notes that the
19 calculations reflect the charging conditions when the charge curves of these EV models were
20 developed by EV-Database. The charge curves developed by EV-Database do not reflect all
21 charging conditions, as factors such as the weather, charger configurations, and battery health
22 can all impact charging speeds in certain circumstances. Therefore, the real life experience for
23 the three EV models at FBC's DCFC stations may be different than the analysis shown below.

24 The analysis provided below shows how energy-based rates will address the disadvantage that
25 time-based rates create for vehicles with a charging rate that is slower than the station charging
26 rate, such as in the Nissan Leaf. While EV's with faster charging rates, such as the 2022 Audi Q4
27 E-Tron, will pay slightly more than under time-based rates, this is reasonable as these vehicles
28 can take advantage of the full charging rate of the station and will be paying for the electricity they
29 receive. Overall, none of the bill impacts are expected to be greater than 50 percent.

30 FBC provides the detailed analysis below for the three EV models identified.

¹ <https://www2.gov.bc.ca/gov/content/industry/electricity-alternative-energy/transportation-energies/renewable-low-carbon-fuels>


² According to EV-Database, the usable battery capacity is estimated based on average energy consumption and range under moderate drive style and climate. Real-life values may differ significantly.

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 5

1 **2019 Nissan Leaf**

2 Figure 1 below shows the charge curve of a 2019 Nissan Leaf at a 50 kW DCFC station from EV-
 3 Database. According to the publicly available information, the useable capacity for a 2019 Nissan
 4 Leaf is 39 kWh.

5 **Figure 1: Charge Curve of 2019 Nissan Leaf at 50 kW DCFC Station**



6
 7 Based on the charge curves shown above and the usable battery capacity of 39 kWh, Table 1
 8 below provides the calculation for the electricity dispensed and time required to charge from a
 9 10 percent to a 90 percent State of Charge (SoC) in 5 percent increments. FBC notes that the
 10 amount of electricity dispensed to the 2019 Nissan Leaf would be the same for the 50 kW and
 11 100 kW DCFC stations since this EV model can only use the CHAdeMO connector and has a
 12 maximum charge rate below 50 kW.

1 **Table 1: Calculation for Electricity Dispensed and Charging Minutes Required from 10% SoC to**
 2 **90% SoC for 2019 Nissan Leaf at both 50 kW and 100 kW EV DCFC Stations**

EV DCFC Charger Power Level:		50	kW				
Usable Battery Capacity:		39	kWh				
	Charging	Charging	Electricity		Cumulative	Cumulative	
SoC (%)	Curves (kW)	Power (kW)	Dispensed	Time (min)	(kWh)	(min)	
(a)	(b)	(c) - See	(d) = Battery	(e) = (d) / (c)	(f)	(g)	
		Note 1	x 5%				
10%	40	40	2.0	2.9	2	3	
15%	42	42	2.0	2.8	4	6	
20%	43	43	2.0	2.7	6	8	
25%	43	43	2.0	2.7	8	11	
30%	43	43	2.0	2.7	10	14	
35%	44	44	2.0	2.7	12	17	
40%	44	44	2.0	2.7	14	19	
45%	45	45	2.0	2.6	16	22	
50%	45	45	2.0	2.6	18	24	
55%	45	45	2.0	2.6	20	27	
60%	45	45	2.0	2.6	21	30	
65%	40	40	2.0	2.9	23	33	
70%	33	33	2.0	3.5	25	36	
75%	30	30	2.0	3.9	27	40	
80%	26	26	2.0	4.5	29	44	
85%	22	22	2.0	5.3	31	50	
90%	20	20	2.0	5.9	33	56	

3

4 Notes to Table:

- 5 1) The charging power in kW in column (b) is estimated from the charge curves.
- 6 2) Charging power is limited by either the EV charge curves or the charging power of the EV
- 7 DCFC station, i.e., the lesser of the charge curve and maximum power level at the DCFC
- 8 station.
- 9

10 Table 2 below provides the requested information for the 2019 Nissan Leaf based on the

11 calculation from Table 1 above. The results of the analysis show:

- 12 • The owner of a 2019 Nissan Leaf (i.e., an EV with small battery capacity and a lower
- 13 charge rate) would only pay approximately \$0.39 more (+5 percent) under the proposed
- 14 energy-based rate if using FBC's 50 kW DCFC station for 30 minutes of charging, but
- 15 would save approximately \$8.01 (-49 percent) if using FBC's 100 kW DCFC station for the
- 16 same 30 minutes of charging.
- 17 • The owner of a 2019 Nissan leaf would benefit from FBC's proposed energy-based rate
- 18 as the owner would no longer be disincentivized from using the 100 kW station due to
- 19 cost. Although the car would not charge any faster at the 100 kW station, using the 100
- 20 kW station (e.g., if the 50 kW stations were already in use) would no longer be more costly

1 than using a 50 kW station. Under the time-based rates, the same owner would have to
 2 pay \$8.40 more if they used a 100 kW station. Thus, FBC’s proposed energy-based rate
 3 creates more charging options for the owner of small EVs such as the 2019 Nissan Leaf.


4 **Table 2: Scenario 1 – 2019 Nissan Leaf (40 kW DC Charging Acceptance Rate)**

Power Level (kW)	Charge Duration (min)	Total kWh Dispensed	Existing Time-Based Rate (cents/min)	Total Charging Bill (\$)	Proposed Energy-Based Rate (cents/kWh)	Total Charging Bill (\$)	Bill Impact (\$)	Bill Impact (%)
(A)	(B)	(C)	(D)	(E = B*D / 100)	(F)	(G = C*F / 100)	(H = G - E)	(I = H/E*100)
50	30	21	26	\$ 7.80	39	\$ 8.19	\$ 0.39	5%
100	30	21	54	\$ 16.20	39	\$ 8.19	\$ (8.01)	-49%

6 **2019 Kia Soul**

7 Figure 2 below shows the charge curves of a 2019 Kia Soul at a 50 kW and a 175/350 kW DCFC
 8 station from EV-Database. As shown by the charge curve for the 175/350 kW DCFC station (i.e.,
 9 the blue line), the maximum charging power that the 2019 Kia Soul can accept would be limited
 10 to a maximum of 75 kW due to the design of the vehicle. This charge curve (i.e., blue line) is also
 11 applicable for the purposes of calculating the dispensed electricity at a 100 kW DCFC station as
 12 the maximum charging power for the vehicle is less than the power level of the charging station.

13 **Figure 2: Charge Curves of 2019 Kia Soul**



1 Based on the charge curves shown above and the usable battery capacity of 64 kWh according
 2 to EV-Database, Table 3 and Table 4 below provide the calculations for the electricity dispensed
 3 and the time required to charge from a 10 percent to a 90 percent SoC in 5 percent increments
 4 for the 50 kW station and 100 kW station, respectively.

5 **Table 3: Calculation for Electricity Dispersed and Charging Minutes Required from 10% SoC to**
 6 **90% SoC for 2019 Kia Soul at 50 kW EV DCFC Station**

EV DCFC Charger Power Level:	50	kW					
Usable Battery Capacity:	64	kWh					

SoC (%)	Charging Curves (kW)	Charging Power (kW)	Electricity Dispersed (kWh)	Time (min)	Cumulative (kWh)	Cumulative (min)
(a)	(b) - See Note 1	(c) - See Note 2	(d) = 64 kWh x 5%	(e) = (d) / (c)	(f)	(g)
10%	40	40	3.2	4.8	3	5
15%	41	41	3.2	4.7	6	10
20%	42	42	3.2	4.6	10	14
25%	43	43	3.2	4.5	13	19
30%	43	43	3.2	4.4	16	23
35%	44	44	3.2	4.3	19	27
40%	45	45	3.2	4.3	22	32
45%	46	46	3.2	4.2	26	36
50%	47	47	3.2	4.1	29	40
55%	48	48	3.2	4.0	32	44
60%	48	48	3.2	4.0	35	48
65%	49	49	3.2	3.9	38	52
70%	50	50	3.2	3.8	42	56
75%	40	40	3.2	4.8	45	61
80%	25	25	3.2	7.7	48	68
85%	25	25	3.2	7.7	51	76
90%	25	25	3.2	7.7	54	84

7

8 Notes to Table:

- 9 1) The charging power in kW in column (b) is estimated from the charge curves.
- 10 2) Charging power is limited by either the EV charge curves or the charging power of the EV
 11 DCFC station, i.e., the lesser of the charge curve and maximum power level at the DCFC
 12 station.

1 **Table 4: Calculation for Electricity Dispensed and Charging Minutes Required from 10% SoC to**
 2 **90% SoC for 2019 Kia Soul at 100 kW EV DCFC Station**

EV DCFC Charger Power Level:	100	kW				
Usable Battery Capacity:	64	kWh				
SoC (%)	Charging Curves (kW)	Charging Power (kW)	Electricity Dispensed (kWh)	Time (min)	Cumulative (kWh)	Cumulative (min)
(a)	(b) - See Note 1	(c) - See Note 2	(d) = 64 kWh x 5%	(e) = (d) / (c)	(f)	(g)
10%	75	75	3.2	2.6	3	3
15%	74	74	3.2	2.6	6	5
20%	75	75	3.2	2.6	10	8
25%	75	75	3.2	2.6	13	10
30%	75	75	3.2	2.6	16	13
35%	75	75	3.2	2.6	19	15
40%	75	75	3.2	2.6	22	18
45%	70	70	3.2	2.7	26	21
50%	70	70	3.2	2.7	29	23
55%	57	57	3.2	3.4	32	27
60%	57	57	3.2	3.4	35	30
65%	57	57	3.2	3.4	38	34
70%	57	57	3.2	3.4	42	37
75%	40	40	3.2	4.8	45	42
80%	25	25	3.2	7.7	48	49
85%	25	25	3.2	7.7	51	57
90%	25	25	3.2	7.7	54	65

3
4 Notes to Table:

- 5 1) The charging power in kW in column (b) is estimated from the charge curves.
 6 2) Charging power is limited by either the EV charge curves or the charging power of the EV
 7 DCFC station, i.e., the lesser of the charge curve and maximum power level at the DCFC
 8 station.
 9

10 Table 5 below provides the requested information for the 2019 Kia Soul based on the calculations
 11 from Tables 3 and 4 above. The results show:

- 12 • The owner of a 2019 Kia Soul (i.e., an EV with a medium battery size and medium charge
 13 rate) would pay approximately \$0.78 more (+10 percent) under FBC's proposed energy-
 14 based rate if using FBC's 50 kW DCFC station, but would save approximately \$2.55 (-16
 15 percent) if using FBC's 100 kW DCFC station for the same 30 minutes of charging.
 16 • The owner of a 2019 Kia Soul would benefit from FBC's proposed energy-based rate as
 17 the owner would no longer be disincentivized from using the 100 kW station due to cost.
 18 Although the vehicle is unable to take full advantage of the higher 100 kW charging rate,
 19 using the 100 kW station (e.g., if the 50 kW stations were already in use) would no longer

1 be more costly than using a 50 kW station. Under the time-based rates, the same owner
 2 would have to pay \$8.40 more if they used a 100 kW station. Thus, FBC’s proposed
 3 energy-based rate creates more charging options for the owner of a medium EV such as
 4 the 2019 Kia Soul.

5 **Table 5: Scenario 2 - 2019 Kia Soul (77 kW DC Charging Acceptance Rate)**


Power Level (kW)	Charge Duration (min)	Total kWh Dispensed	Existing Time-Based Rate (cents/min)	Total Charging Bill (\$)	Proposed Energy-Based Rate (cents/kWh)	Total Charging Bill (\$)	Bill Impact (\$)	Bill Impact (%)
(A)	(B)	(C)	(D)	$(E = B * D / 100)$	(F)	$(G = C * F / 100)$	$(H = G - E)$	$(I = H / E * 100)$
50	30	22	26	\$ 7.80	39	\$ 8.58	\$ 0.78	10%
100	30	35	54	\$ 16.20	39	\$ 13.65	\$ (2.55)	-16%

7 **2022 Audi Q4 E-Tron**

8 Figure 3 below shows the charge curves of the 2022 Audi Q4 E-Tron at a 50 kW, 150 kW, and
 9 300 kW DCFC station from EV-Database. FBC notes that for the purpose of completing the
 10 analysis for its 100 kW stations, FBC used the charge curves of the 300 kW charger but would
 11 limit the maximum charging power to 100 kW. This means that based on the charge curve shown
 12 below, the charging power at a 100 kW DCFC station will remain flat at 100 kW from 10 percent
 13 SoC to approximately 50 percent SoC before the charging power begins to decline below 100
 14 kW.

1

Figure 3: Charge Curves of 2022 Audi Q4 E-Tron



2

3 Based on the charge curves shown above and the usable battery capacity of 77 kWh according
 4 to EV-Database, Table 6 and Table 7 below provide the calculations for the electricity dispensed
 5 and the time required to charge from a 10 percent to a 90 percent SoC in 5 percent increments
 6 for the 50 kW station and 100 kW station, respectively.

1 **Table 6: Calculation for Electricity Dispensed and Charging Minutes Required from 10% SoC to**
 2 **90% SoC for 2022 Audi Q4 E-Tron at 50 kW EV DCFC Station**

EV DCFC Charger Power Level:	50	kW				
Usable Battery Capacity:	77	kWh				
			Electricity			
SoC (%)	Charging Curves (kW)	Charging Power (kW)	Electricity Dispensed (kWh)	Time (min)	Cumulative (kWh)	Cumulative (min)
(a)	(b) - See Note 1	(c) - See Note 2	(d) = Battery x 5%	(e) = (d) / (c)	(f)	(g)
10%	45	45	3.9	5.1	4	5
15%	45	45	3.9	5.1	8	10
20%	46	46	3.9	5.1	12	15
25%	46	46	3.9	5.0	15	20
30%	46	46	3.9	5.0	19	25
35%	46	46	3.9	5.0	23	30
40%	47	47	3.9	5.0	27	35
45%	47	47	3.9	4.9	31	40
50%	47	47	3.9	4.9	35	45
55%	47	47	3.9	4.9	39	50
60%	48	48	3.9	4.8	42	55
65%	48	48	3.9	4.8	46	60
70%	48	48	3.9	4.8	50	64
75%	48	48	3.9	4.8	54	69
80%	49	49	3.9	4.7	58	74
85%	49	49	3.9	4.7	62	79
90%	40	40	3.9	5.8	65	84

3

4 **Notes to Table:**

- 5 1) The charging power in kW in column (b) is estimated from the charge curves.
- 6 2) Charging power is limited by either the EV charge curves or the charging power of the EV
- 7 DCFC station, i.e., the lesser of the charge curve and maximum power level at the DCFC
- 8 station.

1 **Table 7: Calculation for Electricity Dispensed and Charging Minutes Required from 10% SoC to**
 2 **90% SoC for 2022 Audi Q4 E-Tron at 100 kW EV DCFC Station**

EV DCFC Charger Power Level:	100	kW				
Usable Battery Capacity:	77	kWh				
SoC (%)	Charging Curves (kW)	Charging Power (kW)	Electricity Dispensed (kWh)	Time (min)	Cumulative (kWh)	Cumulative (min)
(a)	(b) - See Note 1	(c) - See Note 2	(d) = Battery x 5%	(e) = (d) / (c)	(f)	(g)
10%	175	100	3.9	2.3	4	2
15%	175	100	3.9	2.3	8	5
20%	175	100	3.9	2.3	12	7
25%	150	100	3.9	2.3	15	9
30%	130	100	3.9	2.3	19	12
35%	130	100	3.9	2.3	23	14
40%	115	100	3.9	2.3	27	16
45%	110	100	3.9	2.3	31	18
50%	100	100	3.9	2.3	35	21
55%	90	90	3.9	2.6	39	23
60%	80	80	3.9	2.9	42	26
65%	75	75	3.9	3.1	46	29
70%	70	70	3.9	3.3	50	33
75%	70	70	3.9	3.3	54	36
80%	70	70	3.9	3.3	58	39
85%	50	50	3.9	4.6	62	44
90%	40	40	3.9	5.8	65	50

3
4 **Notes to Table:**

- 5 1) The charging power in kW in column (b) is estimated from the charge curves.
- 6 2) Charging power is limited by either the EV charge curves or the charging power of the EV
 7 DCFC station, i.e., the lesser of the charge curve and maximum power level at the DCFC
 8 station.
- 9 3) The Audi E-Tron, and other vehicles capable of charging at rates of 100 kW or more, may
 10 not achieve the full charging rate shown in column (c) due to voltage or current limitations.

11
 12 Table 8 below provides the requested information for the 2022 Audi Q4 E-Tron based on the
 13 calculations from Tables 6 and 7 above. The results show:

- 14 • For both the 50 kW and 100 kW stations, the owner of a 2022 Audi Q4 E-Tron (i.e., an EV
 15 with a larger battery and faster charging rate) would experience a small increase in cost
 16 by approximately \$1.17 and \$1.74, respectively, for 30 minutes of charging if the rate is
 17 changed from the existing time-based to the proposed energy-based rate.

- 1 • This analysis shows that for a larger EV with a faster charging rate, the difference between
 2 the existing time-based rate and the proposed energy-based rate would be small.

3 **Table 8: Scenario 3 - 2022 Audi Q4 E-Tron (125 kW DC Charging Acceptance Rate)**

Power Level (kW)	Charge Duration (min)	Total kWh Dispensed	Existing Time-Based Rate (cents/min)	Total Charging Bill (\$)	Proposed Energy-Based Rate (cents/kWh)	Total Charging Bill (\$)	Bill Impact (\$)	Bill Impact (%)
(A)	(B)	(C)	(D)	(E = B*D / 100)	(F)	(G = C*F / 100)	(H = G - E)	(I = H/E*100)
50	30	23	26	\$ 7.80	39	\$ 8.97	\$ 1.17	15%
100	30	46	54	\$ 16.20	39	\$ 17.94	\$ 1.74	11%

4
 5 To summarize, as demonstrated in all three scenarios above, none of the bill impacts are
 6 expected to be greater than 50 percent. However, based on the three scenarios, FBC observes
 7 the following:

- 8 • The proposed change to a common energy-based rate will create more charging options
 9 for owners of small and medium battery capacity EVs, such as the 2019 Nissan Leaf and
 10 2019 Kia Soul. These vehicles will not be able to take advantage of the higher charging
 11 speed of the 100 kW stations, as these EVs are either limited by the charging speed of
 12 the CHAdeMO connector for the Nissan Leaf or limited by the max charging capacity of
 13 the battery for the Kia Soul. However, the owners can use either the 50 kW or the 100 kW
 14 stations, whichever are available, without paying a premium for the 100 kW stations and
 15 without having to wait for a 50 kW station to become available.
- 16 • For EVs with larger batteries and faster charging capabilities, such as the Audi Q4 E-Tron,
 17 the owners will pay slightly more under the proposed energy-based rate because these
 18 EV models can receive significantly more electricity during a 30-minute charging session
 19 when compared to smaller EV models. FBC considers the slightly higher cost to be
 20 reasonable because the owners of these EV models can take full advantage of the faster
 21 charging stations and will therefore be paying for the amount of electricity they receive.

22
 23

24
 25 2.2 If the bill impact of switching from time-based to energy-based rates is expected
 26 to be greater than 50 percent in any of the three scenarios provided in the
 27 preceding IR, please highlight the same and discuss whether FBC views any
 28 mitigation is necessary.

29
 30 **Response:**

31 Please refer to the response to BCUC IR1 2.1.

32

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 15

1 **3.0 Reference: ENERGY-BASED RATE AND RATE DESIGN**

2 **Exhibit B-1, Section 3.2.1.1, p. 19**

3 **Levelized Period**

4 On page 19 of the Application, FBC states:

5 FBC's RS [Rate Schedule] 96 EV charging rates were originally set on a levelized-
6 cost basis from 2018 to 2030 for the 50 kW stations (13 years) and from 2021 to
7 2030 for the 100 kW stations (10 years). The levelized costs were based on the
8 original planned installation schedule of all stations to be complete in 2021 with an
9 expected service life of 10 years for the DCFC stations.

10 On the same page, FBC also states that it is proposing to reset the rates for its EV DCFC
11 service starting in 2024 over a 10-year levelization period and adds that the proposed
12 energy-based rate is designed to fully recover the cost of service of FBC's EV DCFC
13 service since inception to 2033.

14 3.1 Please explain why FBC has opted to “reset” the levelized period for recovering
15 the forecast cost of service starting in 2024 and ending in 2033, considering that
16 the RS 96 time-based rates matched the original 10-year service life of FBC's EV
17 DCFC stations that would end in 2030.

18
19 **Response:**

20 FBC considered shortening the levelization period to seven years (i.e., 2024 to 2030) instead of
21 resetting the levelization period to 10 years; however, this approach would increase the rate to
22 \$0.61 per kWh. At \$0.61 per kWh, FBC's rate would be the highest of all DCFC charging stations
23 in BC; in particular, the rate would be approximately 79 percent higher than BC Hydro's proposed
24 energy-based rate of \$0.34 per kWh (which is set based on a 10-year period) and approximately
25 53 percent higher than Tesla's offering of \$0.40 per kWh during the peak hours according to their
26 Time-of-Use (TOU) rates.

27 If the energy-based rate for FBC's DCFC stations is set at \$0.61 per kWh, there would be
28 significant risk of reduced or no station utilization, as there are alternative offerings by other
29 service providers at much lower rates. This will result in an overall under-recovery and ultimately
30 lead to rate impacts for FBC's other customers, with stations being under-utilized or not utilized
31 at all.

32 Additionally, and as discussed on page 24 of the Application, FBC included the future costs of
33 like-for-like replacements of its stations at the end of the 10-year expected service life, based on
34 the costs of the EV chargers in today's dollars plus an annual escalation for inflation. Therefore,
35 the analysis period does not end at 2030 (i.e., FBC contemplates the stations will continue service
36 beyond the original 10 years), and the costs for future sustainment capital expenditures are
37 incorporated in the revised levelized rate calculation.

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 16

1 **4.0 Reference: ENERGY-BASED RATE AND RATE DESIGN**

2 **Exhibit B-1, Section 3.2.1.2, Table 3-2, pp. 19–21, Excel attachment**
3 **Appendix E-1 – 50 kW Cost of Service Model_Energy Based, Tab**
4 **“Volume_Rev_O&M”, Excel attachment Appendix E-2 – 100 kW Cost**
5 **of Service Model_Energy Based, Tab “Volume_Rev_O&M”**
6 **Total Annual Charging Minutes**

7 On page 19 of the Application, FBC states:

8 In order to develop the growth rates for FBC’s owned EV DCFC stations, FBC
9 engaged Dunsky Energy + Climate Advisors (Dunsky) to provide a forecast of light
10 duty EV sales in the FBC service area from 2023 to 2040 based on three growth
11 scenarios, i.e., low growth, medium growth, and high growth [...]

12 On page 20 of the Application, FBC provides Table 3-2 showing the rates for Dunsky’s
13 low, medium, and high growth scenarios for EV sales in the FBC service area. On pages
14 20 and 21 of the Application, FBC states:

15 In setting the energy-based rates from 2024 to 2033 as part of this Application,
16 FBC applied the medium scenario growth rates from Dunsky’s analysis to all of
17 FBC’s EV DCFC stations with a cap of maximum utilization at 54 percent at each
18 station. The maximum utilization of 54 percent is based on FBC’s estimates of
19 historical utilization on an hourly basis at its own EV DCFC stations [...]

20 In the “Volume_Rev_O&M” Tab of Appendix E-1 – 50 kW Cost of Service Model_Energy
21 Based and Appendix E-2 – 100 kW Cost of Service Model_Energy Based attached to
22 Exhibit B-1, FBC provides the forecast of Total Annual Charging Minutes for its 50 kW and
23 100 kW DCFC stations, respectively, for the levelized period.

24 4.1 Please explain how FBC calculated the forecast total annual charging minutes in
25 its cost of service models. As part of the response, please explain whether the
26 growth in the forecast total annual charging minutes in FBC’s cost of service
27 models should align with the medium growth scenario rates provided by Dunsky in
28 Table 3-2 of the Application, and if yes, please explain why it currently does not.

29
30 **Response:**

31 Concurrently with these IR responses, FBC has filed an Evidentiary Update to the Application
32 which updates FBC’s proposed energy-based rate from \$0.42 per kWh to \$0.39 per kWh. FBC’s
33 proposed change to the rate is primarily due to the updates to the BC Low Carbon Fuel Standard
34 (BC-LCFS) which became effective on January 1, 2024³, which changed the calculation related
35 to carbon credits. FBC has also updated the rate calculation to include actual data for the full year
36 of 2023 (the data included in the Application only included actuals up to November 2023). Please

³ <https://www2.gov.bc.ca/gov/content/industry/electricity-alternative-energy/transportation-energies/renewable-low-carbon-fuels>

1 refer to the response to BCUC IR1 6.1 for more details. FBC has responded to this IR based on
 2 the new proposed energy-based rate of \$0.39 per kWh from the Evidentiary Update, which
 3 includes actual charging minutes for the full year of 2023.

4 The forecast annual charging minutes shown in the “Volume_Rev_O&M” tab of Appendices E-1
 5 and E-2 of the Application are the aggregate of forecast charging minutes of each station. FBC
 6 applied the growth rates from the Dunskey medium growth scenario shown in Table 3-2 of the
 7 Application to each station individually. However, the growth rates for the forecast charging
 8 minutes in aggregate do not perfectly align with the growth rates from Dunskey’s medium scenario
 9 due to two factors:

- 10 (i) FBC applied a maximum utilization of 54 percent to each station, as discussed
 11 in Section 3.2.1.2 of the Application; and
- 12 (ii) FBC prorated the charging minutes of the Castlegar station because of the
 13 closure described in Section 2.2.1 of the Application.⁴

14 FBC provides two examples below which show how the growth rates from Dunskey’s medium
 15 scenario and the maximum station utilization of 54 percent were applied. Please refer to the
 16 response to BCUC IR1 4.2 which explains how FBC developed the maximum utilization of 54
 17 percent per station.

18 Table 1 below provides an example for a station with 10,000 charging minutes in 2023. Based on
 19 the growth rates of Dunskey’s medium scenario, the utilization of this example station will remain
 20 less than 54 percent throughout the next 10 years; thus, the station growth rates will remain
 21 aligned with the growth rates of Dunskey’s medium scenario.

22 **Table 1: Growth Rate for Station with Annual Charging Minutes Under 54 percent Utilization**

Line	Particular	Reference	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
1	Dunskey Medium Growth Rate	Table 3-2 of Application		0.47	0.39	0.36	0.38	0.37	0.35	0.32	0.28	0.25	0.22
2	Annual Charging Minutes at Station at Dunskey Growth Rate	Prior Yr x (1 + Line 1)	10,000	14,743	20,486	27,869	38,494	52,614	71,066	93,850	120,521	150,094	182,662
3	No. of Minutes at Max 54% Utilization	Line 5 x 54%	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824
4	Total Forecast Annual Charging	Minimum of Line 2 and 3	10,000	14,743	20,486	27,869	38,494	52,614	71,066	93,850	120,521	150,094	182,662
5	Total No. of Minutes Station Open to Public (24/7)	60 min x 24 hr x 365 days	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600
6	Station Utilization (%)	Line 4 / Line 5	2%	3%	4%	5%	7%	10%	14%	18%	23%	29%	35%
7	Station Growth Rate	Line 6, (Current Yr / Prior Yr) - 1		0.47	0.39	0.36	0.38	0.37	0.35	0.32	0.28	0.25	0.22

23

⁴ The Castlegar station was only in-service for 4 months in 2023; as such, the station utilization was prorated to 12 months based on the actual charging minutes from the 4 months in service before applying the growth rates for 2024. If applying the growth rate without prorating for the closure, the forecast for the Castlegar station would always be for 4 months only.

1 Table 2 below provides another example for a station with 50,000 charging minutes in 2023.
 2 Based on the growth rates of Dunsky’s medium scenario, the utilization of this example station
 3 will reach 54 percent by 2029; thus, the total number of charging minutes forecast for this example
 4 station will remain at 283,824 minutes from 2029 to 2033. Table 2 below shows that the growth
 5 rates of the station will align with Dunsky’s medium scenario up to 2028 only and there will be no
 6 growth in charging minutes at this station after 2029.

7 **Table 2: Growth Rate for Station with Annual Charging Minutes Reaching 54 percent Utilization**

Line	Particular	Reference	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
1	Dunsky Medium Growth Rate	Table 3-2 of Application		0.47	0.39	0.36	0.38	0.37	0.35	0.32	0.28	0.25	0.22
2	Annual Charging Minutes at Station at Dunsky Growth Rate	Prior Yr x (1 + Line 1)	50,000	73,714	102,432	139,343	192,470	263,071	355,329	469,252	602,605	750,471	913,309
3	No. of Minutes at Max 54% Utilization	Line 5 x 54%	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824
4	Total Forecast Annual Charging	Minimum of Line 2 and 3	50,000	73,714	102,432	139,343	192,470	263,071	283,824	283,824	283,824	283,824	283,824
5	Total No. of Minutes Station Open to Public (24/7)	60 min x 24 hr x 365 days	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600
6	Station Utilization (%)	Line 4 / Line 5	10%	14%	19%	27%	37%	50%	54%	54%	54%	54%	54%
7	Station Growth Rate	Line 6, (Current Yr / Prior Yr) -1		0.47	0.39	0.36	0.38	0.37	0.08	-	-	-	-

8
 9 FBC also provides Confidential Attachment 4.1 which shows the calculation of the forecast
 10 charging minutes per station using the growth rates of Dunsky’s medium scenario with the
 11 maximum utilization of 54 percent applied to each station individually.

12 FBC is filing Attachment 4.1 on a confidential basis and requests that it be held confidential by
 13 the BCUC in perpetuity, pursuant to Section 18 of the BCUC’s Rules of Practice and Procedure
 14 regarding confidential documents as set out in Order G-72-23. Confidential Attachment 4.1
 15 contains commercially sensitive and market competitive information regarding detailed
 16 performance and utilization of FBC’s EV DCFC service for each individual station which, if publicly
 17 disclosed, could potentially jeopardize the market competitiveness of FBC’s individual stations,
 18 which could result in higher costs for customers. FBC, therefore, requests that Attachment 4.1 be
 19 filed on a confidential basis in perpetuity and that it only be made available to interveners upon
 20 executing a Confidentiality Declaration and Undertaking form acceptable to the BCUC.

21
 22

23
 24 4.2 Please provide the basis for FBC’s assumption for the cap of maximum utilization
 25 of 54 percent at each charging station and briefly discuss how FBC’s “estimates of
 26 historical utilization on an hourly basis” were applied to arrive at this cap of
 27 maximum utilization. As part of the response, please explain how this cap of
 28 maximum utilization was applied by FBC in its cost of service models (i.e. in
 29 Appendix E-1 and Appendix E-2, as referenced above).

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 19

1

2 **Response:**

3 Although FBC's EV DCFC stations are open 24 hours throughout the year, the utilization of its
4 stations will remain limited during the overnight hours (i.e., between 11 pm to 6 am). Considering
5 the limited usage during the overnight hours, FBC assumes the maximum utilization that its EV
6 DCFC stations can reach is 54 percent.

7 The 54 percent of maximum utilization was developed based on the actual number of charging
8 events per hour over a 24-hour period at FBC's EV DCFC stations from 2018 to 2023. Table 1
9 below provides the calculation for the 54 percent maximum utilization per station. Please refer to
10 the response to BCUC IR1 4.1 for a demonstration of how the maximum utilization of 54 percent
11 was applied to the calculation of forecast charging minutes shown in the cost-of-service model
12 (i.e., Appendix E-1 and Appendix E-2).

13 The steps of calculating and the assumptions involved for the maximum utilization of 54 percent
14 are as follows:

15 1. Using the total number of actual charging events in each hour during a day divided by the
16 total number of charging events from 2018 to 2023, FBC developed the demand profile of
17 FBC's DCFC stations for charging at each hour over a 24-hour period. It can be seen from
18 Table 1 below that approximately 96.3 percent of charging at FBC's stations took place
19 between 6 am and 11 pm (i.e., sum of column c between 6 am and 11 pm) while only 3.7
20 percent of charging took place between 11 pm and 6 am. This demand profile reflects
21 FBC's expectation that the use of public charging stations during the overnight hours will
22 continue to be limited regardless of the growth in EV adoption. FBC notes that this demand
23 profile is only applicable to FBC's stations as it is based on the actual utilization pattern of
24 FBC's stations.

25 2. Based on a total of 1,440 minutes per day (i.e., 60 minutes x 24 hours per day), the number
26 of charging minutes at each station is estimated using the demand profile of charging at
27 each hour from Step 1.

28 3. Due to the time needed for the switch over between drivers, a charging station cannot be
29 used 100 percent of the time, even during peak hours. As most charging events at DCFC
30 stations complete in around 30 minutes, it is reasonable to assume there will be at least
31 one switch over within each hour. FBC assumes that only 80 percent of the hour (i.e.,
32 maximum 48 minutes) will be used for actual charging during the peak hours (i.e.,
33 electricity flowing in the EV and metered). This reflects the time needed for the existing
34 driver to end the charging event (either through the display panel or through the mobile
35 app or through the car), unplug and put the charging cable back in place and drive away,
36 as well as the time needed for the new driver to park, connect the charging cable, and
37 initiate the charging event. That is, it is reasonable to assume that it would take an average
38 of 6 minutes for the existing driver to end the charging event and drive away from the
39 parking spot at the station and also assumes it would take an average of 6 minutes for the

1 new driver to park their EV and initiate charging. This takes into account that drivers may
 2 not be ready to move their vehicles as soon as the charging is complete.

3 4. Based on the demand profile for charging in each hour, and assuming the maximum
 4 number of minutes that charging could realistically occur during the peak hours at each
 5 station is 48 minutes (or 80 percent of an hour), then the maximum usage of each hour in
 6 percentage over a 24-hour period can be calculated. Table 1 below shows that the
 7 average maximum usage for a day is approximately 54 percent.


8 **Table 1: Calculation for the Maximum Utilization of 54 percent per Station**

Hour	No. of Charging Event per Hour (Actual 2018 - 2023)	Demand of Charging at FBC's Stations per Hour	Charging Min per Hour based on Probability, Max at 48 Min	Total No. of Min per Hour	Maximum % of Usage per Hour
(a)	(b)	(c) = (b) / Total No. of Charging Event (43,165)	(d) = Smaller of (c) x 1,440 min and 48 min (80% of an hour)	(e)	(f) = (d) / (e)
0	336	0.8%	11	60	19%
1	227	0.5%	8	60	13%
2	186	0.4%	6	60	10%
3	132	0.3%	4	60	7%
4	87	0.2%	3	60	5%
5	192	0.4%	6	60	11%
6	500	1.2%	17	60	28%
7	1,033	2.4%	34	60	57%
8	1,881	4.4%	48	60	80%
9	2,648	6.1%	48	60	80%
10	3,240	7.5%	48	60	80%
11	3,683	8.5%	48	60	80%
12	3,884	9.0%	48	60	80%
13	3,810	8.8%	48	60	80%
14	3,780	8.8%	48	60	80%
15	3,731	8.6%	48	60	80%
16	3,429	7.9%	48	60	80%
17	3,037	7.0%	48	60	80%
18	2,391	5.5%	48	60	80%
19	1,778	4.1%	48	60	80%
20	1,323	3.1%	44	60	74%
21	814	1.9%	27	60	45%
22	605	1.4%	20	60	34%
23	438	1.0%	15	60	24%
Total	43,165	100%	772	1,440	54%

9
 10 Figure 1 below shows that using FBC's actual charging events per hour between 2018 and 2023,
 11 the peak hours are between 8 am and 7 pm. FBC assumes the maximum utilization possible
 12 during these hours would be 80 percent. That is, if the growth of the station reaches maximum

1 utilization with charging events constantly occurring during the peak hours, it will still require 10
 2 to 12 minutes for the switch between the existing driver and the new driver waiting to use the
 3 charging station. Overall, for a 24-hour period, the average usage is 54 percent.

4 **Figure 1: Maximum Hourly Utilization Capped at 80%**



5

6

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 22

1 **5.0 Reference: ENERGY-BASED RATE AND RATE DESIGN**

2 **Exhibit B-1, Section 3.2.1.3, pp. 21–22; FBC EV DCFC Service –**
3 **Detailed Assessment Report dated December 29, 2022 (BCUC Order**
4 **G-341-21 Compliance Filing), Section 3.2.1.4, p. 17; 2021 British**
5 **Columbia Hydro and Power Authority (BC Hydro) Public Electric**
6 **Vehicle Fast Charging Rate, Exhibit C20-4, pp. 10–14**
7 **Cost of Electricity Forecast**

8 On page 21 of the Application, FBC states:

9 [...] For the purpose of forecasting the dispensed electricity from 2024 to 2033 over
10 the 10-year levelized period, FBC assumed there is a direct correlation between
11 the number of charging minutes and dispensed electricity in kWh. [...]

12 For the purpose of forecasting the cost of electricity at FBC’s stations, which is
13 based on the metered electricity, FBC used the forecast of dispensed electricity
14 [...] and the regression of the actual ratio of monthly dispensed electricity over
15 metered electricity vs. the actual monthly station utilization [...] of each FBC owned
16 DCFC station from 2018 to 2023 [...]

17 On pages 10 to 14 of Exhibit C20-4 of the 2021 BC Hydro Public Electric Vehicle Fast
18 Charging Rate proceeding, Suncor Energy Services Inc. provided charging arcs for
19 different EVs that demonstrated that the charge speed in an EV decreases as it
20 approaches a full state of charge.

21 5.1 Please explain whether FBC has considered, with respect to its assumption of
22 correlation between the number of charging minutes and dispensed electricity in
23 kWh, that in general the charge speed decreases as the EV approaches full state
24 of charge.

25
26 **Response:**

27 FBC acknowledges that, in general, charge speed will decrease as the EV approaches a full state
28 of charge. FBC has anecdotally observed that most charging events at its public EV DCFC
29 stations end in 30 minutes or when the EV reaches 80 percent SoC, whichever comes first. FBC
30 believes most users are more inclined to end charging at 80 percent SoC instead of waiting for
31 the extra time required to reach full SoC at a much slower charge speed. This generally aligns
32 with the recommendation from most EV manufacturers and news media, as described in these
33 two sources:

- 34 • [https://www.electrifying.com/blog/knowledge-hub/why-giving-80percent-is-the-best-](https://www.electrifying.com/blog/knowledge-hub/why-giving-80percent-is-the-best-result-for-your-electric-car)
35 [result-for-your-electric-car.](https://www.electrifying.com/blog/knowledge-hub/why-giving-80percent-is-the-best-result-for-your-electric-car)
- 36 • [https://www.flo.com/en-ca/insights/ev-battery-charging-best-practices-the-20-80-rule-for-](https://www.flo.com/en-ca/insights/ev-battery-charging-best-practices-the-20-80-rule-for-batteries/#:~:text=Simply%2C%20the%2020%2D80%25,meant%20to%20improve%20battery%20life)
37 [batteries/#:~:text=Simply%2C%20the%2020%2D80%25,meant%20to%20improve%20b](https://www.flo.com/en-ca/insights/ev-battery-charging-best-practices-the-20-80-rule-for-batteries/#:~:text=Simply%2C%20the%2020%2D80%25,meant%20to%20improve%20battery%20life)
38 [attery%20life.](https://www.flo.com/en-ca/insights/ev-battery-charging-best-practices-the-20-80-rule-for-batteries/#:~:text=Simply%2C%20the%2020%2D80%25,meant%20to%20improve%20battery%20life)

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 23

1 Since FBC believes most charging takes place at less than 80 percent SoC, where the charge
2 speed of most EVs is more optimal, the impact of decreasing charge speed as the EV approaches
3 full SoC would be small.

4 FBC also notes that although the same growth rates from Dunskey's medium scenario were
5 applied to both the forecast of charging minutes and forecast of dispensed electricity in kWh, the
6 base charging minutes and dispensed electricity were based on actual historical data. This means
7 that actual trends and behaviour of EV owners at FBC's DCFC stations are embedded in the base
8 charging minutes and dispensed energy for the purpose of the forecast. As mentioned above,
9 FBC believes there would be limited charging (in both minutes and kWh) at a high SoC where the
10 charge speed of most EVs would be slowest. This trend would be reflected in the actuals which
11 FBC used for the purpose of the forecast, and as such, the impact due to slow charging speed to
12 reach 100 percent SoC in FBC's forecast would be small.

13
14

15

16 5.2 Please clarify how FBC applied the result of the regression of the ratio of monthly
17 dispensed electricity over metered electricity vs. the actual monthly station
18 utilization for each station from 2018 to 2023 to calculate the proposed energy-
19 based rate of \$0.42 per kWh.

20

21 **Response:**

22 For clarity, the dispensed electricity in kWh is the amount of electricity taken by EVs during
23 charging events while the metered electricity in kWh is the amount of electricity provided to the
24 DCFC stations, which includes electricity during stand-by, electronic equipment, fans, display
25 screen, telecommunication, etc. The metered electricity in kWh is used to determine the total cost
26 of electricity provided to DCFC stations under Rate Schedule (RS) 21.

27 The purpose of the regression formula in Figure 3-1 of the Application is to forecast the metered
28 electricity in kWh based on the forecast dispensed electricity such that the total electricity costs
29 under RS 21 (based on metered electricity) can be calculated. The regression was developed
30 using monthly actuals in charging minutes (which is used to calculate the utilization of each station
31 in percentage) as well as the actual monthly ratio of dispensed electricity over metered electricity
32 at each FBC DCFC station from 2018 to 2023. As explained on page 21 of the Application, the
33 ratio of dispensed electricity over metered electricity would change depending on the utilization
34 rate of each station. As the station is utilized more, dispensed electricity increases with reduced
35 stand-by electricity; therefore, the ratio of dispensed electricity over metered electricity increases
36 as utilization of the station increases.

37 As discussed in the response to BCUC IR1 4.1, FBC applied Dunskey's medium growth rates on
38 a station-by-station basis to forecast the annual charging minutes and dispensed electricity in
39 kWh. The regression formula shown in Figure 3-1 of the Application is used to estimate the

1 metered electricity based on the forecast charging minutes and the dispensed electricity in kWh.⁵
 2 To illustrate how the regression formula was applied to determine the metered electricity of each
 3 station, FBC provides working examples in Tables 1 and 2 below based on the same sample
 4 stations provided in the response to BCUC IR1 4.1.

5 **Table 1: Illustration of the Calculation for the Metered Electricity for Sample Station No. 1**

Line	Particular	Reference	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
1	Dunsky Medium Growth	Table 3-2 of Application		0.47	0.39	0.36	0.38	0.37	0.35	0.32	0.28	0.25	0.22
2	Annual Charging Minutes at Station at Dunsky	Prior Yr x (1 + Line 1)	10,000	14,743	20,486	27,869	38,494	52,614	71,066	93,850	120,521	150,094	182,662
3	No. of Minutes at Max 54% Utilization	Line 5 x 54%	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824
4	Total Forecast Annual Charging Minutes	Minimum of Line 2 and 3	10,000	14,743	20,486	27,869	38,494	52,614	71,066	93,850	120,521	150,094	182,662
5	Total No. of Minutes Station Open to Public	60 min x 24 hr x 365 days	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600
6	Station Utilization (%)	Line 4 / Line 5	2%	3%	4%	5%	7%	10%	14%	18%	23%	29%	35%
7	Station Growth Rate	Line 6, (Current Yr / Prior Yr) -1		0.47	0.39	0.36	0.38	0.37	0.35	0.32	0.28	0.25	0.22
8	Annual Dispensed Electricity (kWh)	Prior Yr x (1 + Line 7)	7,200	10,615	14,750	20,065	27,716	37,882	51,167	67,572	86,775	108,068	131,517
9	Ratio of Dispensed over Meter Electricity (kWh)	Regression Formula: 0.1768 x Ln(Line 6) + 1.2497, Max at 95%	55%	62%	68%	73%	79%	84%	90%	95%	95%	95%	95%
10	Metered Electricity (kWh)	Line 8 / Line 9	13,109	17,180	21,819	27,471	35,193	44,949	57,111	71,497	91,342	113,756	138,438

6
7 **Table 2: Illustration of the Calculation for the Metered Electricity for Sample Station No. 2**

Line	Particular	Reference	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
1	Dunsky Medium Growth Rate	Table 3-2 of Application		0.47	0.39	0.36	0.38	0.37	0.35	0.32	0.28	0.25	0.22
2	Annual Charging Minutes at Station at Dunsky Growth Rate	Prior Yr x (1 + Line 1)	50,000	73,714	102,432	139,343	192,470	263,071	355,329	469,252	602,605	750,471	913,309
3	No. of Minutes at Max 54% Utilization	Line 5 x 54%	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824	283,824
4	Total Forecast Annual Charging Minutes	Minimum of Line 2 and 3	50,000	73,714	102,432	139,343	192,470	263,071	283,824	283,824	283,824	283,824	283,824
5	Total No. of Minutes Station Open to Public (24/7)	60 min x 24 hr x 365 days	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600	525,600
6	Station Utilization (%)	Line 4 / Line 5	10%	14%	19%	27%	37%	50%	54%	54%	54%	54%	54%
7	Station Growth Rate	Line 6, (Current Yr / Prior Yr) -1		0.47	0.39	0.36	0.38	0.37	0.08	-	-	-	-
8	Annual Dispensed Electricity (kWh)	Prior Yr x (1 + Line 7)	31,440	46,352	64,409	87,619	121,025	165,419	178,469	178,469	178,469	178,469	178,469
9	Ratio of Dispensed over Meter Electricity (kWh)	Regression Formula: 0.1768 x Ln(Line 6) + 1.2497, Max at 95%	83%	90%	95%	95%	95%	95%	95%	95%	95%	95%	95%
10	Metered Electricity (kWh)	Line 8 / Line 9	37,708	51,364	67,799	92,230	127,395	174,126	187,862	187,862	187,862	187,862	187,862

8
9
10
11

⁵ Dispensed electricity cannot equal or exceed metered electricity as there will always be ancillary electricity consumption such as control panel, display screen, fans, telecommunication equipment, etc. FBC assumed that at maximum utilization of each station, the maximum ratio of dispensed electricity over metered electricity would be 5 percent, based on the actual monthly data shown in Figure 3-1 of the Application.

1 Further, on page 22 of the Application, FBC states:

2
 3 As part of the forecast cost of electricity under FBC’s commercial service RS 21,
 4 FBC included the approved 2024 rate increase of 6.74 percent and assumed a
 5 further annual rate increase of 4 percent starting from 2025 onward. [Emphasis
 6 added]

7 On page 17 of FBC’s BCUC Order G-341-21 Compliance Filing, FBC stated:

8 For the updated forecast of electricity costs from 2023 to 2032, FBC included the
 9 3.98 percent rate increase for 2023 (approved on a permanent basis by Order G-
 10 382-22), and assumed a further rate increase of 3.5 percent in 2024 with an annual
 11 increase of 2 percent starting from 2025 onward. [Emphasis added]

12 5.3 Please discuss why FBC has updated its cost of electricity forecast from an annual
 13 rate increase of 2 percent to 4 percent from 2025 onward.

14 5.3.1 Please re-calculate the proposed energy-based rate using an annual rate
 15 increase of 2 percent assumption.
 16

17 **Response:**

18 Concurrently with these IR responses, FBC has filed an Evidentiary Update to the Application
 19 which updates FBC’s proposed energy-based rate from \$0.42 per kWh to \$0.39 per kWh. FBC’s
 20 proposed change to the rate is primarily due to the updates to the BC Low Carbon Fuel Standard
 21 (BC-LCFS) effective January 1, 2024⁶, which changed the calculation related to carbon credits.
 22 However, FBC has also updated the rate calculation to include actual data for the full year of 2023
 23 (as the data included in the Application only included actuals up to November 2023). Please refer
 24 to the response to BCUC IR1 6.1 for more details. FBC has responded to this IR based on its
 25 updated proposed energy-based rate of \$0.39 per kWh.

26 FBC updated its cost of electricity forecast under RS 21 from 2025 onward to be more
 27 conservative and to better align with FBC’s most recently approved rate changes, as shown in
 28 Table 1 below.

29 **Table 1: Rate Changes from FBC Annual Reviews (2021 to 2024)**

	2021	2022	2023	2024
BCUC Order	G-42-21	G-374-21	G-382-22	G-340-23
Annual Approved Rate Increase (%)	4.36%	3.47%	3.98%	6.74%

30
 31 If FBC re-calculated the forecast cost of electricity based on an annual rate increase of two
 32 percent instead of four percent from 2025 onward, the proposed energy-based rate would
 33 decrease to \$0.36 per kWh (from the updated proposed rate of \$0.39 per kWh). As FBC assumed

⁶ <https://www2.gov.bc.ca/gov/content/industry/electricity-alternative-energy/transportation-energies/renewable-low-carbon-fuels>.



FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 26

1 a consistent annual rate increase applied to RS 21 and third-party utilities, a two percent increase
2 has also been used to re-calculate electricity costs from third-party utilities from 2025 onward.
3 However, FBC continues to believe that using a four percent annual rate increase for the cost of
4 electricity is more appropriate as it is more reflective of FBC's recent rate increases.

5

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 27

1 **6.0 Reference: ENERGY-BASED RATE AND RATE DESIGN**

2 **Exhibit B-1, Section 3.2.1.8, pp. 27, 28; 2021 FBC Rate Design and**
3 **Rates for EV DCFC Service (2021 FBC EV Rates proceeding), Exhibit**
4 **B-7, BCUC Information Request (IR) 9.4.1, 9.8**
5 **Carbon Credits**

6 On page 27 of the Application, in relation to carbon credits, FBC states:

7 [...] approved as part of the rates and rate design of the existing time-based rates
8 under Order G-341-21, an estimate of \$200 per credit was included for FBC's 50
9 kW and 100 kW stations which was close to the average market price in 2019 and
10 2020 when the time-based rates were developed.

11 In response to BCUC IR 9.4.1 and 9.8 of the 2021 FBC EV Rates proceeding, FBC
12 clarified that its estimate of \$200 per credit was based on the penalty that the fuel suppliers
13 were required to pay to become compliant under the Renewable and Low Carbon Fuel
14 Requirements Regulation (RLCFRR).

15 Further, on pages 27 and 28 of the Application, FBC states:

16 [...] the November 2023 update of the BC-LCFS [Low Carbon Fuel Standard]
17 Credit Market Data shows that the current market price (November 2023) is
18 \$496.83 per credit.

19 [...] based on the recent price of monetized carbon credits and the current BC-
20 LCFS Credit Market Data, the original assumption of \$200 per credit from the
21 Revised Application is no longer consistent with the current credit market.

22 6.1 Please explain why FBC changed its methodology in the Application for estimating
23 the price of carbon credits from applying the \$200 per credit penalty to referring to
24 the current market price of carbon credits.

25 6.1.1 Please re-calculate the proposed rate using penalty assumption at the
26 current penalty rate.

27
28 **Response:**

29 When FBC filed the Revised and Updated EV Application in September 2020 for time-based rates
30 (Revised EV Application), no carbon credits had been monetized at that time. Therefore, in order
31 to determine a value for the carbon credits on a forecast basis as part of the calculation of the
32 time-based rates, FBC assumed the price of the carbon credits would be equivalent to the \$200
33 per credit penalty set by the Renewable and Low Carbon Fuel Requirements Regulation
34 (RLCFRR) for non-compliance. From a strictly financial standpoint, this is the point at which a
35 company would be indifferent between purchasing a carbon credit or paying a penalty, all else
36 equal.

1 However, since the approval of FBC's time-based rates in 2021, FBC has been monetizing the
 2 carbon credits related to its EV charging service through the BC-LCFS at market prices which
 3 have been much higher than \$200 per credit. In fact, the market price of carbon credits was up to
 4 almost \$500 per credit by the end of December 2023.⁷ With the benefit of actual monetized values
 5 based on market prices, FBC updated its methodology for estimating the price of carbon credits
 6 as part of the calculation of the energy-based rate because FBC considers the market prices to
 7 be more representative of future monetization values.

8 As explained in the Evidentiary Update filed concurrently with these IR responses, FBC has
 9 reduced its proposed energy-based rate from \$0.42 per kWh to \$0.39 per kWh. The detailed
 10 explanation and calculations of the revised energy-based rate are provided in the Evidentiary
 11 Update. The primary reason for the proposed change to the energy-based rate is that as part of
 12 the BC-LCFS, the government of BC issued the *Low Carbon Fuels Act*, effective January 1, 2024,
 13 which replaced the *Greenhouse Gas Reduction (Renewable and Low Carbon Fuel Requirements)*
 14 *Act*.⁸ FBC also notes that as part of OIC 689/2022, the penalty for non-compliance was increased
 15 from \$200 per credit to \$600 per credit, effective January 1, 2023,⁹ which the BC Low Carbon
 16 Fuels (General) Regulation under the *Low Carbon Fuels Act* has maintained.¹⁰

17 Accordingly, FBC provides the following table which shows:

- 18 (i) the proposed updated energy-based rate of \$0.39 per kWh using FBC's proposed
 19 method for calculating the monetized value of the carbon credits (i.e., using the
 20 assumption that the market price will remain close to \$500 per credit until 2025 but will
 21 begin to decline at a rate of 10 percent per year starting in 2026);
- 22 (ii) the energy-based rate if FBC were to use the new penalty of \$600 per credit; and
- 23 (iii) the energy-based rate if FBC were to use the previous penalty of \$200 per credit.

24 **Table 1: Comparison of Rates Using Low Carbon Fuels Act and Penalty Amounts**

Carbon Credit Rate Scenario	Rate (\$/kWh)
Evidentiary Update (Updated Carbon Credit based on new Low Carbon Fuels Act)	0.39
Carbon Credit priced at \$600 per credit penalty (new Low Carbon Fuels Act)	0.00
Carbon Credit priced at \$200 per credit penalty (previous BC RLCFRR)	0.53

25
 26 Table 1 above shows that if FBC were to use the updated penalty of \$600 per credit as the
 27 assumption for the monetized value of the carbon credits for all years starting in 2024, FBC's EV
 28 DCFC service would be free. That is, the forecast value at \$600 per credit would be more than

⁷ BC Credit Market Data, January 2024 Update: <https://www2.gov.bc.ca/gov/content/industry/electricity-alternative-energy/transportation-energies/renewable-low-carbon-fuels/credits-market>.

⁸ <https://www2.gov.bc.ca/gov/content/industry/electricity-alternative-energy/transportation-energies/renewable-low-carbon-fuels>.

⁹ OIC 689/2022, https://www.bclaws.gov.bc.ca/civix/document/id/oic/arc_oic/0689_2022.

¹⁰ Section 28(2), https://www.bclaws.gov.bc.ca/civix/document/id/oic/oic_cur/0699_2023.



FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 29

1 enough to pay for the total cost-of-service of FBC's EV DCFC stations, and so there would be no
2 cost to EV customers to charge their vehicles.

3 Although the \$200 per credit penalty is no longer applicable (as the correct price for the penalty
4 is now \$600 per credit), FBC included the \$200 per credit penalty to show that, based on the old
5 penalty, the energy-based charging rate would be very high and would create the risk of having
6 no EV charging customers.

7 Ultimately, using the market price to forecast the value of the carbon credits is the most
8 representative of how the credits are actually valued and monetized. To further align with the
9 expectation of the future credit market, as described in Section 3.2.1.8 of the Application, FBC
10 conservatively assumed that the market price will remain close to \$500 per credit until 2025 but
11 will begin to decline at a rate of 10 percent per year starting in 2026 as part of the calculation for
12 the proposed energy-based rate. FBC considers this to be the most reasonable assumption of
13 how the carbon credits related to its EV DCFC service will be valued over the next 10 years.

14

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 30

1 **7.0 Reference: ENERGY-BASED RATE AND RATE DESIGN**

2 **Exhibit B-1, Section 3.2.1.4, p. 24; 2023 BC Hydro Public Electric**
3 **Vehicle Charging Service Rates, Exhibit B-5, BCUC IR 21.4**

4 **Adoption of North American Charging Standard (NACS) Connectors**

5 On page 24 of the Application, FBC states that given the expected 10-year service life of
6 EV chargers, it has included future like-for-like replacement costs at the end of the service
7 life of each charger which has been estimated based on the costs of EV chargers in
8 today's dollars escalated annually by inflation.

9 In response to BCUC IR 21.4 of the 2023 BC Hydro Public Electric Vehicle Charging
10 Service Rates proceeding, BC Hydro stated that along with other public EV charging
11 service providers it is planning to support the Tesla North American Charging Standard
12 (NACS) connectors in the near future.

13 7.1 Please clarify whether FBC is considering replacing its existing charging station
14 connectors with NACS connectors in the future.

15 7.1.1 If yes, please provide an estimate of the expected capital cost for
16 retrofitting connectors in FBC's existing charging stations, the impact on
17 FBC's forecast utilization of charging stations for the 10-year levelized
18 period, and the estimated impact on the proposed energy-based rate, if
19 FBC were to adopt NACS connectors.

20
21 **Response:**

22 At this time, vehicles equipped with NACS connectors (primarily Tesla at the time of preparing
23 these IR responses) are utilizing CHAdeMO or CCS adapters to charge at FBC-owned charging
24 stations. FBC expects all future NACS-equipped EVs will continue to be able to use CCS adapters
25 to connect to public charging stations.

26 Currently, FLO has indicated to FBC that they do not plan to support NACS connector retrofits for
27 the type of FLO chargers deployed by FBC to date. As such, FBC expects that NACS connectors
28 would be introduced at the time of DCFC station replacement, or when installing new charging
29 stations in the future. If retrofit becomes available, FBC will also consider it at that time.

30 FBC currently does not have a cost estimate for retrofitting or replacing stations with NACS
31 connectors. However, as discussed on page 24 of the Application, the proposed levelized energy-
32 based rate over a 10-year period includes an estimate of future capital expenditures as a proxy
33 for minor repairs or parts replacements as well as future like-for-like replacement costs when
34 individual stations reach the end of their expected service life. Both future capital assumptions
35 could be used toward expenditures needed to retrofit existing stations with NACS connectors or
36 replacing end-of-life stations with new stations with NACS connectors. As such, FBC's proposed
37 energy-based rate includes a certain level of future capital that could be used for NACS
38 connectors.



FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 31

1 With regard to new charging stations with NACS connectors (i.e., not replacements), as discussed
2 in Section 4.2 of the Application, FBC will continue with the approach directed by Order G-341-
3 21, which is that FBC will include the evaluation of additional stations as part of FBC's annual
4 review or revenue requirement proceedings. The evaluation will include an assessment of
5 whether the levelized rates under RS 96 need to be recalculated due to the new station(s).

6

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 32

1 **8.0 Reference: ENERGY-BASED RATE AND RATE DESIGN**

2 **Exhibit B-1, Section 3.3.2, p. 30; 2021 FBC EV Rates proceeding,**
3 **Exhibit B-7, BCUC IR 7.4**

4 **Power Levels**

5 On page 30 of the Application, FBC states that it is proposing a common energy-based
6 rate for its 50 kW and 100 kW stations rather than different rates for the different power
7 levels.

8 In response to BCUC IR 7.4 of the 2021 FBC EV Rates proceeding, FBC stated:

9 In its proposed form, RS 96 contains rates that are specific to 50 kW and 100 kW
10 stations. Should FBC install a standard station size that differs from these sizes,
11 FBC will apply to the BCUC to amend RS 96 to accommodate the new station
12 size(s).

13 8.1 Please discuss whether FBC views that RS 96 should allow for more flexibility in
14 the event that FBC owns or operates different power level EV charging stations in
15 the future. For example, should RS 96 be amended such that the proposed rate is
16 applicable to all fast charger power levels, or have rates for charging stations with
17 power level ranges such as less than 50 kW, between 50 kW and 100 kW and
18 more than 100 kW?

19
20 **Response:**

21 FBC does not consider it necessary to incorporate additional flexibility into the RS 96 design, as
22 FBC does not have plans to install additional charging stations at this time. As discussed in
23 Section 4.2 of the Application, FBC proposes to continue with the approach for new stations
24 directed by Order G-341-21, which is that FBC will include the evaluation of additional stations as
25 part of FBC's annual review or revenue requirement proceedings. The evaluation will include an
26 assessment of whether the levelized rate under RS 96 needs to be recalculated due to the new
27 station(s).

28

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 33

1 **9.0 Reference: IDLING CHARGE**

2 **Exhibit B-1, Section 1.2, p. 4, Section 2.3.3, pp. 14–15, Section 3.4, p.**
3 **33**

4 **Implementation of the Proposed Idling Charge**

5 On page 14 of the Application, FBC notes that most EV DCFC providers that are
6 transitioning to energy-based rates are also introducing an idling charge to discourage
7 unnecessary congestion at charging stations. On page 33 of the Application, FBC submits
8 its intention to introduce an idling charge (Idling Charge) of \$0.40 per minute after the end
9 of a charging session, with a 5-minute grace period.

10 9.1 Please provide the definition of “end of a charging session” that will be used in
11 FBC’s electric tariff.

12
13 **Response:**

14 FBC defines the end of a charging session as when electricity stops being delivered to the electric
15 vehicle by the FortisBC-owned DCFC station.

16
17

18
19 9.2 Please confirm, or otherwise explain, that FBC will apply the Idling Charge to all
20 FBC owned or operated fast charging stations (i.e. not only at select stations).

21
22 **Response:**

23 FBC confirms it intends to apply the Idling Charge to all FBC owned or operated fast charging
24 stations at all of its sites, at all times of day.

25
26

27
28 9.3 Please discuss how FBC will communicate the Idling Charge to its customers (i.e.
29 app notification, payment screen alert, and/or physical signage at charging sites).

30
31 **Response:**

32 FBC will communicate the Idling Charge on site at each charging location with appropriate
33 signage, online via the PlugShare tool, through FBC’s website (i.e., FortisBC.com), and will
34 collaborate with FLO to notify registered FLO members in the FBC electric service territory via
35 email.

36

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 34

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33

Further, on page 4 of the Application, FBC indicates that the implementation timeline for transitioning to the proposed energy-based rate will be approximately four weeks after receiving approval from the BCUC and temporary dispensation from Measurement Canada. On page 33 of the Application, FBC states:

Currently, FLO has indicated that their system is not capable of accommodating both an energy-based rate and a time-based Idling Charge. FLO has communicated to FBC that upgrading their system to accommodate an Idling Charge is part of their development plan but not expected to be implemented until late 2024.

9.4 Please clarify whether implementation of the Idling Charge is contingent on the approval of an energy-based rate, or whether FBC intends to implement the Idling Charge, if approved, regardless of the outcome of the energy-based rate.

Response:

Implementation of the Idling Charge is intended to be contingent on the approval and implementation of an energy-based rate.

9.5 Please confirm, or otherwise explain, that FBC will implement the energy-based rate ahead of the Idling Charge if FLO cannot accommodate both the energy-based rate and Idling Charge at the same time.

Response:

Confirmed. As FLO is currently able to accommodate energy-based rates, once FBC receives temporary dispensation from Measurement Canada and receives approval of its proposed energy-based rate from the BCUC, FBC will direct FLO to implement the approved energy-based rate, regardless of whether FLO can implement the Idling Charge at that time or not.

Once FLO has developed their system to accommodate idling charges, and if the Idling Charge is approved by the BCUC, FBC will direct FLO to implement the charge.

FortisBC Inc. (FBC or the Company) FBC Electric Vehicle (EV) Direct Current Fast Charge (DCFC) Energy-Based Rate Application (Application)	Submission Date: March 12, 2024
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 35

1 **10.0 Reference: IDLING CHARGE**

2 **Exhibit B-1, Section 1.1.1, p. 2**

3 **Revenue Recognition for the Proposed Idling Charge**

4 The proposed Idling Charge will generate incremental revenues for FBC. On page 2 of the
5 Application, FBC notes that in Decision and Order G-341-21, the BCUC approved the
6 inclusion of related revenues and expenses associated with the EV DCFC stations in
7 FBC's regulated accounts, with variances between annual forecast and actual
8 revenues/costs to be subject to flow-through treatment in FBC's revenue requirement.

9 10.1 Please explain whether FBC plans to recognize the additional revenues from the
10 Idling Charge as a flow-through in FBC's revenue requirements, or to include the
11 revenue as an offset to the cost of service model, or elsewhere.

12
13 **Response:**

14 FBC has not included any forecast revenue from the Idling Charge in the proposed energy-based
15 rate. The revenue from the Idling Charge will be captured as a flow-through in FBC's revenue
16 requirements. FBC notes that the purpose of the Idling Charge is to encourage EV customers to
17 exit the station once charged; it is not designed to be a revenue stream and ideally, there would
18 be no revenue recovered through the idling charge if all EV customers, as intended, exit the
19 station within 5 minutes of the end of their charging session. As such, FBC expects limited
20 revenue from the idling charge.

21

Attachment 4.1

REFER TO LIVE SPREADSHEET MODEL

Provided in electronic format only

FILED CONFIDENTIALLY