

Sarah Walsh Director, Regulatory Affairs

Gas Regulatory Affairs Correspondence Email: <u>gas.regulatory.affairs@fortisbc.com</u>

Electric Regulatory Affairs Correspondence Email: <u>electricity.regulatory.affairs@fortisbc.com</u> FortisBC 16705 Fraser Highway Surrey, B.C. V4N 0E8 Tel: (778) 578-3861 Cell: (604) 230-7874 Fax: (604) 576-7074 www.fortisbc.com

May 15, 2025

Residential Consumer Intervener Association 1130 W Pender Street Vancouver, B.C. V6E 4A4

Attention: Abdulrahman (Abdul) Abomazid,

Dear Abdul Abomazid:

Re: FortisBC Inc. (FBC)

2025 Cost of Service Allocation (COSA) and Revenue Rebalancing (Application)

Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 1

On February 14, 2025, FBC filed the Application referenced above. In accordance with the regulatory timetable established in BCUC Order G-60-25 for the review of the Application, FBC respectfully submits the attached response to RCIA IR No. 1.

If further information is required, please contact the undersigned.

Sincerely,

FORTISBC INC.

Original signed:

Sarah Walsh

Attachments

cc (email only): Commission Secretary Registered Interveners



3

1 CHAPTER 5: 2025 COSA STUDY METHODOLOGY AND RESULTS

2 **1.0 Reference Exhibit B-1, Page 17**

5.2.2.2 Distribution Rate Base

4 **FBC states:** "For the classification of distribution plant, a minimum system study (MSS) 5 was performed to determine the split between customer- and demand-related costs. A 6 similar approach was taken in the 2017 COSA. The MSS assumes a certain size of the 7 distribution plant such as the number of poles, conductions, and transformers is required 8 to serve the minimum load requirements of customers, thus the costs associated with such 9 minimum system are dependent on the number of customers, i.e., customer-related 10 regardless of their level of load demand. The remaining costs of the distribution plant are then classified as demand-related since any cost associated with the distribution plant 11 12 beyond the minimum system requirement is considered to be due to the customers' level 13 of load demand being greater than the level that a minimum system can serve."

- 14 1.1 Have there been any changes to the assumptions that form the basis of the
 15 methodology used to determine the minimum system study in the current COSA
 16 compared to the previous one? If so, provide a clear explanation of each change
 17 and its justification.
- 18

19 Response:

20 The following response has been provided by EES Consulting and FBC:

21 No, there have not been any changes to the methodology for the Minimum System Study. 22 However, as described in the response to BCUC IR1 6.1, FBC inadvertently excluded neutral 23 conductors from the line length data provided to EES Consulting as part of the 2025 MSS analysis. 24 The impact of correcting for this error (i.e., including the neutral conductors) is that the customer-25 related portion of conductor costs decreases from 71 percent to 65 percent. As a result of this 26 and a few other changes to the COSA model inputs, FBC has filed an updated COSA model and 27 Updated Application concurrently with these IR responses. Please refer to the cover letter to the 28 Updated Application for further details of the changes.

- 29
- 30
- 31
- 32 33
- 34
- 1.2 Are the "minimum load requirements" applied in this study identical to those used in previous COSA study? If not, specify exactly what has changed and provide reasoning for each difference.
- 35



1 Response:

2 The following response has been provided by EES Consulting:

There has been no change from the previous COSA study. The approach takes a minimum system rather than a minimum load approach. The minimum system is the smallest or lowest price equipment purchased to deliver one kWh to the end point service compared to the as-built system.

- 7
- 8
- 9
- 101.3What specific minimum household energy consumption level is assumed in the
current COSA? Include the numerical value(s) used and the rationale behind this
assumption.12assumption.
- 13 14 **Response:**

15 The following response has been provided by EES Consulting:

16 The minimum system equipment includes a 15 kVa transformer, a 40-foot pole, and No. 2 17 aluminum conductor steel reinforced (ACSR). The minimum household consumption is 1 kWh (or 18 less) and the likely maximum would be less than 15 kVA peak demand. This configuration is 19 appropriate because it is typical of the minimum sized equipment that would be installed for the 20 smallest service.

- 21
- 22
- 22
- 241.4Describe how the current assumptions about minimum load requirements take into25account each of the following factors:
- Time-of-use rates
- Net metering
 - Demand side management programs
- 29

28

- Electric vehicle adoption (including the specific adoption assumptions used)
- 3031 <u>Response:</u>

32 The following response has been provided by EES Consulting:

Generally, with respect to an actual physical system, time-of-use rates and demand side management can be approaches to limit the need for over-sized service installations above the minimum system. However, net metering and electric vehicle adoption typically require larger than minimum system equipment to provide adequate service. Typically, these are not factors that feed



FortisBC Inc. (FBC or the Company)	Submission Date:
2025 COSA and Revenue Rebalancing (Application)	May 15, 2025
Response to RCIA Information Request (IR) No. 1	Page 3

- 1 into a minimum system analysis as they are generally retail rate and after-the-system-is-built
- 2 optimization considerations as opposed to the theoretical construction of a minimum system
- 3 necessary to deliver one kWh to an end-point service. Please also refer to the response to RCIA

4 IR1 1.2.



2.0

1 Appendix A – EES CONSULTING COSA REPORT

2 3

Reference Exhibit B-1, Page 19

3.4.3 Peak Load Carrying Capability Adjustment (PLCC)

4 FBC states: "While the minimum system is, in theory, designed to carry only a minimal 5 amount of load, the actual facilities chosen as the minimal size can carry some amount of 6 demand, therefore the minimum system without adjustment, overstates the customer-7 related component. The actual amount of demand capability within the minimum system 8 is a function of load density, minimum required clearances, minimum equipment 9 standards, temperature, and other engineering considerations. Under traditional cost allocation techniques, each customer/connection attracts an equal allocation of the 10 minimum system, plus demand costs allocate based on the total customer class's non-11 coincident peaks. As such, it has been argued that a customer class's non-coincident 12 13 demand allocator is too large, because a portion of these peak demand-related costs are 14 being covered through the per customer/connection minimum system allocation.

- 15 The correction of the problem of over-allocation demand can be achieved by the 16 application of a PLCC adjustment. The precise amount of a PLCC adjustment should 17 match the definition of the minimum system adopted. In the FortisBC case, it was 18 determined that the average PLCC for the FortisBC system is 0.97 kW per customer. This 19 update reflects the same PLCC adjustment methodology as previous studies"
- 20 2.1 On what basis was the PLCC adjustment left unchanged in the current COSA
 21 study? Please provide an explanation for why no update was made, including any
 22 rationale supporting this decision.

2324 **Response**:

25 The following response has been provided by EES Consulting:

The PLCC adjustment methodology did not change from 2017 since the underlying MSS methodology also remained the same. However, since the inputs into the PLCC model changed in number and costs between the 2017 and 2025 studies, the result changed from 1.09 to 0.97, with both values close to 1.0.

- 30
- 31
- 32
- 2.2 Provide an explanation of how the PLCC adjustment is expected to be affected by
 each of the following factors. If no impact is expected, explain the reasoning behind
 that conclusion:
- Time-of-use rates
- Net metering



IS BC"	FortisBC Inc. (FBC or the Company) 2025 COSA and Revenue Rebalancing (Application)	Submission Date: May 15, 2025
10 10	Response to RCIA Information Request (IR) No. 1	Page 5

1	Demand-side management programs								
2 3 4	 Electric vehicle adoption, including the specific assumptions regarding adoption levels 								
5	Response:								
6	The following response has been provided by EES Consulting:								
7 8 9	The PLCC analysis includes measured demands on the system by feeder. These measured demands include whatever mix of factors caused those demands to be higher or lower, including the factors listed in the question, which are all present on the FBC system.								
10									
11 12 13	2.3 Could FBC provide a comparison of Peak Load Carrying Capability (PLCC) adjustments across different jurisdictions?								
14 15 16	2.3.1 What are the main factors or drivers that account for any observed differences in how PLCC is applied?								
17	Response:								
18	FBC does not have a jurisdictional comparison of PLCC factors.								
19 20 21 22	The main factor or driver for the PLCC adjustment is the actual demands on each feeder compared to the carrying capacity of each feeder, considering a reliability margin of 20 percent of peak kVA.								
_									



1 Appendix B – FBC Final COSA 2025 Model

- 2 3.0 Reference Exhibit B-1
- 3 "Load" worksheet

4 **FBC** presents the following:

Group Coincidence Factor	Residential	Small Con	nmercial	Large Comm Primary 30/32	Large Comm Transmission 31	Lighting	Intention	Wholesale Primary 40	Wholesale Transmission
Jan-22	43.63%	54.26%	67.73%	75.58%	97.55%	58,41%	38.175	96.33%	91,205
Feb-22	38.60%	54.81%	68.91%	74,38%	96.43%	59.04%	38.14%	93,72%	97.525
Mar-22	33.52%	49.69%	64.67%	\$2,00%	96.86%	55.89%	27,94%	\$0,47%	95.585
Apr-22	28.89%	45.68%	60.83%	69.60%	95.85%	51.91%	32.80%	76.66%	86.57%
May-22	27.03%	43,49%	62.36%	76.97%	97.22%	55.35%	42.98%	91.60%	80.715
Jun-22	36.06%	51.04%	67.50%	74,84%	96.85%	62.29%	61 18%	92.45%	90.295
Jul-22	43.30%	58.42%	72.91%	80.56%	97.14%	63.59%	61.00%	100.00%	97.785
Aug-22	40.40%	56.07%	70.43%	83.23%	98.33%	63,70%	59.74%	84.65%	86.401
Sep-22	39.67%	57.29%	71.34%	\$3,04%	97.93%	56.30%	60.00%	99.06%	96.05%
Oct-22	28,20%	43.50%	62.73%	73,89%	96.99%	52.30%	37.58%	82.15%	74.095
Nov-22	38.14%	60.10%	80.23%	82.79%	92.14%	53,44%	39.91%	99.42%	43.335
Dec-22	46.42%	58.66%	69.04%	\$3,23%	97,24%	61.51%	36.92*	98.02%	99.195

- 3.1 What is the methodology used to derive the Group Coincidence Factors in the current COSA study?
- 7 8

5 6

9 **Response:**

10 The following response has been provided by EES Consulting:

11 The Group Coincidence Factor is the percentage of individual meters that peak at the same time.

12 It is determined by dividing the class peak by the sum of individual peaks, where the sum of

13 individual peaks is the aggregate total of the maximum values for each meter for the month

- 14 regardless of time, and the class peak is the maximum hourly value for the class (all meters added
- 15 at the same time).

16