



**Doug Slater**  
Director, Regulatory Affairs

**Gas Regulatory Affairs Correspondence**  
Email: [gas.regulatory.affairs@fortisbc.com](mailto:gas.regulatory.affairs@fortisbc.com)

**Electric Regulatory Affairs Correspondence**  
Email: [electricity.regulatory.affairs@fortisbc.com](mailto:electricity.regulatory.affairs@fortisbc.com)

**FortisBC**  
16705 Fraser Highway  
Surrey, B.C. V4N 0E8  
Tel: (778) 578-3874  
Cell: (778) 214-3842  
Fax: (604) 576-7074  
Email: [doug.slater@fortisbc.com](mailto:doug.slater@fortisbc.com)  
[www.fortisbc.com](http://www.fortisbc.com)

June 7, 2019

Commercial Energy Consumers Association of British Columbia  
c/o Owen Bird Law Corporation  
P.O. Box 49130  
Three Bentall Centre  
2900 – 595 Burrard Street  
Vancouver, BC  
V7X 1J5

Attention: Mr. Christopher P. Weafer

Dear Mr. Weafer:

**Re: FortisBC Energy Inc. (FEI)**

**Project No. 1598988**

**Application for a Certificate of Public Convenience and Necessity for the Inland Gas Upgrade Project (the Application)**

**Response to the Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2**

---

On December 17, 2018, FEI filed the Application referenced above. In accordance with British Columbia Utilities Commission Order G-79-19 setting out a further Regulatory Timetable for the review of the Application, FEI respectfully submits the attached response to CEC IR No. 2.

If further information is required, please contact the undersigned.

Sincerely,

**FORTISBC ENERGY INC.**

***Original signed:***

Doug Slater

Attachments

cc (email only): Commission Secretary  
Registered Parties

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 1

1 **34. Reference: Exhibit B 5, CEC 1.1.3 and 1.3.2 and 1.3.4**

As such, FEI's approach to system-wide corrosion monitoring for its pipelines is as follows. Taken as a whole, this approach addresses all FEI pipelines.

Asset Class	Diameter Range (NPS)	System-Wide Corrosion Monitoring Approach
Transmission pipelines operating at greater than or equal to 30% SMYS	6 and greater	In-line inspection
Transmission pipelines operating at greater than or equal to 30% SMYS	Less than 6	Modified ECDA; however, FEI will continue to monitor technology available for mitigating the potential for rupture failure on these lines
Pipelines operating at less than 30% SMYS	Any	Integrity-related activities such as CP Surveillance, visual observation any time the pipeline may be exposed during its lifecycle, and leak detection are performed. A significant condition monitoring program (such as a regular in-line inspection program) or mitigation (replacement, reconditioning, or abandonment) is only planned upon an occurrence of a relevant leak history.

1.3.2 If yes, please identify the areas in which FEI expects to see similar concerns.

**Response:**

Please refer to the response to CEC IR 1.1.3. FEI has identified external corrosion as a potential hazard to its entire buried steel pipeline system. Please also refer to BCUC IR 1.4.1 for FEI's assessment of the potential for active corrosion on cathodically protected pipelines in its system.

2

1.3.4 If FEI is expecting to experience similar issues in significant portions of its remaining transmission pipelines, is the current CPCN application part of a larger overall project that is not yet before the Commission? Please explain.

**Response:**

No, this Application is not part of a larger overall project that is not yet before the BCUC. Please refer to the responses to CEC IRs 1.1.2 and 1.1.3. It is possible in the future, however, that FEI may prioritize investment for providing ILI capability or other integrity management solutions for transmission pipelines operating at 30 percent SMYS or greater that are less than NPS 6 if the appropriate technology were to become proven and commercialized and industry standard practice were to include these smaller diameter pipelines.

3

4

34.1 Please provide the number of pipelines lower than NP6 and operating at greater than 30% SMYS.

5



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 2

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34

**Response:**

FEI has 71 pipelines smaller than NPS 6 and operating at greater than 30 percent of SMYS, as listed in the response to BCUC IR 1.8.2, Table 5.

34.2 What, if any, technologies has FEI identified to date that are expected to be available for pipelines smaller than 6 NPS in the future, if any?

**Response:**

At this time, FEI has not identified any proven and commercialized technology for external corrosion monitoring on pipelines smaller than NPS 6.

As stated in the response to BCOAPO IR 1.1.1, for laterals that are less than NPS 6 and above 30 percent of SMYS, FEI currently employs Modified ECDA and will continue to monitor available technology and industry practice for mitigating the potential for rupture due to corrosion. FEI considers this approach as appropriate considering the technology available and current industry practice.

34.3 Does FEI intend to introduce some form of in-line inspection or other technology in all its pipelines operating at greater than or equal to 30% SMYS, including NPS less than 6, when such technologies becomes available?

**Response:**

FEI intends to continue to monitor available technology and industry practice for mitigating the potential for rupture due to external corrosion. If proven and commercialized technology becomes available and adopted by industry, FEI would be obligated to evaluate the use of such technology to mitigate identified hazards to its pipeline system and would make a decision at that time whether to introduce the in-line inspection or other technology for its pipelines.





FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 4

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9

34.5.2 If yes, would FEI conduct the assessment itself or utilize specialized risk assessment professionals? Please explain.

**Response:**

Please refer to the response to CEC IR 2.34.4.

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 5

1   **35.   Reference: Exhibit B-5, CEC 1.3.2**

3.2   Please discuss the potential consequences of a rupture.

**Response:**

As discussed in Section 3.3.4 of the Application, a natural gas pipeline rupture has the potential to result in significant safety, reliability, environmental and regulatory consequences. The following discusses these consequences.

- **Safety Consequences:** As noted in Section 3.3.4 of the Application, if the gas ignites, there can be significant safety impacts beyond the immediate area surrounding the pipeline. An ignited release can result in potential harm due to the ensuing fire and resulting thermal effects on people and property. The following is an excerpt from a Gas Research Institute Report GRI-00/0189, A Model for Sizing High Consequence Areas Associated with Natural Gas Pipelines, 2001, prepared by C-FER Technologies:

“The rupture of a high-pressure natural gas pipeline can lead to outcomes that can pose a significant threat to people and property in the immediate vicinity of the failure location. The dominant hazard is thermal radiation from a sustained fire (...).”

2

3           35.1   What pressures are considered to be ‘high pressure’ pipelines?

4

5   **Response:**

6   The referenced report (GRI-00/0189) does not contain an explicit definition of “high pressure”;  
7   however, Table 3.1 “Summary of relevant North American pipeline failure incident reports”  
8   includes incidents ranging from 497 psi (approximately 3430 kPa) to 1207 psi (approximately  
9   8320 kPa). The operating pressures of the 29 Transmission Laterals fall within this range.

10




FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commerical Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 7

1 **37. Reference: Exhibit B-2, BCUC 1.14.3**

The graphs below expand on the information provided in the table in the response to BCUC IR 1.14.2, and separate out current firm customers' demand, forecasted growth in firm demand, industrial firm, and industrial interruptible (IT) in a stacked bar format that illustrates the cumulative demand. The information is grouped by lateral system. Note that in the lower pressure ranges in the capacity graphs below, the PRS capacity and the system capacity (without PRS) intersect and then at all lower pressures the PRS capacity and the system capacity follow the same declining capacity curve. The region of the graph where the two curves coincide indicates the operating conditions where the control valve would be fully open due to upstream pressures less than the set point (29.9 percent SMYS) of the PRS. In this operating area, the PRS is not limiting the capacity of the system. For the same reasons (because the control valve is fully open), any capacity upgrades that might be required to increase capacity to serve future increases in firm demand for tap pressures in this range would be no different in scale or scope with or without PRS and could not be addressed, for example, by removing the PRS.

**Mackenzie System:**



2  
3  
4

37.1 Please explain the causes of tap pressure changes.





FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 8

1 **Response:**

2 The tap pressure experienced at the tap location supplying any FEI lateral is primarily  
3 determined by the operation of the upstream transmission system. The upstream pipeline  
4 operator operates their pipeline under a range of conditions to meet delivery volume and  
5 delivery pressure requirements at all critical points and customer receipt locations along their  
6 pipeline system. This is achieved while also optimizing their delivery costs and meeting the  
7 operations and maintenance requirements on their own system. Tap pressures vary when there  
8 are changes in the upstream transmission system such as changes in customer demand on a  
9 daily or seasonal basis, whether upstream compressor stations are operating or not to maintain  
10 required pressures, and whether portions of the upstream system are undergoing inspection or  
11 maintenance. Tap pressures are expected to be variable, but under normal circumstances on a  
12 day-to-day or seasonal basis, they vary in a predictable way and in a narrower range than the  
13 maximum or minimum values indicated on the Demand and Capacity Graph in the preamble to  
14 this information request.

15  
16

17

18 37.2 Does FEI normally operate at maximum operating pressure on each lateral, or  
19 does that change from time to time? Please explain.

20

21 **Response:**

22 FEI may at times be at or near the maximum operating pressure of each lateral, but will most  
23 often be operating at pressures below the maximum operating pressure (and in some cases at  
24 the minimum contractual pressure). Please refer to the response to CEC IR 2.37.1 for an  
25 explanation of the causes for the changes in operating pressure.

26  
27

28

29 37.3 Does the stacked bar chart represent the maximum demand experienced by the  
30 transmission lateral, average value, or other value? Please clarify.

31

32 **Response:**

33 The stacked bar charts represent the maximum demand experienced by the transmission  
34 system and includes demand of customers forecast to be connected to the system in the  
35 forecast period (Firm Growth). In the MacKenzie System example above, the Firm Growth is



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 9

1 very small relative to the existing Firm and Industrial demands and is not clearly distinguishable  
2 in the chart.

3  
4

5

6 37.4 The CEC notes that in the Mackenzie system, the demand exceeds the system  
7 capacity line at all tap pressures below 5,600kPag. Does the Mackenzie system  
8 or other lateral ever operate below 5,600 kPag?

9

10 **Response:**

11 Yes. At times, the MacKenzie lateral will operate below 5600 kPag. The pressure in the system  
12 varies for reasons such as those outlined in the response to CEC IR 2.37.1. Other lateral  
13 systems may operate below 5600 kPag as well, but they operate independently of the  
14 MacKenzie System.

15

16

17

18 37.4.1 If yes, please comment on how the system capacity line exceeding the  
19 demand affects customer experience, if at all.

20

21 **Response:**

22 The system capacity line exceeding the demand indicates that the maximum demand of all  
23 customers can be met and that customers would experience no constraints on their ability to  
24 consume gas. Conversely, when the demand exceeds the system capacity line, this indicates  
25 not all customers can take their maximum demand. In this circumstance, the demand of  
26 customers with interruptible rate schedules may need to be managed to ensure their  
27 consumption added to the consumption of existing firm customers does not exceed the lateral  
28 system capacity. Under this system condition, interruptible customers may experience  
29 curtailment to achieve the required demand management.

30

31

32

33 37.5 Does FEI always operate at tap pressures which exceed its demand on the 29  
34 laterals? Please explain.

35

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 10

1 **Response:**

2 Tap pressures vary within a range. When the lateral system is served by an upstream  
3 transmission pipeline company, the tap pressure within that range may be determined by factors  
4 outside of the direct control of FEI as described in the response to CEC IR 2.37.1. FEI therefore  
5 ensures that each of the 29 Transmission Laterals has the capacity, even at a minimum tap  
6 pressure, to meet the forecast firm demand of its downstream customers. For lateral systems  
7 supplied by companies other than FEI, this minimum pressure will often be a contractual lower  
8 value that the upstream operator is obligated to meet or exceed. For lateral systems fed from  
9 FEI's Interior Transmission System, the minimum pressure is determined by the design  
10 constraints in place on that larger system. Should the firm demand forecasted exceed the  
11 lateral system's capacity (at the minimum tap pressure) at any point within the forecast, FEI will  
12 identify system capacity upgrades to be designed and installed before the demand exceeds the  
13 available capacity. This ensures FEI maintains, at all times, the capacity to meet the delivery  
14 requirements of all firm customers served by the system.

15  
16

17

18 37.6 The CEC would like to understand how often interruptible customers currently  
19 experience interruptions on the laterals and how this would change if PRS were  
20 implemented. For each transmission lateral in which the PRS option has been  
21 screened out due to capacity issues, please provide the historic demand by  
22 month for the last five years in graph format for each year.

23

24 **Response:**

25 The lateral systems where PRS was screened out due to capacity issues include the following:

- 26
- 27 • The MacKenzie System
    - 28 ○ MacKenzie Lateral 168
    - 29 ○ MacKenzie Loop 168
    - 30 ○ Feeds the downstream BC Forest Products Lateral 168
  - 31 • The Prince George 1 System
    - 32 ○ Prince George 1 Lateral 168
    - 33 ○ Feeds the downstream Prince George Pulp Lateral 168 and the Husky Oil Lateral 168

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 11

- 1       • The Kamloops 1 System
- 2             ○ Kamloops 1 Lateral 168
- 3             ○ Kamloops 1 Loop 168
- 4       • The Salmon Arm System
- 5             ○ Salmon Arm Loop 168
- 6             ○ Feeds the downstream Salmon Arm 3 Lateral 168
- 7       • The Cranbrook Kimberly System
- 8             ○ Cranbrook Lateral 168 and Cranbrook Loop 219
- 9             ○ Cranbrook Kimberley Loop 273
- 10            ○ Cranbrook Kimberley Loop 219 and Kimberley Lateral 168
- 11            ○ Skookumchuck Lateral 219
- 12       • The Fording System
- 13            ○ Fording Lateral 219
- 14            ○ Fording Lateral 168
- 15            ○ Feeds the downstream Elkview Lateral 168

16 The historic demand by month would not be helpful in understanding of the frequency of  
17 interruption or curtailment of interruptible capacity on a lateral as historical demand on these  
18 systems is more a function of the tap pressure and flows on a daily and even hourly basis. As  
19 FEI does not maintain records which provide the dates and durations of historic calls for  
20 curtailment of interruptible customers associated with insufficient capacity on the lateral, it  
21 cannot provide the requested historic demand by month identifying the date and duration of  
22 interruptions.

23 Of the six lateral systems identified, two systems, the Salmon Arm system and the Cranbrook  
24 Lateral 168 and Loop 219 in the Cranbrook Kimberly system, could not meet the current and  
25 forecasted firm demand on the system if a PRS was installed. Consequently, a PRS installation  
26 was excluded in these cases as it would not allow FEI to meet its firm demand obligations within  
27 the forecast period and is not related to service provided to interruptible customers. The  
28 impacts to interruptible customers on the remaining four laterals for the five years from January  
29 31, 2014 to December 31, 2018 is discussed in detail in the response to CEC IR 2.37.6.2.



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 12

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31

37.6.1 Please identify when interruptions were experienced and the duration of interruptions on the above graphs or other format if appropriate.

**Response:**

Please refer to the response to CEC IR 2.37.6.

37.6.2 Using an average of the last five years for demand, please plot the interruptions that would occur under a PRS option.

**Response:**

As described in the response to CEC IR 2.37.6, FEI does not have records that detail historical interruptions. To provide an understanding of the potential impact a PRS could have on the lateral systems identified in the response to CEC IR 2.37.6, FEI reviewed the tap pressure and Interruptible customer flow rates in the period between January 1, 2014 and December 31, 2018. Although there is no record of instances of curtailment, these lateral systems are actively managed to stay within the current available capacity. Therefore, the actual customer flows reviewed may already have been lower than typical in many instances due to curtailment that may have been in place.

The following provides a summary for each lateral system describing the change in the number or days these customers may be subject to curtailment using the pressures that were experienced over the 5 year history if the Firm customers served by the lateral system had been at peak demand and a PRS had been installed operating at 29.9 percent SMYS. As the potential for the Firm customers on the system to be at peak is only expected to occur during the months of November through the end of February, only the data for that period was included in the review. This summed to 601 winter days in that 5-year period.

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 13

1 **The MacKenzie System:**

PRs at MacKenzie Lateral System Tap	
<b>Nov 1 to Feb 28 2014-2018</b>	
Days with Curtailment Potential (tap pressure <5599 kPa)	566
Days with Curtailment Potential with PRS (all days)	601
Days with some Curtailment Potential with or without PRS but Potential is greater with PRS (tap pressure between 4110 and 5599 kPa)	472

2  
 3 Over this period there would be 566 days where curtailment potential would have existed had all  
 4 customers been at peak demand. With a PRS in place, all 601 days would have had  
 5 curtailment potential, 35 days more than without a PRS. Of the 566 days that had some  
 6 curtailment potential without PRS, 472 of those days would have required a greater degree of  
 7 curtailment with a PRS. Based on a review of the recorded tap pressure during this 5-year  
 8 period, there were 92 days when the tap pressure was below the PRS set point of 4110 kPa  
 9 and could require the same degree of curtailment with or without a PRS. Based on the  
 10 recorded industrial demand during the same 5 year period there were 2 days where the  
 11 interruptible customers would be curtailed to a greater degree with PRS (tap pressures were  
 12 between 4110 kPa and 5599 kPa and the measure industrial flow was higher than the current  
 13 lateral capacity, and much higher than the capacity with PRS) and an additional 5 days where  
 14 curtailment could have been required only because a PRS was in place (tap pressures were  
 15 >5599 kPa, where the current lateral has capacity for all customers peak demand, but the  
 16 measured industrial flow was higher than the capacity available with PRS). This analysis  
 17 confirms that the PRS alternative for this lateral would result in more curtailment to the  
 18 interruptible customers that are currently being served by the system. FEI did not consider the  
 19 PRS alternative as viable in any system where the peak demand of customers currently served  
 20 by the system could not be met within the forecast period to the same degree as that provided  
 21 by the lateral system without PRS. As a result PRS was not considered a viable option for the  
 22 MacKenzie Lateral.

23 **The Prince George 1 System:**

PRs at Prince George 1 Lateral 168 Tap	
<b>Nov 1 to Feb 28 2014-2018</b>	
Days with Curtailment Potential	601
Days with Curtailment Potential with PRS (all days)	601
Days with some Curtailment Potential with or without PRS but Potential is greater with PRS (tap pressure > 4110 kPa)	600

24  
 25 For the Prince George 1 Lateral, the Interruptible customers have curtailment potential for the  
 26 entire period with or without PRS, but would have had a greater degree of curtailment required  
 27 with a PRS for all but 1 of the 601 days. Reviewing the recorded tap pressure and industrial  
 28 flow during this 5 year period, there were 52 days when the tap pressure was below the PRS



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 14

1 set point of 4110 kPa and could require the same degree of curtailment with or without a PRS.  
2 There were 2 days based on recorded flows of interruptible customers where those customers  
3 would be curtailed to a greater degree with PRS (tap pressures were lower and the measured  
4 industrial flow was higher than the current lateral capacity, and much higher than the capacity  
5 with PRS) and an additional 41 days where curtailment could have been required only because  
6 a PRS was in place (the tap pressures were high enough that the current lateral had capacity  
7 for the measured industrial flow, but would not have had sufficient capacity with PRS). This  
8 analysis confirms that the PRS alternative for this lateral would result in more curtailment to the  
9 interruptible customers that are currently being served by the system. As a result PRS was not  
10 considered viable for the Prince George 1 Lateral.

11 ***The Kamloops 1 System:***

PRS at Kamloops 1 Tap	
<b>Nov 1 to Feb 28 2014-2018</b>	
Days with Curtailment Potential (tap pressure < 4257 kPa)	412
Days with Curtailment Potential with PRS (all days)	601
Days with some Curtailment Potential with or without PRS but Potential is greater with PRS (tap pressure between 4122 kPa and 4257 kPa)	0

12  
13 Over this period, there would be 412 days where curtailment potential existed had all customers  
14 been at peak demand. With a PRS in place, all 601 days would have had curtailment potential,  
15 189 days more than without a PRS. Based on a review of the recorded tap pressure and  
16 industrial flow during this 5-year period, there were 353 days when the tap pressure was below  
17 the PRS set point of 4122 kPa and could require the same degree of curtailment with or without  
18 a PRS. There were no days based on recorded flows of interruptible customers where those  
19 customers would be curtailed to a greater degree with a PRS. This is a result of one of the  
20 larger customers not operating at their full capacity in recent years. Although the current  
21 measured industrial flow may not have triggered additional curtailment with PRS in the 5-year  
22 period, their historical demand preceding this period would have. As a result, PRS was not  
23 considered viable for the Kamloops 1 Lateral as it could interfere with existing customers  
24 returning to historic consumption levels.

25 ***The Cranbrook Kimberley System:***

26 As discussed in the response to CEC IR 2.37.6 a PRS installed at the common tap to the  
27 Cranbrook Lateral 168 and Cranbrook Loop 219 does not provide sufficient capacity to serve  
28 Firm customers. As a result no additional review of impacts to interruptible capacity was  
29 conducted. The tap locations further downstream do not impact capacity to serve Firm  
30 customers, but do impact interruptible customers so the discussion for those laterals in the  
31 Cranbrook Kimberley system follows.



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 15

1 For the 3 locations that follow, the difference in curtailment potential with or without PRS is the  
2 same; however, the number of days in the third row of each table varies, because of the location  
3 of the PRS relative to the TCPL and the associated pressure drop between the tap and PRS  
4 under peak demand, and the differences in the set point of each PRS.

PRS at Cranbrook Kimberly Loop 273	
<b>Nov 1 to Feb 28 2014-2018</b>	
Days with Curtailment potential (TCPL tap pressure <5713 kPa)	593
Days with Curtailment Potential with PRS (all days)	601
Days with some Curtailment Potential with or without PRS but Potential is greater with PRS (TCPL tap pressure between 4874 and 5713 kPa)	151

5

PRS at Cranbrook Kimberly Loop 219/Lateral 168	
<b>Nov 1 to Feb 28 2014-2018</b>	
Days with Curtailment potential (TCPL tap pressure <5713 kPa)	593
Days with Curtailment Potential with PRS (all days)	601
Days with some Curtailment Potential with or without PRS but Potential is greater with PRS (TCPL tap pressure between 4549 kPa and 5713 kPa)	363

6

PRS at Skookumchuck Tap	
<b>Nov 1 to Feb 28 2014-2018</b>	
Days with Curtailment Potential (TCPL tap pressure <5713 kPa)	593
Days with Curtailment Potential with PRS (all days)	601
Days with some Curtailment Potential with or without PRS but Potential is greater with PRS (TCPL tap pressure between 5414 kPa and 5713 kPa)	5

7

8 Over this period there would be 593 days where curtailment potential existed had all customers  
9 been at peak demand. With a PRS in place, all 601 days would have had curtailment potential,  
10 8 days more than without a PRS. Of the 593 days that had some curtailment potential, without  
11 PRS between 5 and 363 of those days, dependent on location and station set point  
12 requirements, could have required a greater degree of curtailment required with a PRS. Based  
13 on a review of the recorded tap pressure and industrial flow during this 5-year period, were no  
14 days based on recorded flows where the interruptible customers would be curtailed to a greater  
15 degree with PRS. This is a result of one of the larger customers not operating at their full  
16 capacity within the November to February time period recent years. Although the current  
17 measured industrial flow of customers within the winter period may not have triggered  
18 curtailment additional curtailment with PRS in the 5-year period, their measure demand in other  
19 period of the year would have. As a result PRS was not considered viable for these Laterals as  
20 it could interfere with existing customers consumption should there peak demand coincide with  
21 the winter period.



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 16

1 ***The Fording Lateral System:***

PRS at Fording Lateral Tap	
<b>Nov 1 to Feb 28 2014-2018</b>	
Days with Curtailment Potential (TCPL tap pressure <5500 kPa)	473
Days with Curtailment Potential with PRS (all days)	601
Days with some Curtailment Potential with or without PRS but Potential is greater with PRS (TCPL tap pressure <5500 kPa)	473

2  
 3 Over this period, there would be 473 days where curtailment potential existed had all customers  
 4 been at peak demand. With a PRS in place, all 601 days would have had curtailment potential,  
 5 128 days more than without PRS. Of the 473 days that had some curtailment potential without  
 6 PRS, all 473 days could have required a much greater degree of curtailment required with PRS.  
 7 Based on a review of the recorded tap pressure and industrial flow during this 5-year period,  
 8 there were 465 days based on recorded flows of interruptible customers where those customers  
 9 would be curtailed to a greater degree with PRS (tap pressures were lower and the measured  
 10 industrial flow was higher than the current lateral capacity, and much higher than the capacity  
 11 with PRS) and an additional 125 days where curtailment could have been required only  
 12 because a PRS was in place (the tap pressures were high enough that the current lateral had  
 13 capacity for the measured industrial flow, but would not have had sufficient capacity with PRS).  
 14 This analysis confirms that the PRS alternative for this lateral would result in more curtailment to  
 15 the interruptible customers that are currently being served by the system. As a result, PRS was  
 16 not considered viable for the Fording Lateral.

17

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 17

1   **38.   Reference: Exhibit B-5, CEC 1.5.2**

5.2   What is causing the CP shielding on FEI's system? Please explain.

Response:

FEI believes that the quality of coating application and type of coatings applied in the past has resulted in observed coating disbondment, which has contributed to CP shielding on FEI's pipeline system. FEI has also found CP shielding due to the presence of rocks and foreign structures in the backfill adjacent to the pipeline, which can both damage the coating and/or prevent CP current from reaching the pipeline.

2

3           38.1   Does FEI undertake to pinpoint areas that its pipelines might be expected to  
4                    have CP shielding either because of the timing of the pipeline coating application,  
5                    the geographic characteristics of the terrain, or other circumstances that lead to  
6                    shielding?

7

8   Response:

9   No, in the absence of an in-line inspection program, it is not feasible to pinpoint areas in FEI's  
10 pipelines that may be experiencing cathodic protection (CP) shielding.

11 The situations where CP shielding can occur, such as where coating has disbonded or where  
12 rocks are near or in contact with the buried pipeline, may either be systemic or occur randomly  
13 along the length of a pipeline.

14 As demonstrated by the integrity dig data included in FEI's response to BCUC IR 1.4.1,  
15 evidence of CP shielding on FEI's transmission pipelines exists across a range of pipeline ages  
16 and coating types. As discussed in the Application, the indirect inspection surveys of an ECDA  
17 or Modified ECDA are not capable of detecting corrosion in areas where CP shielding occurs.

18

19

20

21                   38.1.1   If yes, please explain when and how often this effort is undertaken.

22

23   Response:

24 Please refer to the response to CEC 2.38.1.

25

26



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 18

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13

38.1.2 If yes, please comment on how FEI uses this information.

**Response:**

Please refer to the response to CEC 2.38.1.

38.1.3 If no, please explain why not.


**Response:**

Please refer to the response to CEC IR 2.38.1.

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 19

1    **39.    Reference: Exhibit B-5, CEC 1.10.1**

Figure 2: Interior Dig Locations (64 active and 12 passive corrosion sites)



2

3            39.1    Please explain the difference between passive corrosion and active corrosion.

4

5    **Response:**

6    The term passive corrosion is used to describe corrosion (e.g. rust) on a pipeline that, based on  
7    the observations of a qualified analyst during an integrity dig, is considered to have occurred at  
8    some time in the past and is no longer actively progressing. The term active corrosion is used  
9    to describe corrosion that is considered to be growing at the time of observation.

10   Factors that could contribute to active corrosion becoming passive include changes to  
11   groundwater conditions or improvements to a previously sub-optimally performing cathodic  
12   protection system.

13

14

15

16            39.2    Were any integrity digs conducted on the Fording Lateral?

17

18    **Response:**

19    Please refer to the response to BCUC IR 2.39.3.2.



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 20

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8

39.2.1 If no, please explain why not.

**Response:**

Please refer to the response to BCUC IR 2.39.3.2.

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 21

1   **40.   Reference: Exhibit B-5, CEC 1.18.1**

18.1   Is it FEI's contention that the transmission laterals are currently unsafe?

Response:

No, it is not FEI's contention that the 29 Transmission Laterals are currently unsafe. As part of its Integrity Management Program for Pipelines, FEI uses a number of available methods including, but not limited to, recurring operational activities such as leak survey and pipeline patrol as well as integrity monitoring through Modified ECDA to mitigate the risk of failure on the 29 Transmission Laterals. However, given the known limitations of these methods to detect external corrosion where there is cathodic protection shielding, the identified potential for pipeline rupture, the availability of mitigation solutions and, in particular, the common use of ILI for smaller diameter pipelines in the industry, FEI has concluded that steps should be taken to mitigate the potential for rupture due to external corrosion.

2

3           40.1    Could the project be safely deferred for a period of time such as 2 years, 5 years  
4                    or longer?

5

6   Response:

7   No. For FEI to be compliant with its legal and regulatory obligations, to be consistent with  
8   industry practice, and to address identified time-dependent risks to its pipeline system, the IGU  
9   Project could not be safely deferred for a period of time such as 2 years, 5 years or longer. FEI  
10   has proposed the IGU Project to proactively address the potential for rupture of the 29  
11   Transmission Laterals. FEI proposed the Project on the basis of:

12           1.   The 29 Transmission Laterals are subject to failure by rupture (refer to section 3.3.3 of  
13                the Application);

14           2.   Pipeline ruptures can result in significant consequences, including serious injuries or  
15                worse to employees or the public (CEC IR 1.3.2);

16           3.   Most transmission pipeline failures are due to external corrosion (section 3.3.1 of the  
17                Application and CEC IR 1.9.3);

18           4.   CP shielding is a known industry issue which can interfere with CP in preventing  
19                corrosion, and can also prevent detection of external corrosion (section 3.3.2 of the  
20                Application and CEC IR 1.6.3);

21           5.   Undetectable external corrosion (due to CP shielding) has previously been observed on  
22                FEI pipelines and FEI considers it probable that it is occurring throughout the 29  
23                Transmission Laterals (BCUC IR 1.4.1 and CEC 1.10.2); and



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 22

1           6. Corrosion is a time-dependent hazard; consequently, unreasonably delaying the ability  
2           to detect this hazard on the 29 Transmission Laterals will increase the likelihood of a  
3           pipeline rupture (BCUC IR 1.3.1).

4           Proven and commercialized in-line inspection technology exists for the mitigation of external  
5           corrosion on these pipelines, and alternative options are available to mitigate the consequences  
6           of failure where these have been demonstrated to provide more value (e.g. technically feasible,  
7           cost-effective compared to other alternatives).

8           Lastly, the IGU Project is necessary to maintain compliance with FEI's legal and regulatory  
9           obligations (CEC IR 1.18.2). As such, FEI has no basis upon which to determine a safe period  
10          of time for deferring the IGU Project.

11  
12

13  
14                   40.1.1    If yes, over what period of time could the project be safely deferred?  
15                                Please explain why.

16  
17           **Response:**

18           Please refer to the response to CEC IR 2.40.1.

19  
20

21  
22                   40.1.2    If no, please explain why not.

23  
24           **Response:**

25           Please refer to the response to CEC IR 2.40.1.

26  
27

28  
29           40.2    Please calculate the potential savings for deferring the capital expenditures for a  
30           period of 5 years.

31  
32           **Response:**



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 23

1 As stated in the response to CEC IR 2.40.1, for FEI to be compliant with its legal and regulatory  
2 obligations, to be consistent with industry practice, and to address identified time-dependent  
3 risks to its pipeline system, the IGU Project could not be safely deferred for a period of time  
4 such as 2 years, 5 years or longer.

5 When taking into account inflation of project costs and assuming no additional capital  
6 expenditures or other incremental costs in the near-term because of deferral of the project, FEI  
7 customers would experience some savings on a net present value (NPV) basis. This conclusion  
8 is based on the assumption that the discount rate in the NPV analysis is greater than the rate of  
9 project cost inflation. However, FEI has not conducted this financial analysis as it would be  
10 speculative and would not provide any benefit to address the underlying need of the IGU  
11 Project.



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 24

1   **41.   Reference: Exhibit B-5, CEC 1.23.3**

23.3   What are FEI's responsibilities to its interruptible customers, and how would this be impacted by reducing operating pressure?

Response:

As per its BCUC approved tariff, FEI is permitted to curtail or restrict gas supply to interruptible customers, for example, under colder weather conditions when core customers' demand increases. At the same time, interruptible customers expect FEI to provide a reasonable level of reliable service for the majority of the year. If these customers were curtailed or restricted too frequently, they would seek alternate fuels that they may view as more reliable and FEI could lose the customer and the load permanently.

PRS was not determined as a feasible solution for some laterals as the PRS would cause a reduction in capacity on those laterals and would result in a year round requirement for more frequent curtailment of customer loads such that FEI not would not be providing a reasonable level of reliable service. In some instances, a PRS would mean FEI could not meet supply needs for forecasted growth in the region served by those laterals. In those instances, PRS could not be done without also requiring a pipeline expansion to restore capacity on that lateral as it could no longer handle expected customer loads. Please refer to the customer impacts summarized in the response to CEC IR 1.23.1 for additional information.

2

3           41.1   Does FEI have a contracted threshold with its customers defining whether or not  
4                   it can restrict or curtail gas supply to interruptible customers? Please explain.

5

6   Response:

7   FEI's rate schedules offer different levels of service to its customers. FEI offers firm,  
8   interruptible, and a combination of firm and interruptible service. Most contracted industrial  
9   customers that are served directly off the FEI transmission system receive a combination of firm  
10   and interruptible service. Therefore, there is usually some amount of contracted firm capacity for  
11   these industrial customers.

12   FEI's obligation to interruptible customers is that if at anytime FEI, acting reasonably,  
13   determines there is insufficient capacity on the system to accommodate the customer's request  
14   for interruptible capacity, FEI may for any length of time, interrupt or curtail transportation  
15   service.

16   If interruptible customers perceived that they were not receiving a reasonable level of reliable  
17   service for the majority of the year, then they could switch some or all of their load to alternate  
18   fuels, or request firm service. If an interruptible customer switched its load to alternative fuels,  
19   other firm customers would no longer receive the benefits of interruptible revenue (i.e., reduced  
20   costs from the increased utilization of a pipeline that was generally designed for firm load under  
21   peak conditions). Similarly, if an interruptible customer switched to firm service, this may  
22   require FEI to invest in upgrades to its system to provide firm service.

23

24



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 25

1  
2           41.2   Please briefly elaborate on customers' expectation of a 'reasonable level of  
3                   reliable service for the majority of the year'.  
4

5    **Response:**

6    FEI's interpretation of its interruptible customers' expectation of a reasonable level of reliable  
7    service for the majority of the year is that they expect interruptions or restrictions to be limited to  
8    the amount of interruptible capacity available to them under peak weather conditions or during  
9    times of maintenance work.

10  
11

12  
13           41.3   What alternative fuels might the customers migrate to if they were curtailed or  
14                   restricted too often?  
15

16    **Response:**

17    Customers might consider alternative fuels such as coal, oil, wood/biomass, and electricity.  
18

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commerical Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 26

1 **42. Reference: Exhibit B-5, CEC 1.30.2**

30.2 Has the natural gas system had reliability issues in the affected laterals? Please explain and provide evidence of the reliability issues.

Response:

FEI has identified the following recorded incidents involving release of gas from its operating history of the 29 Transmission Laterals that may have impacted their reliability. Beyond what is provided in the table below, FEI has not located further details of the reliability impacts for these occurrences.

Year	Pipeline	Cause of Failure	Failure Type	Notes from Available Documents
1973	Fording Lateral 166Q19	Third party damage	Leak	A bulldozer hit the pipeline

2

Year	Pipeline	Cause of Failure	Failure Type	Notes from Available Documents
1976	Castlegar Nelson 166	Natural hazard	Leak (assumed)	Mud and rock slide damaged NPS 6 transmission line. "A line break 6" Inland Natural Gas line in the vicinity of Roson near Selkirk College occurred April 7. Will lose 150 customers at Robson and will lose Selkirk College, and feed Nelson by line pack supplemented by propane storage line."
1977	Castlegar Nelson 166	Third party damage	Leak	A grader hit the pipeline. The pipeline failure was repaired with a pigco high pressure sleeve and continued in operation at reduced pressure.
1982	Fording Lateral 166Q19	Third party damage	Leak	A road grader dug a hole into the NPS 6 pipeline buried on the road right-of-way. No one was injured. No damages. 6 to 7 feet of NPS 6 pipe was welded in and v-rayed.
1983	Prince George 1 Lateral 166	Third party damage	Rupture	Rupture of NPS 6 TP Lateral caused by caterpillar tractor. Tractor operator thrown clear by rupture. No fatalities.
1984	Castlegar Nelson 166	Natural hazard	Leak (assumed)	Mud slide hit the pipeline
1986	Kamboope 1 Loop 166	Human error	Leak	Faulty weld
1988	Trail Lateral 166	Human error	Leak	Back-hoe hit (hired by Inland Natural Gas)
1992	Salmon Arm Loop 166	Third party damage	Leak	BC Hydro auger punctured pipeline. Section of pipeline was cut-out
1996	Fording Lateral 166Q19	External corrosion	Leak	Leak detected during routine leak survey.

3

4 42.1 The CEC notes that leaks have not been identified since 1996. Please explain  
 5 what changes occurred that leaks have not been detected after this period.

6

7 **Response:**

8 Although FEI has not noted changes to its field operational practices that would have impacted  
 9 the occurrence or detection of corrosion leaks on the 29 Transmission Laterals, the absence of  
 10 leaks could be partially attributable to FEI's development and implementation of an Integrity  
 11 Management Program through the 2000s. These management systems, which incorporate a  
 12 plan-do-check-act cycle intended to promote continual improvement, have been adopted by  
 13 many industries with goals of improving asset performance and reducing failures.

14 To manage external corrosion on its non-piggable transmission pipelines, FEI was (i.e. in 1996  
 15 and before) applying cathodic protection (CP) and periodically monitoring CP systems to ensure



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 27


1 their proper function. FEI continues this practice. FEI has also continued to monitor for leaks  
2 on its transmission pipelines over this period.

3

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 28

1 **43. Reference: Exhibit B-2, BCUC 1.14.3**

**Fording System:**



2

The Fording Lateral System is comprised of the Fording Lateral 219 which is partly looped by the Fording Loop 114 from the tap location to a location south of the community of Sparwood. At the end of the Fording Lateral 219 north of Sparwood, the Fording Lateral 168 continues on northward past the community of Elkford to serve large industrial mine sites. The Fording system feeds Gate Stations serving the communities of Sparwood and Elkford and several large industrial sites located at various points along the length of the system. The large industrial customers (mostly mining sites) have large firm industrial and interruptible loads and are currently actively managed year round to keep the interruptible demand within the available capacity of the system. The capacity graph above shows that the installation of a PRS at the TransCanada Pipeline (TCPL) Tap to the system would severely diminish the capacity available for these existing large volume customers. As a result of a PRS impacting the established operations of existing FEI customers, PRS was considered not viable for the Fording Lateral 219 and Fording Lateral 168.

3

4 43.1 The CEC notes that the Fording Lateral System capacity just meets its load at

5 maximum operating pressure. Does FEI expect to increase the capacity of the

6 lateral within the next 10 years? Please explain why or why not.

7



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Inland Gas Upgrade (IGU) Project (the Application)	Submission Date: June 7, 2019
Response to Commercial Energy Consumers Association of British Columbia (CEC) Information Request (IR) No. 2	Page 29

1 **Response:**

2 FEI has no current plans to increase the capacity of the lateral within the next 10 years.

3 FEI is in discussions with a large industrial customer about their longer-term needs regarding  
4 natural gas use and the capacity of the Fording Lateral. The customer has not increased their  
5 firm contracted capacity; however, they continue to add load to the system and are currently  
6 relying on available interruptible capacity. Any upgrades to accommodate firm load increases for  
7 this customer if they were to occur, would likely involve loops of the existing pipeline at various  
8 locations for small portions of the total length of the pipeline and therefore would not impact ILLI  
9 being the preferred alternative for the Fording lateral system.

10

11

12

13 43.2 Please provide a discussion of FEI's obligation to serve interruptible customers.

14

15 **Response:**

16 Please refer to the response to CEC IR 2.41.1 for a discussion of FEI's obligation to serve  
17 interruptible customers.