

Diane Roy Vice President, Regulatory Affairs

Gas Regulatory Affairs Correspondence Email: gas.regulatory.affairs@fortisbc.com

Electric Regulatory Affairs Correspondence Email: <u>electricity.regulatory.affairs@fortisbc.com</u> FortisBC 16705 Fraser Highway Surrey, B.C. V4N 0E8 Tel: (604)576-7349 Cell: (604) 908-2790 Fax: (604) 576-7074 www.fortisbc.com

March 4, 2021

British Columbia Utilities Commission Suite 410, 900 Howe Street Vancouver, B.C. V6Z 2N3

Attention: Mr. Patrick Wruck, Commission Secretary

Dear Mr. Wruck:

Re: FortisBC Energy Inc. (FEI)

Project No. 1599152

Application for a Certificate of Public Convenience and Necessity for the Okanagan Capacity Upgrade (OCU) Project (Application)

Response to the British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1

On November 16, 2020, FEI filed the Application referenced above. In accordance with BCUC Order G-335-20 setting out the Regulatory Timetable for the review of the Application, FEI respectfully submits the attached response to BCUC IR No. 1.

If further information is required, please contact the undersigned.

Sincerely,

FORTISBC ENERGY INC.

Original signed:

Diane Roy

Attachments

cc (email only): Registered Parties



	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
TM .	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 1

1 **Table of Contents** Page no. 2 Α. 3 Β. 4 C. 5 D. Ε. 6 ENVIRONMENT AND ARCHEOLOGY127 7 F. 8 G. 9 Н.



1	Α.	PROJECT NE	ED AND JUSTIFICATION
2	1.0	Reference:	PROJECT NEED AND JUSTIFICATION
3			Exhibit B-1-2 (Updated Application), pp. 18, 28, 29
4			Impacts of COVID-19
5 6 7		On page 18 of capacity planr available custo	the Updated Application, FortisBC Energy Inc. (FEI) states, "FEI's system ning team refreshes its forecast annually, based on the most recently omer addition and consumption data."
8		On page 28 of	the Updated Application, FEI states:
9 10 11 12 13 14 15		FEI's p COVID the CC more acknov be sign presen	beak demand forecast was prepared in 2019, before the onset of the 19 pandemic. As of the date of filing, there is insufficient data to quantify VID-19 impact, to forecast its future impacts on energy consumption or, importantly for system planning, its impact on peak loads. FEI vledges that the immediate and near-term impacts of the pandemic may inficant for some types of customers and economic sectors. However, FEI tly has insufficient information to quantify these impacts.
16		On page 29 of	the Updated Application, FEI states:
17 18 19 20 21 22 23		In sum the pe signific short-te nature, [Interio Upgrac	mary, given the lack of firm information on COVID-19 related impacts on ak load in 2023/2024 and future years, the continuing potential for ant new loads in urban centres like Kelowna, the limitations of existing erm mitigation measures, and the lead time required for a project of this FEI concludes that it would not be prudent to delay the addition of ITS r Transmission System] capacity and that the OCU [Okanagan Capacity de] Project should proceed as set out in this Application.
24 25 26 27		1.1 Please availab this pro	discuss when FEI expects its 2020 peak demand forecast will be le, and whether FEI expects to file an updated demand forecast as part of oceeding.

28 **Response:**

FEI is not proposing to file an updated peak demand forecast as part of this proceeding. FEI is still developing, and has not yet completed, an updated peak demand forecast for the ITS, current as of 2020 and using the results of the 2020 account forecast. As such, FEI is unable to provide an updated 2020 peak demand forecast at this time.

Although FEI's 2020 customer account forecast is complete, the completion of the 2020 peak
 demand forecast and its impacts on the ITS lags the completion of the current account forecast
 by about 9-10 months as it relies on the development of the load in the models of the
 distribution system connected to the ITS that are built using the updated account forecast.



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 3

- Notwithstanding this, preliminary results indicate that the updated peak demand forecast will not 1 2 change the impending requirement for the OCU Project. The updated forecast will only provide 3 FEI with a more current assessment of the extent of short-term mitigation measures that were 4 described in the Updated Application and that will still be required from the winter of 2021-2022 5 until the Project is completed. 6 7
- 8
- 9
- 10
- 11
- 1.2 Please provide a detailed discussion of the work FEI is undertaking with respect to estimating the impact of the COVID-19 pandemic upon peak demand 12 forecasting, including any timelines for such work.
- 13

14 Response:

15 FEI still has insufficient data to quantify any potential impact of the COVID-19 pandemic on 16 peak demand forecasts. As discussed in Section 3.3.1.2 of Updated Application, FEI bases its 17 customer forecast method on forecasts from the Conference Board of Canada (CBOC) and the 18 BC Statistics 20-year household formation (HHF) forecast. FEI has not received updates to 19 these forecasts since the beginning of the pandemic. FEI has also continued to attach 20 customers in 2020 at rates comparable to 2019 which suggests that, so far, the pandemic has 21 not materially affected current growth rates. FEI will review and incorporate updated forecasts 22 from the CBOC and BC Statistics when they are received and apply these updates to the 23 forecasts prepared later in 2021.

24 Additionally, as described in FEI's peak demand forecasting methodology explained in Section 25 3.3.1 of the Updated Application, FEI dampens the effect of any one year's variation through a 26 process of averaging the results of the previous three years. Therefore, FEI expects that 27 UPC_{peak} will not materially increase or decrease in response to the pandemic. Any change in the 28 new peak demand forecast would be largely due to changes in the customer account forecast 29 driven by CBOC and HHF growth rates that have not yet been received.

- 30
- 31

FORTIS BC

2

3

4

	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
гм	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 4

1 2.0 Reference: PROJECT NEED AND JUSTIFICATION

Exhibit B-1-2, pp. 24, 25, 28

Minimum Inlet Pressure at Gate Stations

- On page 24 of the Updated Application, FEI states:
- 5 FEI designs the ITS to deliver a minimum inlet pressure of 2415 kPag (350 psig) 6 into the major gate stations serving downstream Intermediate Pressure (IP) 7 systems on a peak day. This minimum pressure is the parameter that defines the 8 ITS capacity limit. This minimum pressure is identified as the primary capacity 9 constraint for this region in order to maintain a 350 kPag (50 psig) working 10 pressure differential across Polson Gate Station and Kelowna #1 Gate Station 11 that supply IP systems that operate at 2070 kPag (300 psig), supplying 12 thousands of customers. This minimum delivery pressure ensures a reasonable 13 working pressure across the station always exists to accommodate effective 14 sizing and operation of the station regulators and other station equipment.
- 15 On page 25 of the Updated Application, FEI states:
- 16 These pressure-controlled regions are identified in Table 3-1 above, with the 17 segments most relevant to the OCU Project listed in rows 2 to 5. These portions 18 of the pipeline can provide a local constraint on capacity. The most significant 19 constraint on maintaining minimum pressure into the north and central Okanagan 20 is the pressure limitation to 5171 kPag (750 psig) between Ellis Creek Control 21 Station in Penticton and the SN9-3 Control Station south of Kelowna. The OCU 22 Project will address this constraint by providing the ability to supply gas into the 23 NPS 12 Savona to Penticton mainline at the maximum 5171 kPa at a point more 24 than 28 kilometres closer to the major load centres on the ITS in the Central 25 Okanagan.
- 26 On page 28 of the Updated Application, FEI states:
- 27 The first regions to experience a capacity shortfall would be the communities of 28 West Kelowna, Lavington, and Lumby (shown in Figures 3-9 and 3-10 above). 29 The systems in these communities are supplied by the Kelowna #1 Gate Station and the Polson Gate Station, which require inlet pressures sufficient to maintain 30 31 an adequate pressure differential between transmission inlet pressure and 32 discharge pressure. Due to their approximate midpoint location on the ITS 33 mainline, the inlets of both stations experience the lowest pressures experienced 34 on the ITS, and current forecasts indicate that the inlet pressures would be 35 insufficient to operate the stations in the case of extreme cold conditions during 36 the winter of 2023/2024. Customers served by the Kelowna #1 Intermediate 37 Pressure system currently number approximately 16,300 in West Kelowna and 38 the customers served by the Polson Intermediate Pressure system in Vernon 39 number over 2,000 in Lavington and Lumby.

FORTIS BC^{**}

- 2.1 Please explain if the minimum inlet pressure of 2415 kPag (350 psig) is uniform for all major gate stations on the ITS.
- 2 3

1

4

5

2.1.1 If not, please explain the factors that contribute to variations in minimum inlet pressure.

6 **Response:**

An inlet pressure of approximately 2420 kPa (350 psig)¹ is the minimum inlet pressure for gate
stations supplying intermediate pressure (IP) systems operating at 2070 kPa. The required inlet
pressure is related to the downstream operating pressure of the system the gate station is
supplying. Gate stations with lower operating pressure in the downstream system can have
lower inlet pressure requirements.

Allowing sufficient pressure differential across the regulating station (minimum inlet pressure minus downstream system operating pressure) provides flexibility during the station design to more-economically size equipment and the overall facility. This is because equipment sized for very low pressure differentials is typically larger and more costly, and otherwise presents constraints when designing new stations or upgrading existing stations. For this reason, FEI has identified 2420 kPa as the appropriate minimum pressure to preserve design flexibility for these stations.

19 The minimum inlet pressure requirements for the Kelowna #1 and Polson Gate Stations 20 supports a minimum 350 kPa (inlet = 2420 kPa to outlet = 2070 kPa) pressure differential 21 Between Savona and Penticton, in addition to the two gate stations across the station. 22 identified in the Updated Application, there are two additional gate stations in Kamloops, and 23 one additional gate station in Kelowna supplied from the ITS. These stations all serve 2070 kPa 24 IP systems and share the minimum inlet pressure of 2420 kPa. The majority of the remaining 25 gate stations on the ITS directly serve distribution systems that operate with lower operating pressure (420 kPa), and therefore can accommodate lower inlet pressures. 26

27 28 29 2.2 30 Please discuss whether there have been any instances in the past ten years where inlet pressure into the into the major gate stations on the ITS has been 31 below the minimum inlet pressure of 350 psig. 32 33 2.2.1 If so, please describe the circumstances causing such instances, and 34 the impacts upon the downstream system. 35 36 **Response:**

In the past ten years, FEI has not experienced inlet pressures below the minimum 350 psig at
 the inlet to the major gate stations on the ITS during periods of high system demand when this

¹ The 2415 kPa referenced in the Updated Application was an approximate conversion of 350 psig.



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 6

low pressure would cause a concern for maintaining supply to the downstream system. FEI has
 therefore not experienced any impacts upon downstream systems.

However, the inlet pressure to a gate station is not the sole indicator of insufficient capacity at the station. During periods with low system demand, inlet pressures around 350 psig may not be a concern as the low system flow may not require high inlet pressure to maintain operation of the system downstream of the station. It is during high flow conditions driven by peak demand where it is most critical to ensure inlet pressure is maintained above a minimum threshold. A gate station's capacity to deliver the required flow (and hence maintain pressure into the downstream system) reduces as the inlet pressure to the station reduces.

10		
11		
12		
13	2.3	Please explain the extent to which the inlet pressure observed at the Kelown
14		Gate Station and the Polson Gate Station is affected by (i) the peak deman

- 132.3Please explain the extent to which the inlet pressure observed at the Kelowna #114Gate Station and the Polson Gate Station is affected by (i) the peak demand on15the entirety of the ITS system, and (ii) the peak demand in localized areas of the16ITS system.
- 17

18 **Response:**

19 The pressures observed on the ITS at the Kelowna #1 and Polson Gate Stations are influenced 20 (lowered) to some extent by any peak demand load that is added to the ITS and that is not 21 upstream of a pressure control station or compressor station that is actively controlling pressure. 22 In the case of Kelowna #1 and Polson Gate Stations, this region would extend from the 23 discharge of the Savona Compressor Station in the northwest, to the outlet of the current Ellis 24 Creek Pressure Control Station in Penticton. Although there are additional pressure control 25 stations within this area (creating the pressure controlled regions outlined in Table 3-1 of the 26 Updated Application), under peak demand the regulators at these stations are "wide open" and 27 do not restrict the flow of gas or provide any pressure control function because the inlet 28 pressure is lower than the station set-point. Load on the ITS outside of this area, primarily south 29 of Ellis Creek and east of Oliver through the west and central Kootenays, does not currently directly influence pressure at the Kelowna #1 or Polson Gate Stations because of the pressure 30 31 reduction at Ellis Creek to 750 psig. However, the ITS load in this area does factor into the 32 future capacity requirements to serve the Okanagan, such as future compression upgrade 33 requirements at the Kitchener Compressor Station (as discussed further in the response to 34 BCUC IR1 12.1).

Peak demand in localized areas of the ITS is more influential on the pressure at Kelowna #1 35 36 and Polson Gate Stations the closer those localized areas are to either of the two gate stations 37 because the gas is flowing a longer distance. For example, a load addition to the ITS at 38 Kamloops, would have less impact on the pressure at Polson Gate or Kelowna #1 Gate Stations than a load addition at Armstrong (just north of Vernon). This is because there is a penalty in 39 40 terms of pressure loss in the downstream system for every kilometre a unit of energy in the form 41 of natural gas is required to flow in the system. For a unit of gas delivered from Savona to 42 Kamloops, the pressure loss per kilometre associated with that delivery (and its associated



FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	Submission Date: March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 7

pressure impact at Polson Gate) stops once the gas has been delivered the approximately 32 kilometres from Savona to Kamloops. If that same quantity were instead delivered to Armstrong, moving the gas continues to have a cost in terms of higher pressure loss per kilometre for the additional 100 kilometres it travels beyond Kamloops to arrive at Armstrong. More distant local areas served directly through Kelowna #1 and Polson Gate Stations, such as West Kelowna, Lavington, or Lumby have an even greater effect on inlet pressure at these gate stations.

- 8
- 9
- 10

11

- 2.4 Please discuss whether the minimum inlet pressure at major gate stations may be affected by future increases in demand.
- 12 13

14 **Response:**

As described in the response to BCUC IR1 2.3, future increases in demand will reduce the inlet pressure at gate stations throughout the system. If the question is directed at whether future increases in demand would cause FEI to adjust the minimum inlet pressure used as a system design parameter, the response would be no.

- 19
- 20
- 20

25

21

222.5Please provide graphs for the Kelowna #1 Gate Station and the Polson Gate23Station which show from 2019 to 2039 the forecasted inlet pressure under24forecasted peak day conditions in the absence of the OCU Project.

26 **Response:**

Figure 1 below shows the station inlet pressure of major ITS gate stations from 2019 to 2024 under forecast peak day conditions in the absence of the OCU Project. Figure 2 shows the minor improvement that would result from increasing the Savona tap pressure from 600 psig to 650 psig in 2022 to offset the pressure decay for a period of time. Beyond 2024, the hydraulic model no longer converges, which indicates that the system would effectively collapse to zero pressure under the sustained peak day load.

In the forecast period starting from 2020, the inlet pressure at Polson Gate will fall below the
 minimum design pressure of 350 psig and would continue to decay in the absence of the OCU
 Project. FEI will apply short-term mitigation measures to ensure the downstream systems are
 able to continue to operate safely and reliably until the completion of the OCU Project.

The rate of pressure decay illustrates the limited timeframe FEI has to implement mitigation measures before a critical point is reached. The pressure decay becomes more pronounced each year as the decay is nonlinear, and hence accelerates as the pressure declines.











FORTIS BC

- 1 2 3 4 2.6 Please confirm or explain otherwise that the OCU Project is not solely designed
 - 2.6 Please confirm or explain otherwise that the OCU Project is not solely designed to address the potential capacity shortfall in the communities of West Kelowna, Lavington, and Lumby.

8 **Response:**

9 Confirmed. The communities mentioned, served by the Kelowna #1 and Polson Gate Stations, 10 would be the first to experience impacts. Left unaddressed, the impact of insufficient system 11 capacity would spread along the ITS from those major gate stations impacting other customers

- 12 in nearby regions such as Greater Kelowna, Lake Country, Vernon, and Coldstream.
- 13

5

6

7

- 14
- 15
- 16
- 17
- 18

specifically address the forecasted capacity shortfall in the communities of West Kelowna, Lavington, and Lumby only.

2.6.1.1 Please discuss the pros and cons of such an approach.

Please discuss whether FEI considered alternatives that would

19 20

2.6.1

21 **Response:**

FEI considered alternatives to address the forecast capacity shortfall at a local level in the communities of West Kelowna, Lavington, and Lumby. However, these alternatives are not viable long-term solutions for the ITS and do not provide the reliability, resiliency, and operational benefits to the ITS outside of these local areas. The proposed OCU Project will not only provide a capacity enhancement that is available year round to support peak demand, but it will also enhance the way the system can be configured in lower demand periods to support operations and maintenance work on the ITS within the Thompson and Okanagan region.

The capacity shortfall at a local level could be managed in two ways: by supplementing the supply deficit locally with compressed natural gas (CNG) or liquefied natural gas (LNG), or by curtailing local load to match the available supply.

32 CNG/LNG Supply Augmentation

As explained in the response to BCUC IR1 2.6, the communities of West Kelowna, Lavington, and Lumby are just the first communities that would be impacted. As such, when considering a localized CNG/LNG solution, initially at least two locations would need to be addressed, one on the West Kelowna IP system and another on the Polson IP system serving both Lavington and Lumby. Local CNG/LNG injection would be needed to meet two objectives: first, to meet the local increase in peak demand, and second to compensate for any inlet pressure reduction at the gate station serving the system caused by growth in other areas along the ITS. Taking



	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
1.14	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
-	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 10

West Kelowna as an example, CNG/LNG injection could be supplied to manage the peak day 1 2 deficit in year one. In year two, more CNG/LNG would be required to meet the increased 3 demand of new customers in the West Kelowna area, but additional CNG/LNG would be 4 needed to overcome the reduction in inlet pressure at the Kelowna #1 Gate Station caused by 5 demand growth in other communities along the ITS. Consequently, the quantities required to be 6 available on a peak day would escalate year over year because of local growth but also 7 because of system growth. Eventually, supplementation would be required on days warmer than 8 a peak day, further increasing the volumes required to be stored onsite and delivered into the 9 systems. To be a permanent solution, the facility would need to be constructed large enough to 10 serve the forecast future demand. A similar approach would be needed for the Polson IP 11 system. Transportation in the form of LNG rather than CNG would be more effective because of 12 the lower storage volumes. In order for the two facilities to be effective well into the forecast 13 period, each would be smaller in scale than the LNG facility described in Alternative 5 of the 14 Updated Application (the LNG facility alternative proposed, but not selected), but still larger than 15 the local community need. Combined, the two facilities would be less useful and beneficial for 16 the system than Alternative 5, or the preferred OCU Project pipeline.

17 Customer Load Curtailment

18 Curtailing customer load locally to address the supply deficit caused by the capacity shortfall is 19 not considered viable by FEI and would have similar increasing requirements as those 20 described above. FEI does not consider it appropriate to design or operate its system by relying 21 on curtailment of firm customers to maintain the required minimum system pressures. If FEI 22 were to consider curtailing locally, as new customers are added to the local systems each year 23 the increasing peak demand would increase the curtailment requirements year over year. 24 Additionally, in order to alleviate inlet pressure decreases at gate stations caused by system 25 growth in other areas, further curtailment would be required each year. The most effective 26 curtailment for maintaining inlet pressure at the Kelowna #1 Gate Station would be to curtail 27 customers in the West Kelowna system. Customers in other areas could be curtailed to 28 maintain the inlet pressure, but as described in the response to BCUC IR1 2.3, changes in peak 29 demand in more distant locations of the system are less influential on the inlet pressure. So 30 there would be incentive to target customers for curtailment based on their location. FEI has no 31 means of managing a mass curtailment of customers in a local system. The most effective 32 target customers considered for curtailment would be large volume customers where the 33 curtailment effect could be more easily quantified and managed. In a local system, there are 34 limited numbers of such customers to target in order to achieve the increasing curtailment 35 required and manage the capacity deficit over a number of years. Over time, such an approach 36 would create service level inequities and result in security of supply concerns for customers in 37 these local areas compared to the remainder of FEI's customers.

In summary, while addressing the capacity deficit on the ITS at a local level could have some short-term benefits, over the long-term it is not considered a feasible solution for the OCU Project. Addressing the deficit by installing local supply would ultimately require multiple facilities to be operated and maintained, and each would be significantly larger in scale than the initial needs to meet escalating future requirements. Any operational benefits would be more



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 11

localized and less useful to support operations work on the system elsewhere. Addressing the issue by curtailing local customer demand would provide no operational benefit to the ITS, and there is no means in the gas distribution system to apply targeted curtailment to the local customers. Finally, this approach would place the burden of insufficient system capacity on a group of FEI customers who would be disadvantaged simply because of the community in which they are located.

- 7
- 8

9

- 102.7Please provide a table which identifies for each major gate station on the ITS; the11first year in the forecast period where, in the absence of the OCU Project,12forecasted inlet pressure would fall below the minimum inlet pressure of 350 psig13under peak day conditions at the gate station; and the number of customers14served downstream of the gate station.
- 15

16 **Response:**

17 The table below shows the year each gate station in the affected area would fall below 350 psig,

18 and the number of customers served downstream of the gate station. In the short term, FEI will

- 19 employ mitigation measures described in Section 4.2 of the Application to ensure continued
- 20 supply to downstream customers. However, as discussed in the response to BCUC IR1 2.5, the
- 21 hydraulic model fails to converge (i.e., the pressure decays to zero in this area) after 2024. As a
- result, FEI is unable to model any further pressure decay to other stations on the system.

Gate Station	Year Winter Peak Day Pressure < 350 psig	Winter Peak Day Mitigation Measures Insufficient	Customers Served (currently)
Polson Gate	Winter 2020-21	Winter 2023-24	2,000
Kelowna #1 Gate	Winter 2020-21	Winter 2023-24	16,300
Cary Road Gate	Winter 2022-23	Winter 2023-24	9,000

23

- 24
- 25
- 26
- 27
- 28 29

2.7.1 Please also provide this information in the scenario where the OCU Project is constructed but no other capacity upgrades are undertaken in the forecast period (if applicable).

30 Response:

Following completion of the OCU Project, FEI has identified the next required capacity upgrade in the forecast period as the Kitchener B Compressor Station. In the absence of this compressor

33 upgrade, after 2029, the delivery pressure of the OLI PEN 406 pipeline will increasingly degrade

3. below the minimum required 1135 psig at the Oliver V Control Station (Oliver). This pressure is

below the minimum required 1135 psig at the Oliver Y Control Station (Oliver). This pressure is



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 12

- 1 required at this point in the ITS to ensure that Oliver can continue to supply the two pipelines
- 2 leaving that facility and which operate at an MOP of 1135 psig: the Kingsvale Oliver pipeline
- 3 (required to deliver 105 MMscfd to the Enbridge system at Kingsvale), and the South Okanagan
- 4 Natural Gas pipeline that feeds the OCU Project pipeline. If this pressure degradation is not
- 5 addressed, the Polson Gate Station inlet pressure would fall below 350 psig by 2037 as
- 6 identified in the table below.

Gate Station	Year Winter Peak Day Pressure < 350 psig	Customers Served (currently)
Polson Gate	Winter 2037-38	2,000

- 8 Other gate stations would remain above the minimum 350 psig requirement in the forecast
- 9 period. Please also refer to the response to BCUC IR1 12.1 for a discussion of FEI's future gas
- 10 supply strategy for the ITS.

FORTIS BC^{**}

1	3.0	Reference	PROJECT NEED AND JUSTIFICATION
	0.0		
2			Exhibit B-1-2, p. 25
3 4			FEI 2017 Long Term Gas Resource Plan proceeding, Exhibit B-1, pp. 152, 153
5			Line Pack
6		On page 25 o	f the Updated Application, FEI states:
7 9 10 11 12 13 14 15 16		The su on sub system to be continu alterna accour The tra value l a peak	accessful application of line pack to supplement the system capacity relies ficient periods of lower system demand to occur where input into the n can exceed current demand and rebuild the line pack within the system available for future periods of peak demand. The ITS experiences uous daily cycles in demand where line pack is constantly in flux ating between periods of depletion followed by periods of regeneration. FEI hts for this capability by applying the transient factor to the peak demand. ansient factor adjusts the magnitude peak load used for system design to a lower than the hourly peak demand actually experienced on the system on a day, reflecting that the balance can be provided by the system line pack.
17 18		On pages 15 stated:	2 to 153 of the FEI 2017 Long Term Gas Resource Plan (LTGRP), FEI
19 20 21 22 23 24		Desigr an hou ten a. demar averag this pe	ning transmission systems to meet peak demand. Core demand varies on urly basis and typically exhibits a morning peaking period between six and m. and an evening period between five and nine p.m. The peak hour and for these customers can be more than 40 percent above the hourly ge (daily demand/24 hours). Transmission systems are designed to meet eak demand condition.
25			
26 27		The a should	mount of line pack within a transmission system determines whether it be designed to meet peak day or peak hour conditions. A pipeline system
28		with a	large relative line pack can temporarily support increased demand out of
29		the sys	stem that exceeds the supply into the system. As demand exceeds supply
30		the ar	nount of gas "packed" in the pipeline (i.e. line pack) is reduced and
31		pressu	ire in the pipeline is drawn down, until such time that the demand drops
32		below	the supply into the system, at which point pressure (and line pack) can
33		recove	r. Pipeline length and operating pressure determine the amount of line
34		pack a	vallable in the system. I ypically, longer, larger diameter systems operating
35		at high	her pressures with high line pack are designed to peak day conditions;
აი 37		lower	sery, systems with lower amounts of line pack (due to factors such as pressures and smaller volumes) are designed to meet neak hour loads
51			stoburde and smaller volumes, are designed to meet peak nour loads.

(],		Application 1	FortisBC Energy Inc. (FEI or the Company) for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	Submission Date: March 4, 2021					
FORTIS BC*		Response to	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1 Page 14						
1 2 3 4 5	3.1 <u>Response:</u>	Please confirm, or explain otherwise, that the peak demand forecasts presented in the Updated Application (e.g. in Figures 3-6 to 3-8) reflect the application of the transient factor.							
6 7	Confirmed. modified by	demand forecast presented in Figures 3-6 to 3-8 reflect nt factor.	cts the demand						
8 9									
10 11 12 13 14	<u>Response:</u>	3.1.1	Please discuss whether the transient factor is applied at level or at a more granular localized level.	t a system wide					
15 16	The transier reflect the e	nt factor is ffect of line	applied at a system-wide level. The transient factor mod pack which is a property of the larger system and not a sp	ifies the load to becific location.					
17 18									
19 20 21 22 23 24		3.1.2	Please show a comparison of the peak day foreca adjusted for the transient factor and unadjusted for the for the forecast period. If available, please also provide forecast for the ITS.	ist for the ITS transient factor, the peak hour					
25	<u>Response:</u>								
26	The figure	below prov	vides the requested comparison. The middle curve is	the ITS peak					

27 demand forecast provided in the Updated Application.



	FortisBC Energy Inc. (FEI or the Company)	Submission Date:	
тм	Application for a CPCN for the Okanagan Capacity Opgrade (OCO) Project (Application) Response to British Columbia Utilities Commission (BCLIC) Information Request (IB) No. 1	Page 15	
		r ago ro	



Comparison of Peak Day Demand

8 Response:

1 2 3

4 5

6

7

9 Although described as a peak day measure, the ITS loading, when a transient factor is applied, 10 provides peak demand load that falls between a peak day load with no factor applied 11 (representing the daily average load each hour with no variation through the day) and the higher 12 peak hour load. The peak hour demand is the highest system peak of the day and typically 13 occurs in the morning hours just as residential and commercial loads begin to come online 14 following the overnight period. Please refer to the figure in the response to BCUC IR1 3.1.2 for 15 a comparison of the relative variation in peak demand loading. FEI refers to this approach (i.e. 16 applying the transient factor) as a "peak day" loading but it is a generalization that implies that 17 the effects of available line pack over the day are considered. On systems such as ITS, where the configuration provides available line pack, using a peak hour loading would result in under 18 19 estimating the available capacity and would identify capacity constraints at a lower loading 20 (earlier in a peak demand forecast) than the system is actually capable of supporting. Therefore

FORTIS BC^{*}

1 "peak day" load modified by a transient factor is more appropriate measure for assessing 2 capacity on the ITS.

3 4		
5 6 7 8 9	3.2.1 Pl hig <u>Response:</u>	ease explain whether periods of low line pack coincide with periods of ghest demand on the ITS.
10 11 12 13	Yes, periods of low line pa function of the average p along the ITS will drop, ar along the system and thus	ack coincide with periods of highest demand on the ITS. Line pack is a ressure in the system. During periods of high demand, the pressure and so periods of high demand result in lower pressures at each point a lower line pack.
14 15		
16 17 18 19 20 21	3.2.2 PI ty fo <u>Response:</u>	ease discuss whether there are any localized points on the ITS with pically low line pack where peak hour demand may be more relevant r capacity planning purposes than peak day.
22 23 24 25 26 27	Along the length of the ITS relevant for capacity plan that extend from the ITS m as the Kelowna #1 Latera and 5.9 kilometres in leng These laterals have less	S mainline, peak day demand modified by the transient factor is most ning purposes. However, there are locations where smaller laterals nainline result in a locally reduced available line pack. Locations such I and the Coldstream Lateral (supplying Polson Gate Station) are 2.1 of th, respectively, and have a smaller diameter than the ITS mainline.
28 29	However, FEI includes the modified by the transient	hese laterals in the ITS models and applies the peak day loading factor. FEI compensates for the higher pressure drop locally that

would occur in these laterals on the peak hour by adjusting a parameter referred to as the "pipe efficiency" for the lateral.

- 32
 33
 34
 35
 3.2.3 Please describe the line pack characteristics of the pipelines feeding the Kelowna #1 Gate Station and the Polson Gate Station.
 37
- 38 **Response:**
- 39 Please refer to the response to BCUC IR1 3.2.2.

FORTIS BC

- 1
- 2
- 3 4

5

6

3.3 Please explain whether FEI must consider the duration of a peak winter event beyond the peak day in its system capacity planning on the ITS.

7 <u>Response:</u>

8 FEI does not consider the duration of a peak winter event for designing the system capacity with 9 respect to any pipe and compression facilities required to meet a peak day. The design for 10 these facilities, to the extent that they rely on rebuilding line pack in the off peak part of the day, 11 does not require subsequent non-peak days to recover. As a result, the system is designed to 12 support back-to-back peak days should they occur. For peak shaving facilities like the LNG 13 facilities proposed in Alternative 5, the sizing of the vapourizer facilities for gas send-out would 14 likewise meet the need for recurring peak days if needed. The duration and severity of winter 15 peak events would be a factor in determining appropriate LNG storage volumes required at 16 such a site to support extended peak demand. A load duration curve representing an extremely 17 cold winter would be a consideration in the design of an LNG peak shaving facility.

- 18
 19
 20
 21
 23.3.1 Please provide a load duration curve showing the daily peak demand on the ITS for the year with the coldest peak day observed in the last five years.
- 24

25 **Response:**

26 The figure below presents the load duration plot of daily demand in the ITS for 2020, the year 27 with the coldest day observed in the last five years. The demand for the coldest day and then for 28 each successively warmer day is laid out left to right representing each day of the year. The 29 degree day (DD) on the coldest day was a 36.9 DD (-18.9 ° C recorded at the Kelowna Airport 30 on January 14, 2020). The peak load that day was 274 TJ per day. The red arrows indicate the 31 demand in unadjusted form for the flow on January 14, 2020 and the expected flow on a design 32 degree day (DDD). The black arrows represent the flow adjusted by the transient factor and 33 reflect the actual flows and the expected flow on a DDD as they would be presented against the 34 ITS peak demand in Figures 3-7 or 3-8 of the Updated Application. The variation in daily flows 35 through the year, including during warmer periods, show how industrial demand can vary and influence recorded system demand on days with similar weather. 36









1 4.0 Reference: PROJECT NEED AND JUSTIFICATION 2 FEI 2017 LTGRP proceeding, Exhibit B-1, p. 154 3 End-use Peak Load Forecasting

- 4 On page 154 of the 2017 LTGRP, FEI stated:
- 5 FEI has since commissioned Posterity, a consultant, to develop an exploratory 6 process linking peak demand forecasts to the end-use scenarios used in the 7 annual demand forecasts. At this point, the exercise is theoretical in nature and 8 unsupported by direct measurement. As such, FEI's infrastructure planning 9 continues to rely on the Traditional Peak Method. The exploratory end-use 10 method does, however, provide a means of assessing a range of peak demand 11 forecast possibilities and the impact on system capacity upgrade project scope 12 and timing.
- 4.1 Please explain whether FEI has conducted analysis of the link between end-use
 demand forecasts and peak demand for the ITS system as part of its assessment
 of the need for the Project.
- 16

17 <u>Response:</u>

No. FEI used its Traditional Peak Method forecast to assess the Project need and timing and believes that forecast, derived from FEI monthly consumption data, remains the best available. FEI has not conducted any analysis for the Project using a range of alternate forecasts based on end-use methods as the end-use forecasts still remain theoretical and unverified by hourly metered data. Without direct hourly measurement for residential and commercial customers, FEI has no evidence to support that theoretical modifications to peak demand based on future end-use changes would be reasonable. Please also refer to the response to BCUC IR1 4.1.2.

25 26 27 28 4.1.1 If yes, please provide a summary of this analysis, and explain the extent 29 to which it supports the peak demand forecast used in the Application. 30 31 **Response:** 32 Please refer to the response to BCUC IR1 4.1. 33 34 35 If no, please compare the peak demand forecast presented in the 36 4.1.2 37 Updated Application with the end-use peak demand analysis provided



	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
тм	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
•	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 20

for the ITS in the FEI 2017 LTGRP, and discuss any significant differences between the two forecasts.

2 3

4 <u>Response:</u>

5 In the 2017 LTGRP, FEI presented a range of end-use forecasts in addition to the traditional peak demand forecast. The forecasts used in the 2017 LTGRP had a base year of 2015, 6 7 meaning the forecast started with total connected accounts as of December 31, 2015. Accounts 8 and demand for years 2016 and beyond included forecast amounts. This compares to the 9 forecast used in the Updated Application that had a base year of 2018 starting with total 10 connected accounts as of December 31, 2018 and with accounts and demand for years 2019 11 and beyond including forecast amounts. In the years between the two forecasts, FEI recorded 12 three consecutive years of net customer attachments that exceeded the forecast used in the 13 2017 LTGRP, with 2018 being an all-time high for FEI in customer attachments. As a result, the 14 2019 customer account forecast started from a 2018 year end account total that exceeded the 15 range of forecasts used in the 2017 LTGRP. Therefore, the 2019 peak demand forecast also 16 increased above the peak demand forecasts used in the 2017 LTGRP.

17 As discussed on pages 154-155 of FEI's 2017 LTGRP², the end-use method is theoretical and not based on metered FEI data. The end-use forecasts and the traditional FEI forecast all 18 19 underestimated the peak demand load in 2019 by at least 15 TJ compared to the forecast used 20 in the Updated Application. Some end-use forecasts predicted declining loads. Three of the six 21 forecasts predicted no capacity constraint in the forecast period. Regardless, the FEI traditional 22 forecast and the Upper Bound end-use forecast were the closest estimate to the current 23 projected demand. Of the increase in ITS peak demand of 15.7 TJ in 2019 above the highest 24 2017 LTGRP forecasts, 4.4 TJ/d is associated with the net increase in residential customers, 25 8.3 TJ/d is associated with small and large commercial rates schedules and 2.9 TJ/d is 26 associated with customers in the industrial rate schedules. As a result of the high customer 27 attachments in the period preceding the 2019 forecast and with FEI's commercial account 28 forecasting method using a three-year average for commercial accounts, there is a sustained 29 higher growth rate for commercial accounts. This results in a higher growth rate in the current 30 2019 peak demand forecast than was present in the forecast used for the 2017 LTGRP. The 31 factors influencing the current forecast upward compared to the traditional and end-use 32 forecasts increased pressure on the timing for the OCU Project and resulted in the increasing 33 need to manage the Project timing with short-term mitigation measures.

While the end-use forecasts used in the LTGRP provide a means of studying some potential variation in how a peak demand forecast may change as a result of end-use influences, as mentioned previously, the method for imposing the variation is theoretical. Currently, the forecast produced by the method predominantly underestimates FEI's current peak demand by a larger margin than the traditional forecast methods. FEI believes the end-use method needs some basis in direct measurement of FEI customers' usage that presently is not available. Until such time as FEI is able to collect discrete customer consumption more widely, FEI believes

² <u>https://www.fortisbc.com/about-us/corporate-information/regulatory-affairs/our-gas-utility/gas-bcuc-</u> submissions/fortisbc-energy-inc.-gas-submissions/LTGRP/2017-resource-plan-for-natural-gas



that the end-use forecasts are insufficient to project peak demand for the purpose of planning capacity infrastructure. FEI will be submitting a CPCN application for its Advanced Metering Infrastructure Project later this year which, if approved, could provide individual customer metering data that would support a better understanding and application of end-use peak demand forecasting.

- 4.1.3 Please briefly explain the strengths and weaknesses of end-use peak demand forecasting with respect to system capacity planning. **Response:**Please refer to the response to BCUC IR1 4.1.2.
- 14

FORTIS BC*

FortisBC Energy Inc. (FEI or the Company) Submission Date: Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) March 4, 2021 Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1 Page 22

1	5.0	Reference:	PROJECT NEED AND JUSTIFICATION
2			Exhibit B-1-2, pp. 20, 21
3 4			BC Office of Housing and Construction, Provincial Policy: Local Government Implementation of the BC Energy Step Code, p. 4
5			Use Per Customer
6 7		On page 20 peak day der	of the Updated Application, FEI provides the formula used for forecasting nand:
		Th	e calculation of the forecast peak day demand in any year can be described by the following

formula;

Peak Day Demand(Year N) = $\sum_{i=1}^{n} (\Sigma Current Accounts \times UPC_{peak} + \Sigma Forecasted Accounts to Year N)$ × UPCpeak)(rate schedule i) + ∑Industrial Customer Maximum Demand + SContract Obligations for Interruptible Customers

8

9 On page 21 of the Updated Application, FEI states:

10 FEI determines the peak demand of residential and commercial customers 11 connected to and consuming gas on the ITS by multiplying the three-year 12 average peak use per customer (UPCpeak) for each rate schedule by the number of current customers in the system in each residential and commercial 13 14 rate schedule. FEI then multiplies the three-year average UPCpeak for each of 15 the rate schedules by the forecast number of new customer accounts in each 16 rate schedule for each year of the forecast, and adds this to the peak demand for 17 current customers. FEI does not modify the UPCpeak values over the forecast 18 period.

19 5.1 Please explain the rationale for selecting a three-year average UPCpeak, rather 20 than an average over some longer or shorter period.

22 **Response:**

21

23 FEI considers the three-year average to be the appropriate balance between stabilizing the UPC_{peak} for system planning, while also reflecting any developing trends between the current 24 25 consumption and historical results. In determining an appropriate UPC_{peak} for system planning, 26 FEI considers these two competing objectives.

27 The first objective is to establish a stable value of UPC_{peak} that doesn't vary greatly from year to 28 year and which can be applied to hydraulic models to determine system capacity upgrade 29 requirements, if any. A stable value of UPC_{peak} will result in more consistent determination of 30 projected scope and timing of identified capacity upgrades. FEI uses a process that derives a 31 peak hour value from monthly customer consumption. Year-to-year variations can occur 32 because of the coarseness of the data (monthly readings). Using a three-year average 33 dampens the year-to-year variations to some degree and provides a more stable and consistent 34 result.



The second objective is to have timely recognition of changes in customer utilization reflected in
 the current value of UPC_{peak}. For example, over time it is reasonable to expect that the average

3 residential customer might become more efficient and the average premise might have a lower

UPC_{peak} due to better insulation, more efficient appliances, etc. Using a ten-year or a five-year
 average would provide a more stable value of UPC_{peak}, but would obscure more recent changes

6 in customer efficiency from being reflected in the UPC_{peak}.

For these reasons, FEI has consistently used a three-year average UPC_{peak} for system planning
 purposes.

- 9
- 10
- 11
- 5.2 Please provide a detailed explanation of why the UPCpeak for current customers
 is assumed to be constant over the forecast period.
- 14

15 **Response:**

The UPC_{peak} for residential, small commercial, and large commercial customers does change
 from year to year as new forecasts are developed.

18 It is reasonable to expect the values to continue to vary over time. The FEI trends presented in 19 the following response to BCUC IR1 5.3 show historical changes over 10 years. Over time, 20 customer activities such as improvements in energy efficiency, changing end-use applications, 21 and possibly fuel switching will impact UPC_{peak}. However, FEI emphasizes that the scope and 22 scale of these activities are currently unknown. There remains uncertainty in the directional 23 impacts on UPC_{peak} of some efficiency technologies like smart learning thermostats or on-24 demand hot water heaters.

FEI believes that the Traditional Peak Method which holds UPC_{peak} constant through the forecast remains appropriate. This method mitigates risk to FEI and its ratepayers through a process of continual re-evaluation throughout the planning period. The UPC_{peak} values are refreshed annually, and then used in the forecast prepared that year, providing a regular check on the current state of peak demand requirements and potential future impact.

30 In an environment where UPC_{peak} is increasing, the planning process identifies, year over year, 31 the likely advance in timing of project requirements. The forecast method provides sufficient 32 notice to initiate project planning and execution, such that projects can be installed to meet the 33 identified capacity deficit. The risk to FEI and its ratepayers of potentially large-scale peak day 34 outages or projects being more costly (due to insufficient planning or execution time) is 35 managed through the traditional method. In an environment where UPC_{peak} is decreasing, the planning method again identifies, year over year, any deferral in project need, so reprioritization 36 37 or re-evaluation of the scope of projects can be undertaken. The traditional planning method in 38 this way mitigates the risk to FEI and its ratepayers of investing in capacity projects before the 39 need is present.



3 4

5

6

5.2.1 Please describe the main factors FEI considers may contribute to an increase or decrease in the UPCpeak in the forecast period.

7 <u>Response:</u>

8 UPC_{peak} is likely to be decreased through energy efficiency measures on existing premises such 9 as increased adoption of high-efficiency appliances, window replacement programs, home 10 insulation programs, and other measures that reduce the instantaneous energy usage, yet 11 provide a similar level of customer comfort. Programs that switch fuel usage away from natural 12 gas to alternate energy forms would similarly reduce UPC_{peak}. As more modern construction of 13 homes and businesses replace older construction, the predominance of more energy efficient 14 structures and appliances would be expected to contribute to a decrease in UPC_{peak}. The 15 directional impacts on UPC_{peak} of some efficiency technologies like smart learning thermostats 16 or on-demand hot water, where energy use may be more concentrated into the periods of the 17 day is less certain. New customers connecting after deciding to replace oil, diesel, propane, 18 and other higher carbon fuels in homes and businesses with natural gas, although not 19 contributing to an increase in UPC_{peak}, may contribute additionally to growth in overall peak 20 demand.

21

22

23

27

245.3Please provide the UPCpeak for residential and commercial customers by rate25schedule for the last 10 years for customers served by the ITS. Please provide a26description and explanation of any observable trends.

28 **Response:**

The following table presents the historical UPC_{peak} from 2009 to 2019 for RS1, RS2 and RS3 (residential and commercial) customers served by the ITS. The figures that follow graphically illustrate the changes in UPC_{peak} by rate schedule over time.

In the response to BCUC IR1 8.4, FEI explains that the Design Degree Day (DDD) was recalculated in 2017 based on a more recent 60-year weather history. This resulted in a reduction in the design temperature being used in most regions. The lower DDD result was used from 2017 onward and resulted in lower values in that period than if DDD values had remained unchanged.

There are no dramatic trends evident in the UPC_{peak} values over time. The UPC_{peak} for RS1 customers drops slightly over the period and mostly in the period from 2017 (primarily due to the DDD change). The UPC_{peak} values for RS2 and RS3 customers have slightly increased when



- 1 comparing the start and end of the period (even when considering the reduction in DDD), but
- 2 the trend is also not significant.

Voor	ITS UPC _{peak} (GJ/Hr)						
Teal	RS 1	RS 2	RS 3				
2009	0.0487	0.1763	1.8831				
2010	0.0479	0.1758	1.8749				
2011	0.0470	0.1739	1.8718				
2012	0.0475	0.1857	1.9181				
2013	0.0485	0.1975	1.9629				
2014	0.0494	0.2113	2.0586				
2015	0.0499	0.2155	2.1111				
2016	0.0502	0.2190	2.2240				
2017	0.0452	0.1946	2.0447				
2018	0.0449	0.1937	2.0176				

ITS Historical UPC_{peak} (GJ/Hr)

ITS - Historical Rate Schedule 1 UPC_{peak}

0.1918

1.9723

0.0448







ITS - Historical Rate Schedule 2 $\mathrm{UPC}_{\mathrm{peak}}$





	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
гм	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 27

3.0 2.5 2.0 UPC_{peak} (GJ/Hr) 1.5 1.0 0.5 0.0 2009 2010 2011 2012 2013 2014 2015 2016 2017 2018 2019 Year

ITS - Historical Rate Schedule 3 UPC_{peak}

5.4 Please explain why the UPCpeak for new customers is assumed to be the same as existing customers.

8 Response:

1 2 3

4 5

6

7

9 As explained in the response to BCUC IR1 5.2, UPC_{peak} values are refreshed annually, 10 providing a regular check on the current state of peak demand requirements. This includes 11 potential future impacts resulting from current efficiency changes that may influence the 12 UPC_{peak}. As a result, the UPC_{peak} of new customers is reflected, to a degree, in the yearly 13 analysis. FEI recognizes that the UPC_{peak} of new customers is likely to be slightly lower than the 14 current average. Regardless, in any given year the net impact of new customer additions on the 15 total peak demand determined from UPC_{peak} is a very small portion of the total peak demand for 16 that year. The impact of a small fraction of that added peak demand being lower because of a 17 smaller UPC_{peak} is even less. The net impact on peak demand may grow larger later in the forecast, but the near-term impacts which would affect the timing of projects to address 18 19 impending capacity shortfalls is immaterial. As a result, FEI applies the same UPC_{peak} values to represent both existing and new customers in the system. 20



3

Page 4 of the BC Office of Housing and Construction document titled "Provincial Policy:
 Local Government Implementation of the BC Energy Step Code"³ states:

- 6 The BC Energy Step Code is a voluntary roadmap that establishes progressive 7 performance targets (i.e., steps) that support market transformation from the 8 current energy-efficiency requirements in the BC Building Code to net zero 9 energy ready buildings. It establishes a set of incremental performance steps for 10 new buildings that aims to communicate the future intent of the Building Code 11 and improve consistency in building requirements across British Columbia (B.C.) 12 to transition to net zero energy ready buildings by 2032. It is a voluntary tool local 13 governments across B.C. can use to encourage—or require—the construction of 14 more energy-efficient buildings in their communities, and do so in a consistent, 15 predictable way.
- 16 5.5 Please discuss whether FEI assumes the number of new customer accounts to
 17 be directly correlated with new buildings.

19 **Response:**

FEI's gross customer additions have a correlation to new building construction and for forecasting gross customer additions, FEI assumes that a percentage of new buildings will be new gas customers. However, FEI's customer account forecast and the forecast used to determine the peak demand is a net customer additions forecast, therefore FEI does not assume net customer accounts are directly correlated with new buildings. Net customer additions are impacted by customers that leave the system for a variety of reasons.

26

18

- 27
- 28

32

- 295.6Please provide any analysis FEI has undertaken with respect to the actions30adopted by local governments in the ITS service area to implement the BC31Energy Step Code, such as mandatory building requirements.
- 33 **Response:**

The BC Energy step code has been implemented by local governments in the largest urban areas served by the ITS. The BC Energy Step Code was implemented in 2019 in the City of Kelowna and the City of Penticton, and in the City of Vernon in 2020. FEI is not aware of any other mandatory buildings requirements adopted by these municipalities.

³ <u>https://www2.gov.bc.ca/assets/gov/farming-natural-resources-and-industry/construction-industry/building-codes-and-standards/guides/baguide_c2_sc_april2017.pdf.</u>

FORTIS BC

3

	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
м	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 29

- 1 2
- 4 5.7 Please discuss the extent to which the BC Building Code and implementation of 5 the Energy Step Code in BC represents a known and measurable impact upon 6 peak load forecasting for new customers in the forecast period, particularly in 7 municipalities who have adopted mandatory approaches to implementing the 8 Energy Step Code.
- 9 10 **Response:**

11 FEI has not observed any measurable impact (i.e., decrease in peak demand) for new 12 customers due to the adoption of the BC Energy Step Code by the three larger municipalities 13 identified in the response to BCUC IR1 5.6. Rather, the population of the Okanagan region has 14 continued to increase and this population growth has led to a corresponding increase in customer demand. Furthermore, increasing industrial load, including new CNG fuelling stations, 15 16 greenhouse expansions and winery operations, along with other industrial customers on the 17 system, has also contributed to the increase in demand. FEI also notes that industrial customers 18 are not impacted by the implementation of the BC Energy Step Code, as it is applicable only to 19 new residential and commercial construction.



1	6.0	Reference:	PROJECT NEED AND JUSTIFICATION
2			Exhibit B-1-2, p. 23
3 4			Exhibit B-1-2-1, Appendix L-3, "ITS Inc. Acct Growth" tab; "ITS Peak Day Demand" tab
5			Peak Demand Forecasting by Customer Class
6		On page 23	of the Updated Application, FEI states:
7 9 10 11 12 13 14 15 16 17 18		To m of the For r family CBO granu uses facto matc adva while forec	aintain consistency with FEI's rate setting forecast, FEI "trues up" each year a more granular BC Stats/LHA forecast to the regional rate-setting forecast. esidential customers, the rate-setting forecast uses the single family/multi- y growth rates from the Conference Board of Canada (CBOC) forecast. The C forecast is applied province-wide and does not provide the regional ularity of the BC Stats/LHA method. The commercial rate-setting forecast a three-year average of customer additions. To "true up" the forecast, FEI rs the municipal forecasts up or down so that the aggregate sum by region hes the CBOC method, but the differences by LHA remain. This has the ntage of maintaining consistency with FEI's rate-setting aggregate forecast, also providing a granular forecast that is reflective of the growth patterns ast by the BC Stats/LHA method.
19		6.1 Pleas	se clarify the difference (if any) between the terms "household formation" as

- 20 21
- 6.1 Please clarify the difference (if any) between the terms "household formation" as defined by BC Stats/LHA and "housing starts" as defined by CBOC.

22 Response:

The BC Stats definition of a household can be found in footnote 11 on page 23 of the UpdatedApplication and is repeated here for convenience:

25 BC Stats uses the Statistics Canada definition of a household as follows: 26 "Household refers to a person or group of persons who occupy the same 27 dwelling and do not have a usual place of residence elsewhere in Canada or 28 abroad. The dwelling may be either a collective dwelling or a private dwelling. 29 The household may consist of a family group such as a census family, of two or 30 more families sharing a dwelling, of a group of unrelated persons or of a person 31 living alone. Household members who are temporarily absent on reference day 32 are considered part of their usual household. A household formation is the 33 formation of a new household."

The Conference Board of Canada (CBOC) defines a housing start as "The number of residentialunits for which construction has begun."

FEI uses the growth rate of household formations (not the household formations themselves) to disaggregate regional customer additions appropriately to municipalities based on the



- 1 household formation growth rate for that municipality. Municipalities that have higher household
- 2 formation growth rates are assigned a larger portion of the regional customer additions.
- 3
- 4
- 5
 6 6.2 Please explain whether the trueing-up of the residential forecast (using the CBOC forecast results) in higher or lower growth rates for the ITS than the BC
 8 Stats/LHA forecast.
- 9 10 **<u>Response:</u>**
- For clarity, FEI assumes the question was intended to place the closing bracket after "forecast"as shown:
- 13 Please explain whether the trueing-up of the residential forecast (using the
- 14 CBOC forecast) results in higher or lower growth rates for the ITS than the BC
- 15 Stats/LHA forecast.

Year-over-year customer growth rates from a forecast developed using either the CBOC
method for residential customers or the three-year average method for commercial customers
would be higher compared to a similar forecast prepared using only the BC Stats/LHA growth

19 rates.

The following chart for residential customers shows that the forecast developed using only the BC Stats household formations growth rates for the ITS communities is slightly lower (1.48 percent) than the filed forecast. FEI notes that the LHA HHF growth rates were applied to all residential customers equally and that this approach does not account for the differences between single and multi-family housing starts that is captured in the CBOC method.







- 2 The following chart for commercial customers shows that a forecast developed using only the
- 3 BC Stats household formations growth rate for the ITS communities is lower (2.96 percent) than
- 4 the filed forecast.





FEI notes that HHF forecast is a way to disaggregate the regional customer additions forecasts developed by the CBOC and three year average methods into municipalities in a way that represents the expected growth in those municipalities. The ITS spans both the Inland and Columbia regions and the disaggregation of growth further allows for combining the municipalities that are connected to the ITS.

- 6
- 7
- . 8
- 9 10

6.3 Please explain why consistency is needed with the rate-setting forecast for the purposes of capacity planning.

11

12 **Response:**

FEI's load forecasts are used for a number of different applications and regulatory filings in which the forecast periods may overlap. Consistency in forecast methods is important to ensure efficiency and transparency in the development of the forecast and reduce the potential for unreasonable or conflicting results.

17
18
19
20
6.3.1 Please identify any key differences in the objectives of forecasting for rate-setting and forecasting for capacity planning.
22

23 Response:

There are no differences in the objectives of forecasting customer accounts for rate-setting and forecasting for capacity planning. The sole objective of the customer forecast process is to develop a single, accurate forecast that can be aggregated and disaggregated with consistency and reasonableness.

For the purposes of capacity planning, FEI considers a longer forecast period up to 20 years and considers the future impact of the peak demand on the system. Peak demand occurs over a short period of hours or days. Capacity planning takes a longer forecast view in order to identify and plan for upgrade projects that may take many years to construct. In addition, capacity planning is concerned with where on the system peak demand occurs and so the more granular information from the BC Stat/LHA forecasts meets that objective.

For the purposes of rate setting, a shorter forecast period is considered. The rate setting demand forecast considers regional annual demand and is not impacted by peak demand or the locality of the demand on the system.

37



- 1

- 2
- 3

6.4 Please explain why a three-year average of customer additions is used to true-up the forecast for commercial customers.

5 Response:

6 FEI clarifies that the "three-year average of customer additions" referenced on page 23 of the 7 Updated Application was intended to refer to "the three year average of commercial customer 8 additions". A revised paragraph is provided below. The underlined words have been added for

9 clarity.

10 The commercial rate-setting forecast uses a three-year average of commercial 11 customer additions. To "true up" the forecast, FEI factors the municipal forecasts 12 up or down so that the aggregate sum by region matches the CBOC method (for 13 residential customers), or the three year average method (for commercial

- 14 customers), but the differences by LHA remain.
- 15

16 A three-year average of commercial customers additions is used because, as shown in 17 Appendix B2 of its 2020-2024 Multi-Year Rate Plan (MRP) Application, FEI's analysis showed 18 that the existing three-year average method used for forecasting commercial customer additions 19 was superior to the alternative methods tested. FEI did not recommend any change to that 20 component of the forecast. Appendix B2 to the MRP Application can be found online at the 21 following link: https://www.bcuc.com/Documents/Proceedings/2019/DOC 53565 B-1-1-22 FortisBC-2020-2024-Multi-YearRatePlan-Appendices.pdf

23 24

25

26

27

- 6.4.1 Please explain whether the trueing-up of the commercial customer forecast (using the three year average of customer additions) results in higher or lower growth rates for the ITS than the BC Stats/LHA forecast.
- 28
- 29 **Response:**

30 Please refer to the response to BCUC IR1 6.2.

- 31
- 32
- 33
- 34 An excerpt of the "ITS Inc. Acct Growth" tab of Appendix L-3 to Exhibit B-1-2-1 is 35 provided below, showing the growth rate for Rate Schedule 3 (RS 3) customers on the 36 Total ITS System:

2018 YE Accounts	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029
628	9.1%	8.5%	8.1%	7.7%	7.1%	6.7%	1.1%	1.1%	1.0%	1.1%	1.0%

FORTIS BC

FortisBC Energy Inc. (FEI or the Company)Submission Date:
March 4, 2021Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)March 4, 2021Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1Page 35

- 6.5 Please explain why the forecasted growth rate for RS 3 customers is higher than other customer classes in the period 2019 to 2024.
- 3 4

5

1 2

6.5.1 Please explain the reason for the significant drop in the forecasted growth rate between 2024 and 2025.

6 **Response:**

- The forecast RS 3 customer growth rate is higher than the other rate schedules from 2019-2024
 due to the unusually high number of RS 3 customers that were added to the system in 2018.
- 9 As shown in Figure 1 below:
- 10 1. Prior to 2017 and 2018 RS 3 customer additions were low.
- 11 2. In 2017 and 2018 RS 3 customer additions increased sharply.
- a. The red rectangle indicates the data used to develop the RS 3 customer additions
 forecast (using a three year average).
- 14

Figure 1: RS 3 Actual Customer Additions

- ITS Rate Schedule 3 Customer Additions 140 170 100 80 60 CustomerAdditions 40 20 2010 2014 2016 2017 2008 2011 2018 40 -60 -80
- 15
- 16 As show in Figure 2 below:
- 17 1. Line segment 1 shows the actual RS 3 customers.
- Line segment 2 shows the result of the commercial customer forecast from 2019 to
 2024.
- 20 3. Line segment 3 shows the long-term result of continuing to add the forecast annual
 21 additions each year, through 2039. This forecast was considered unreasonable
 22 because:


2

3

4

5



- a. There was no apparent cause for the customer increase in 2018.
- Based on Grubbs Outlier test⁴ the 2018 value of 117 customer additions was an outlier.
- 4. Line segment 4 shows the adjustment FEI made to the forecast in 2025.
- As a result of the adjustment the annual RS 3 customer growth rate from 2025 through 2039 is

7 now similar to the other rate schedules as per the "ITS Inc. Acct Growth" tab in Appendix L-3 to

8 the Updated Application.

9



Figure 2: RS 3 Customer Forecast

10 11 12 13 In the "ITS Peak Day Demand" tab of Appendix L-3 to Exhibit B-1-2-1, Row 151 shows a 14 forecast peak industrial demand of 62.23 TJ/d for the forecast period. 15 16 6.6 Please confirm which rate schedules comprise the "industrial demand." 17 18 **Response:** 19 The following rate schedules are included in the industrial demand: 20 Rate Schedule 5 21 Rate Schedule 6

⁴ <u>https://www.graphpad.com/quickcalcs/grubbs2/.</u>



- 1 Rate Schedule 23
 - Rate Schedule 25
 - Rate Schedule 22A and 22B (contractual firm quantity only)

Rate Schedules 22A and 22B have a large component of their demand that is interruptible
service. Only a portion of the demand is contracted as a firm delivery requirement and only that
portion is included in peak demand forecast.

ç	2
	ر

2

3

9

- 10
- 116.7Please confirm, or explain otherwise, the industrial demand figure of 62.23 TJ/d12represents firm demand from industrial customers only.
- 13
- 14

- 6.7.1 If interruptible demand is included, please provide a breakdown of the
- 62.23 TJ/d figure by firm and interruptible demand.
- 15

16 **Response:**

17 Confirmed. As indicated in the response to BCUC IR1 6.6, only firm quantities for industrial 18 customers are included in the peak demand forecast.



7.0 **PROJECT NEED AND JUSTIFICATION** 1 Reference: 2 Exhibit B-1-2, p. 21 3 Industrial demand 4 On page 21 of the Updated Application, FEI states: 5 Maximum Demand from Firm Industrial Customers: For firm industrial customers 6 with available hourly consumption data, FEI determines the UPCpeak for each 7 customer directly from the hourly data. The peak day demand is determined 8 based on the maximum demand observed in the hourly consumption of the 9 customer and assumes that consumption would be sustained over a day. The 10 peak day demand is therefore equivalent to a peak day flow. If an industrial 11 customer has made a contractual commitment to increase their future firm load, 12 this incremental load is included in the peak day demand forecast. Otherwise, 13 FEI does not include any change in industrial customer numbers or demand due 14 to the uncertainty associated with the location and magnitude of consumption 15 needs of future customers in industrial rate schedules.

16 17 Please explain why FEI does not use daily consumption data to determine the UPCpeak for firm industrial customers.

18

19 Response:

7.1

20 FEI builds system-wide peak demand based on the loads originating from within the distribution 21 svstem. The vast majority of industrial customers served by the ITS are located within 22 distribution systems operating at a maximum pressure of 420 kPa. These distribution systems 23 are designed on a peak hour basis as they have no capacity or useable line pack to 24 accommodate hourly load swings. The system capacity is therefore designed to support the 25 maximum hourly load and industrial customer load is assessed to determine their maximum 26 hourly loads. These loads are applied to the distribution system models and roll up into the 27 Transmission system models. The metered data for industrial customers does not have a high 28 degree of consistency as customers can have daily periods of extended high flow, daily periods 29 of extend low flow, or daily periods of intermittent high flow and low flow. Due to the 30 inconsistent nature of industrial customers' daily demand, FEI models the capacity of the ITS 31 assuming that the industrial customers are capable of sustaining their highest observed flow 32 rate (as used in the peak hour distribution model) throughout the daily period. This also means 33 FEI assumes that the periods of low consumption that an industrial customer might have on a 34 typical day, that would contribute to rebuilding line pack in the system, will therefore not occur 35 on a peak day.

- 36
- 37
- 38
- 397.2Please discuss whether the assumption that an industrial customer's maximum40hourly demand is sustained over a day is supported by metered data.

FORTIS BC*

1 2

3

4

- 7.2.1 If not, please explain why FEI makes this assumption.
- 7.2.2 Please provide the total hourly load profile of FEI's firm industrial customers in the ITS in the peak day observed in the last three years.

5 **Response:**

6 FEI provides the figure below that shows the total hourly load profile of firm industrial customers 7 on the system for the coldest days in 2018, 2019, and 2020 with flow sustained through the day.

8 The data indicates a relatively steady cumulative industrial firm demand, with flow varying 9 through the day but not significantly. The time of day when the peak occurs is also variable, with the maximum flows aligned at different points in the day. 10

11 FEI also notes that the industrial demand on February 21, 2018 was higher than on January 14, 2020, a day that was 5.3 degrees colder. This indicates the industrial demand is not well 12 13 correlated to temperature, and colder days could also experience much higher industrial 14 demand than that represented in the figure. As a result of this uncertainty around when, and 15 how sustained, the peak industrial flow will be on any given day, FEI models system capacity to 16 support a sustained maximum industrial demand equal to the highest hourly value observed for

17 each customer.





18 19



- 1
- 2
- 3 4

- 7.3 Please discuss whether FEI considers further capacity upgrades would likely be required in the forecast period to accommodate any additional firm industrial customers.
- 6 <u>Response:</u>

7 FEI is unable to determine with any certainty if or when further capacity upgrades might be 8 required to accommodate any additional firm industrial customers. Such determination would 9 ultimately be driven by factors such as the future change in demand of existing industrial 10 customers as their demand evolves, and the location and demand requirements of future 11 industrial customers. FEI considers such factors to be speculative and therefore are not 12 included in the forecast peak demand for the OCU Project. If a new firm industrial customer is significant enough to drive a major upgrade of the ITS on its own to support the customer 13 14 connection, that would need to be considered and managed and ultimately approved based on 15 the specific requirements of the proposed customer.



3

1 8.0 Reference: PROJECT NEED AND JUSTIFICATION

Exhibit B-1-2, p. 22

1 in 20 Weather Event

- 4 On page 22 of the Updated Application, FEI states:
- 5 FEI's DDD [Design Degree Day] temperature for any system operating within a 6 region is the coldest day that is statistically likely to occur only once in any given 7 20 year period. In determining the DDD value, FEI uses an extreme value 8 statistical method called the Gumbel Method of Moments. This method returns 9 the expected extreme value for a given historical data set based on a specified 10 return period. FEI uses a 1 in 20 return period on a data set that represents the 11 coldest recorded daily mean temperature at the region's weather station each winter over a 60 year period. 12
- The DDD temperature values for weather zones in the ITS range from a 46.7 13 14 Degree Day (DD) 16 (corresponding to minus 28.7°C mean daily temperature) in the Thompson region, to a 43.9 DD (corresponding to minus 25.7°C mean daily 15 temperature) in the North and Central Okanagan region, to a 39.1 DD 16 17 (corresponding to minus 21.7°C mean daily temperature) in the South Okanagan 18 region. The regional DDD values are based on a 60 year weather history as 19 reported by Environment Canada at the Kamloops Airport, Kelowna International 20 Airport, and Penticton Regional Airport weather stations, respectively.
- 218.1Please compare the DDD values for the Thompson region, North and Central22Okanagan region and South Okanagan region against the coldest day observed23in the last 20 years.

24

25 **Response:**

- 26 The following table presents the requested weather information for the three regions.
- 27

Coldest Days Observed since January 1, 2001

Index Weather Station	Index Weather Region Station		Coldest Day 2001-2021 (DD)	Date of Occurrence	
Kamloops (YKA)	Thompson	46.7	42.4	14-Jan-05	
Kelowna (YLW) North/Central Okanagan		43.9	42.2	20-Dec-08	
Penticton (YYF)	South Okanagan	39.1	35.7	20-Dec-08	

- 28
- 29 30

31

32

33

8.1.1 Please outline the number of days in the last 60 years where the observed mean daily temperature was colder than the DDD, and the dates of these occurrences.



2 **Response:**

- 3 The table below provides the requested weather history for the region.
- 4

Days Observed in 60 Year Weather History Exceeding Design Degree Day

Index Weather Station	Region	Design Degree Day (DDD)	Coldest Days (DD)	Date of Occurrence
	Thompson		47.9	28-Dec-68
			50.9	29-Dec-68
Komloone (VKA)		46.7	47.4	30-Dec-68
Ramoops (TRA)		40.7	47	22-Jan-69
			47.3	28-Jan-69
			47.8	29-Jan-69
Kelowna (YLW)	North/Central Okanagan	43.9	46.9	29-Dec-68
			46.3	30-Dec-68
	South Okonomon	20.4	40.5	16-Dec-64
Ponticton (VVE)			42.4	28-Dec-68
Fenilolofi (TTF)	South Okanayan	39.1	42.3	29-Dec-68
			41.1	30-Dec-68

5

6

- 7
- 8 9

10

11 12 Response:

8.2

13 No, the Gumbel extreme value analysis does not place greater weight on values based on when 14 they occur. A set of extreme values is an input to the analysis; for FEI, this is the coldest day to 15 occur in each of 60 years. There is no input into the statistical method to reflect or measure 16 how the data point is related to other data points in the data set along a timeline, i.e. if one data 17 point occurs sooner or later than another.

on observed temperatures in more recent years.

Please explain whether the Gumbel Method of Moments places greater weight

18

20		
21	8.2.1	Please explain why a 60 year data set is used instead of the most
22		recent 20 year period.
23		



1 Response:

FEI has two main objectives that are met by using a 60 year data set. The first is to determine a sufficiently infrequent weather event to design the gas system to ensure reliability and security of supply can be met under the associated high demand forecast to occur during such an event. The second is that the design event is a stable and reproducible target for designing the system and doesn't change from year to year.

FEI believes that an event that is likely to occur only once in a 20 year period only meets the first objective. This is why FEI does not design to a return period of 1 in 15 year or 1 in 10 years. Where the impact of loss of supply due to insufficient capacity can result in customer outages than can extend for days or more in extremely cold weather, to meet a high level of reliability for gas distribution and transmission systems FEI uses a 1 in 20 year return period.

12 Regarding the second objective, as a vital design parameter, it is important that the system 13 design temperature produce a stable and reproducible result which does not vary dramatically 14 over time. This ensures that projects have a clearly defined objective to meet. Using a data set 15 of 20 values to calculate the likely extreme temperature in a future 20 year period is possible. 16 However, the result may vary significantly when it is recalculated in subsequent years, 17 particularly if the data set drops a winter of very cold temperatures and replaces it with a very 18 warm year. A variation such as that just described would have less impact on the statistical 19 result if the data set is larger and there is less influence from year to year changes. FEI uses 20 the result of the Gumbel Method of Moments to provide a consistent design degree day (DDD) 21 temperature to determine peak demand and hence system capacity. To provide consistency, 22 FEI does not currently recalculate the DDD more than once per decade. Using a smaller 23 sample of 20 years would require FEI to recalculate and change the DDD much more 24 frequently. Given the volatility of extreme weather, FEI considers that a 60 year data set 25 reflects trends in weather in a more stable fashion.

- 26
- 27
- 28
- 20 29
- 30
- 31

8.3 Please discuss at a high level any observed trends in the frequency and severity of extreme cold events in the last 60 years.

32 Response:

33 The three figures below present the recorded weather at each weather station listed in the 34 preamble above. The weather data for each region over the past 60 years has exhibited a 35 variation in extreme values with the winter of 1968-69 being the coldest winter in the history and 36 winter of 1964-65 the next most extreme. The Kelowna Airport data only extends to 1968 so 37 does not comprise a full 60 year history, however it does contain the extreme winter of 1968-69 38 when the DDD was exceeded. Since then, the most recent extremes occurred in December 39 1990 with temperatures within 0.2°C of reaching the DDD and in 2008 with temperatures 40 coming within 1.8°C of reaching the DDD. All three regional weather records show a wide



	FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	Submission Date: March 4, 2021
тм	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 44

- 1 distribution of winter extremes over their history. The most extreme event in all regions is within
- 2 the first 10 years of the data history so those values will be removed from the extreme value
- 3 analysis in the next 5-10 years. The magnitude of future peak winter low temperatures that will
- 4 replace the extreme values recorded in the 1960s will determine whether the DDD will increase,
- 5 decrease or stay constant in these regions when recalculated in the future.











FORTIS BC

- 1
- 2
- 3

4

5

6

7

8.4 Please explain whether FEI makes any adjustments to the DDD due to climate change, for example based on observed or expected trends in the frequency and severity of extreme cold events.

8 **Response:**

9 FEI's peak demand forecast does not directly consider the potential impact of climate change on 10 the DDD. FEI is not aware of a reliable method to forecast future changes in extreme weather 11 either in severity or frequency (especially in the cold temperatures which set FEI's peak 12 demand).

13 However, FEI does apply trends in recent weather history (that may reflect climate change 14 impacts) by periodically re-adjusting the DDD temperature used to estimate peak demand. FEI 15 last updated the DDD for each of the 22 weather zones in its operating territory in 2017. These 16 updates examined the weather history in each weather zone over the preceding 60 years. The 17 last update resulted in a warming in the DDD temperature in most weather zones. For example, 18 in the case of the north and central Okanagan, the DDD changed from a 45.0 degree day to a 19 43.9 degree day. This represented a warming of 1.1°C in the design temperature. The 20 Thompson region DDD warmed by 2.2°C and the South Okanagan by 0.9°C. This results in 21 lower peak demand estimates for customers in these regions than would have been calculated 22 using the DDD values in use prior to 2017.



9.0 **PROJECT NEED AND JUSTIFICATION** 1 Reference: 2 Exhibit B-1-2, pp. 25, 51 3 **Class Locations** 4 On page 25 of the Updated Application, FEI states: 5 The ITS serving the Thompson Okanagan region has several regions where 6 pressure is controlled below the original MOP [maximum operating pressure] to 7 ensure pipeline safety factors associated with CSA Z662 class locations 8 requirements. These pressure-controlled regions are identified in Table 3-1 9 above, with the segments most relevant to the OCU Project listed in rows 2 to 5. 10 On page 51 of the Updated Application, FEI states: 11 The class location of a pipeline is related to the population density in the 12 surrounding area. As population in an area increases, the class location can 13 change, and a pipeline operator must take action to ensure the pipeline meets 14 the requirements of the new class location. This can mean reducing MOP or modifying the pipeline. 15 16 9.1 Please explain whether FEI anticipates any class location changes will be 17 required to FEI's pipelines in the ITS during the forecast period as a result of the 18 expected population growth discussed in section 3.3 of the Updated Application. 19 20 **Response:**

At the present time, FEI is not aware of any potential class location changes along FEI's ITS pipelines during the forecast period as a result of the expected population growth.

In accordance with the requirements of CSA Z662:19, FEI is required to assess its pipelines on a regular basis to determine if class locations changes have occurred. Although FEI expects population growth, it is difficult to predict exactly where this growth will be located and whether it will be immediately adjacent to the pipelines in the ITS. As a result it is difficult to anticipate if and where class location changes might occur and whether there will be an impact on the pipelines.



4

1 B. SHORT TERM MITIGATION MEASURES

2 10.0 Reference: SHORT TERM MITIGATION MEASURES

Exhibit B-1-2, pp. 34, 35, 37

Description of Short Term Mitigation Measures

5 In sections 4.2.1 to 4.2.4 on pages 34 to 35 of the Updated Application, FEI describes 6 the following short term mitigation measures: contractual minimum pressure increase, 7 temporary load shifting, station modifications, and additional mitigation measures.

8 With respect to additional mitigation measures, FEI states, "In addition, throughout the 9 period prior to completion of the OCU Project, FEI will manage load additions within 10 system capacity limitations, and identify and manage existing customer loads under 11 peak conditions."

12 Figure 4-1 on page 37 shows the ITS capacity with the short term mitigation measures:



Figure 4-1: ITS Capacity with Mitigation Measures

13

14 15 10.1 For each of the four short term mitigation measures FEI is planning to undertake, please explain the following:

16 17

18

19

20

21

• Whether there are any reliability concerns with respect to the measure's ability to provide dependable capacity during a peak demand event (assuming overall system capacity was sufficient to meet demand);

- The extent to which potential exists for increased capacity by further expansion of the measure at the location(s) described and/or elsewhere on the ITS, and any implications of expanding the measure;
- The potential longevity of the measure as a reliable capacity solution
 (assuming overall system capacity was sufficient to meet demand).
- 24



1 Response:

Following are the reliability, expansion, and longevity concerns for each of the four short-termmitigation measures.

4 1. Contractual Minimum Pressure Increase

- a) Reliability Concerns: An ongoing minimum pressure increase was not represented in the short-term mitigation measures which formed the basis for Figure 4-1 as FEI cannot depend on the additional 50 psig of pressure at Savona. FEI has a verbal understanding that Enbridge will attempt to maintain a minimum 650 pisg pressure at the custody transfer point at Savona; however, no firm contractual obligation exists. For this reason, FEI cannot consider this measure reliable. However, when available, this increased pressure will improve the effectiveness of the other short term mitigation measures.
- b) Expansion Potential: FEI does not have the ability to increase capacity reliably or
 permanently by maintaining or expanding this measure as it is dependent on Enbridge's
 system capacity, which is not within FEI's control.
- 15 c) Longevity: FEI cannot guarantee that this measure will be available over the long-term.

16 2. Temporary Load Shifting

- 17 a) Reliability Concerns: Temporary load shifting is a viable method of reducing the flow 18 through the Polson and Kelowna #1 Gate Stations and can be accomplished by 19 adjusting the station set points in each system in advance of winter each year. This 20 approach shifts the flow to other stations serving the system that do not have the same 21 inlet pressure requirements as the gate stations serving IP systems. As discussed in 22 Section 4.2.2 of the Updated Application, this shift reduces the flow and the overall pressure drop in the transmission laterals supplying these stations and thereby improves 23 24 the inlet pressure at these stations, but otherwise does not impact reliability.
- b) Expansion Potential: This approach is limited by the ability of the distribution system to
 deliver the offset load to the customers who would otherwise be served through the
 Polson Gate or Kelowna #1 Gate Stations. These gate stations cannot be underset
 more than what is currently being considered as this would reduce pressures in the
 downstream IP and DP systems such that minimum capacity requirements in these
 systems would no longer be met. There are no other systems available to further offload
 the Kelowna #1 Gate Station or the Polson IP system.
- c) Longevity: The acceptance of very low inlet pressures through Polson and Kelowna #1
 Gate Stations means a decreased capacity in the downstream DP and IP systems. FEI's
 modeling indicates that with planned station upgrades in these systems, acceptable
 capacity can be maintained only through the winter of 2021/2022. As demand on these
 systems continues to increase, full flow through these stations is likely to be required.
 Thus this measure can only be maintained temporarily.



1 3. Station Modifications

2 Upgrades to district stations to improve capacity will provide a reliable increase in capacity, 3 which will be maintained into the future. FEI does not have reliability concerns associated 4 with this portion of this measure, but there is limited potential to expand it further. The 5 following responses will focus on installation of full station bypasses.

- 6 a) Reliability Concerns: Full station bypasses which will be installed at Polson and Kelowna 7 #1 Gate Stations will be manually operated during peak winter conditions to bypass 8 station equipment and eliminate the associated pressure drop, thereby improving inlet 9 pressure downstream of each station. Manual operation of bypass valves which directly 10 interconnect the transmission and intermediate pressure systems will be performed by 11 qualified and trained FEI operations personnel; however, this will involve logistical 12 challenges and risk. While FEI is confident the measure can be successfully executed 13 for short periods, significant local operational effort and oversight will be required to 14 ensure safe operation of the system.
- b) Expansion Potential: There is no potential to expand this measure. FEI will already be
 fully bypassing stations, allowing gas from FEI's transmission system to enter
 downstream systems with no pressure drop.
- c) Longevity: FEI will not maintain this measure following installation of necessary pipeline
 infrastructure as the OCU Project will improve inlet pressures at the stations such that it
 would no longer be necessary to bypass the stations.

21 4. Additional Mitigation Measures

Please refer to the response to BCUC IR1 2.6.1 for the issues with respect to customercurtailment and load management.

In summary, the pressure decay illustrated in the response to BCUC IR1 2.5 shows the overall
 longevity of the described mitigation measures. With the mitigation measures, the pressure
 decay becomes unacceptable by the winter of 2023-2024 without the OCU Project in service.

27
28
29
30 10.2 Please provide a breakdown of the estimated capacity increases shown in Figure 4-1 by measure.
32

33 Response:

The following figure provides a breakdown of the estimated contribution of each of the mitigation measures. Please note that the blue line, which shows the combined impact of all proposed short-term mitigation measures, was modeled with a minimum inlet pressure of 650 psig to FEI's system at Savona (as indicated in the figure legend). This is not a firm contractual



- increase, but rather represents a working agreement between FEI and Enbridge. All other
 capacity lines were modeled with an inlet pressure of 600 psig to FEI's system at Savona.
 - 400 Daily Demand (TU/d) 320 280 201 Year - ITS Forecasted Peak Demand Minimum Pressure Increased to 650 at Savona, Temporary Load Shifting & Station Modifications **Temporary Load Shifting & Station Modifications** Station Modifications **Temporary Load Shifting** Current ITS Capacity

Breakdown of Short-Term Mitigation Measures



- 1
- 2

4

- 10.3 Please further explain how FEI intends to "identify and manage existing customer loads under peak conditions."

5 Response:

6 As discussed in the response to BCUC IR1 2.6.1, FEI has no means of conducting a mass 7 curtailment of customers in a local system. To be effective, the target of any load curtailment 8 would focus on large volume customers where the curtailment effect could be more easily 9 quantified and managed. FEI's internal industrial marketing group is aware of the potential 10 limitation on ITS capacity. This group works with existing and potential industrial customers who 11 rely on FEI's natural gas service. Until the OCU Project is completed, this group will inform new 12 customers, or existing customers adding load, that FEI may not have the capacity to serve them on a firm basis until completion of the Project. In some cases, customers will accept an 13 14 interruptible rate schedule until the OCU Project is complete at which time FEI can provide firm 15 service. In other cases, FEI will not be able to accommodate the customer connection or 16 expansion.



3

4

1 11.0 Reference: SHORT TERM MITIGATION MEASURES

Exhibit B-1-2, pp. 35, 36

Compressed Natural Gas

On pages 35 to 36 of the Updated Application, FEI states:

- 5 To mitigate the forecast capacity shortfall, 1 to 2 large truckloads of CNG 6 [compressed natural gas] per hour (up to 4 - 6 truckloads per day) would be 7 required during a peak demand event by the winter of 2022/2023. With growing 8 demand in the region, the capacity shortfall and corresponding amount of CNG 9 or LNG [liquefied natural gas] required will increase over time. CNG trucks would 10 be required to travel from a filling point outside of the central Okanagan, where 11 the system has a sufficient gas surplus to allow trucks to fill, to an effective 12 injection point in the central Okanagan. LNG trucks would be supplied from FEI's 13 Tilbury LNG facility in Delta, approximately 400 km from the shortfall region. This 14 CNG/LNG truck traffic would be required during a peak demand event, which 15 corresponds to the most severe winter weather in B.C.
- 16 Transporting fuel by truck during severe winter weather is a less cost effective 17 and reliable method of gas transportation than appropriate and adequate pipeline 18 infrastructure. The reliability concerns could be mitigated through staging of 19 sufficient additional trucks, but this would come at an increased cost. CNG and 20 LNG supplementation would not provide a lasting improvement to FEI's system, 21 as CNG/LNG supplementation is not a viable long-term solution to the capacity 22 shortfall in the Okanagan and will not decrease the cost associated with this 23 required pipeline installation.
- 11.1 Please provide any analysis that FEI has performed to assess the potential costs
 of CNG and/or LNG against the potential benefits of deferring the OCU Project
 (for example, by one to five years).

28 **Response:**

27

A detailed cost/benefit analysis was not completed as FEI does not consider CNG and/or LNG supplementation to be a practical or appropriate means of addressing the forecast ongoing capacity shortfall on the ITS in order to defer the OCU Project. While CNG/LNG supplementation are useful as an emergency response tool, the sections below discuss in qualitative terms the shortcomings of CNG/LNG as a solution to defer major capacity upgrades.

CNG/LNG Trucking Has Lower Reliability and Potentially Higher Safety Risks than a Pipeline

Pipelines are a more reliable method of natural gas transportation than CNG/LNG trucking.
 Trucking introduces the risk of service disruptions due to heavy traffic or accidents, driver error,
 road closures due to severe winter weather, and/or truck breakdowns. There is also added risk

39 associated with trucking CNG/LNG when compared with pipeline transport of natural gas; traffic



- 1 accidents involving CNG/LNG trucks may present a risks to drivers and to the public in the
- 2 surrounding area due to the potential of a product release. As the number of trucks required to
- 3 maintain capacity increases, the associated risk increases as well. The response to BCUC IR1
- 4 11.4 provides more detail regarding the reliability concerns with this solution.

5 **CNG/LNG Implementation Is Logistically Difficult**

6 The number of daily and hourly truckloads required to maintain capacity during peak demand 7 guickly becomes logistically infeasible. By the winter of 2024-2025, up to 36 truckloads of CNG 8 would likely be required on a peak day, a number which FEI does not consider feasible in this 9 scenario. In FEI's previous experience using CNG injection (please refer to the response to 10 BCUC IR1 11.4.1) it can take 1.5 to 2 hours to fill each truck, and 1 to 2 hours to empty each 11 truck at the injection point. While it is possible to fill and to empty multiple trucks at a time, this 12 increases the space and personnel requirements at the compression and decompression sites. This in turn increases the logistical difficulty and the demand on FEI's operational resources. 13 14 Due to the demands which will already be placed on FEI's operations personnel during peak winter conditions in the affected region, including managing short term mitigation measures in 15 16 multiple communities and managing other emergency situations which can arise during extreme 17 weather events, FEI's existing internal resources may not be capable of managing the logistical 18 challenges associated with supplying a significant capacity shortfall using CNG trucking. FEI 19 would likely be required to rely heavily on contractors or on temporary personnel to manage the 20 additional workload, which introduces additional risk of human error.

21 CNG/LNG Requirements Cannot be Precisely Forecast

It is not possible to precisely estimate the amount of CNG which will be required in a given winter. FEI can provide only a best approximation based on hydraulic modeling, but there is a possibility that actual requirements may exceed FEI's estimate. If this is the case, FEI may not have the resources in place to manage the actual shortfall, resulting in customer outages.

Costs Associated with Implementing CNG/LNG Introduce Unnecessary Costs to the OCU Project

28 As CNG/LNG trucking is not a viable long-term solution, and does not provide any lasting 29 capacity benefit to FEI's system, FEI determined that deferral of the Project and implementation 30 of CNG/LNG would inevitably result in higher overall costs to the customer. The costs 31 associated with CNG/LNG trucking would include both an upfront cost to install necessary 32 infrastructure, complete the necessary site upgrades, and purchase/rent required equipment, as 33 well as operational and contractor costs which would escalate each year with increasing 34 demand. These expenditures would not decrease the total cost of the required pipeline, and as 35 such FEI would not consider them a prudent investment since they could be avoided by the 36 timely construction of the OCU Project (which would be necessary in any event). Installation of 37 this necessary pipeline infrastructure will allow FEI to reliably supply its customers without the 38 undue costs and risks associated with using CNG/LNG trucking as a stopgap measure. This 39 differs from the other proposed short-term mitigation measures because other measures do



Please provide an estimate of the number of CNG truckloads per hour and per

day that would be required to meet peak demand in winter 2023/24 and 2024/25.

1 provide a lasting capacity benefit to the system, and therefore represent an appropriate 2 investment.

- 3
- 4
- 5
- 6
- 7
- 8

.

11.2

9 <u>Response:</u>

10 As explained in detail below, FEI would have to be prepared to deploy up to 16 truckloads of 11 CNG per day in the winter of 2023/2024, and approximately 36 truckloads per day in the winter 12 of 2024/2025. However, all estimates of CNG requirements are a best approximation only. It is 13 difficult to accurately model the capacity benefits of CNG injection and the numbers provided 14 below cannot be precise; FEI can provide only its best estimation of the likely future 15 requirements. As noted in the response to BCUC IR1 11.1, FEI does not consider CNG and/or 16 LNG supplementation to be a practical or appropriate means of addressing or deferring the 17 OCU Project, instead considering CNG and/or LNG supplementation valuable and useful 18 emergency response tools.

As discussed in Section 4.2.1 of the Updated Application, FEI has negotiated an understanding with Enbridge to attempt to maintain a higher minimum pressure of 650 psig at Savona, where gas enters FEI's system. However, FEI cannot depend on this pressure in its forecasting as Enbridge does not have a firm contractual obligation to supply this increased pressure and historically observed pressures at Savona have dropped as low as 600 psig during periods of peak demand.

The graphs below show the required hourly and daily CNG truckloads at peak demand, with Savona at both 600 psig and at 650 psig. With Savona supplying gas to the ITS at 650 psig, and all other mitigation measures in place, FEI estimates that demand could be just met in the winter of 2023/2024 without CNG. By the winter of 2024/2025, even with Savona delivering gas at 650 psig, 13 to 16 truckloads of CNG per peak day (i.e., just under a truckload per peak hour) would be required to maintain system capacity at a minimum acceptable level. Note that this is a bestcase scenario, as FEI cannot rely on a pressure of 650 psig at Savona.

32 With Savona supplying gas to the ITS at 600 psig, a significant amount of CNG would be 33 required during peak conditions in the winter of 2023/2024. This requirement would escalate 34 rapidly over subsequent years as demand increases. In 2023/2024, FEI projects that 16 to 17 35 truckloads of CNG per day would be required, depending on whether injection is at Kelowna #1 36 Gate Station or at Polson Gate Station. This correlates to just below 1 truckload per peak hour. 37 By the winter of 2024/2025, 35 to 36 truckloads of CNG would be required every peak day, 38 corresponding to approximately 1.5 full truckloads per peak hour. Based on the forecasts above, 39 FEI's experience with CNG supplementation described in BCUC IR1 11.4.1 could be similar in



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
 Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 56

scope (20 to 24 truckloads of CNG per day compared to 16 to 36 truckloads per day) to what
 would be required in the winter of 2023/2024.

3 In reality, FEI is likely to experience a situation between these two extremes; pressures at 4 Savona are likely to fall between 600 to 650psig, meaning that the requirement for CNG during 5 a peak weather event would fall between zero and 16 truckloads per day in the winter of 2023/2024. However, to maintain reliable service to its customers, FEI must plan for the worst-6 7 case feasible scenario, which is a pressure of 600 psig at Savona coinciding with a peak cold 8 weather event. Therefore, should the OCU Project be delayed, FEI must be prepared to deploy 9 16 truckloads of CNG per day in the winter of 2023/2024, and 36 truckloads per day in the 10 winter of 2024/2025. As discussed in the response to BCUC IR1 11.1, FEI's operational 11 resources would be challenged to coordinate a response of this level during peak winter 12 conditions when they would already be called upon to implement other mitigation measures 13 such as operating manual station bypasses. As such, this solution is not reliable or practical, 14 and becomes rapidly less feasible as demand continues to increase over time.

15 The graphs below show the rapidly escalating requirement for CNG, should the installation of

16 the OCU Project be delayed. These numbers represent FEI's best approximation of the

17 projected supplementation.









- 1 2
- 3

- 4 5

8

9

11.3 Please discuss whether temporarily introducing CNG and/or LNG as a short term measure from 2022/23 could enhance the viability of any of the Project alternatives not selected by FEI, as outlined in section 4 of the Updated Application.

10 **Response:**

11 Temporary introduction of CNG and/or LNG from 2022/23 would not enhance the viability of the 12 other Project alternatives.

13 As discussed in responses to BCUC IR1 11.1 and 11.2, CNG/LNG injection is not a practical 14 long-term solution to address the increasing shortfall in the winters of 2023/2024 and beyond, 15 and becomes logistically infeasible in the years following. The timelines for proposed 16 Alternatives 4 and 5 fall outside of this timeline.

17 As discussed in Section 4.6.2.2 of the Updated Application, Alternatives 1 and 2 have a high 18 degree of risk associated with their schedules. Considering the additional risks and challenges 19 laid out in response to BCUC IR1 11.1, temporary use of CNG and/or LNG would not mitigate 20 the risk sufficiently to make either the preferred alternative.



- 1 2
- 2

5

6

7

11.4 Please describe in detail the reliability concerns associated with using a) CNG supplementation and b) LNG supplementation to meet demand on a peak day event.

8 **Response:**

9 a) Transportation via pipeline is more reliable than transportation via truck. Pipelines typically 10 have a very high availability and disruptions to pipeline supply are infrequent. A new pipeline 11 such as the proposed OLI PEN 406 extension will be unlikely to experience service 12 disruptions. Truck transportation is far more likely to be disrupted by events such as 13 inclement weather (which FEI would expect to be a significant factor should CNG be used to 14 supplement supply during peak winter conditions), traffic accidents, mechanical 15 breakdowns, road closures, heavy traffic, or dispatching issues. Traffic accidents and road 16 closures are frequent in the British Columbia Interior during winter conditions due to heavy 17 snowfall and ice causing dangerous driving conditions and poor visibility. The consequence 18 of delays to CNG trucks would be an inability to maintain system capacity, and a loss of 19 supply to customers during the coldest days of the year when demand is at its highest and 20 reliable gas service is most critical.

21 b) Concerns related to reliability of trucking are applicable to LNG as much as they are to CNG. 22 In this case, fewer trucks would be required due to the higher energy density of LNG when 23 compared to CNG. However, trucks would be required to travel much further (from FEI's 24 Tilbury LNG Facility in Delta, BC) and would be required to travel through the Coquihalla 25 Highway passes. Trucking does continue through this region in the winter, but delays and 26 road closures are frequent during the winter. According to the MOTI, the Coquihalla 27 Highway has closed entirely due to avalanche risk nearly once per year since its 28 construction. Vehicle incidents such as collisions and accidents due to weather conditions 29 cause highway closures even more frequently. As these closures typically occur during the 30 coldest days of the year, when LNG supplementation would be required, there is a high 31 probability that a road closure or accident would prevent LNG trucks from reliably reaching 32 the injection point in Kelowna or Vernon. The resulting capacity shortfall could lead to a loss of supply to customers during the coldest days of the year when demand is at its highest 33 34 and reliable gas service is most critical.

- 35
- 36
- 37
- 38 39

11.4.1 Please discuss FEI's experience with using CNG and LNG supplementation to meet peak demand elsewhere on its system.



1 Response:

2 **CNG Supplementation:**

FEI used CNG supplementation during the supply disruption resulting from the Enbridge pipeline failure in October 2018. FEI engaged a contractor who supplies and operates CNG equipment to assist maintaining gas supply while Enbridge repaired its pipeline. This was undertaken as an emergency response activity to events outside FEI's control (the Enbridge pipeline incident), and as a proof-of-concept for CNG backup during similar situations. It was materially different from delaying a required major capacity upgrade.

9 In this instance, a compression site was set up near Princeton. A temporary workspace was acquired to accommodate space requirements as the existing right-of-way space was insufficient. An electrical upgrade to the site was required to run the required two compressor units. These units were supplied by the CNG provider and tied into FEI's system at the Princeton location. Filling each truck at this site took approximately 1.5 to 2 hours.

A decompression site was set up at FEI's Bradshaw Station in Abbotsford and tied in to FEI's system. This site was selected due to a requirement for a significant amount of space for decompression equipment and trucks to allow up to three trucks to unload concurrently with staging room for a fourth. Site prep was required to accommodate the trucks and equipment trailers and, similar to the compression site, some electrical modifications were required.

19 CNG trucks filled at the Princeton compression site, then travelled to Abbotsford where trucks 20 could hook up to the decompression units for unloading. Typically, emptying each truck took up 21 to two hours. Approximately 20 to 24 trucks per day were moved over approximately 60 days 22 when the CNG supplementation operation was undertaken. Note that in this case, lower 23 reliability was acceptable as CNG trucking was not being used to support system pressures. 24 This proof of concept was primarily a gas supply exercise due to reduced throughput of the 25 Enbridge pipeline, and hence delays to trucks due to road conditions, logistical difficulties, or 26 any other reason would not have resulted in degradation of pressures and a corresponding loss 27 of supply to customers.

Therefore, there was less concern regarding the inherent reliability challenges associated with maintaining a steady supply via trucks during the winter. In this situation, CNG supplementation was a valuable tool to supplement gas supply, and a valuable proof-of-concept. However, as discussed in the response to BCUC IR1 11.1, the reduced reliability associated with trucking when compared to pipeline transport is not acceptable to FEI when a delay to the truck supply will cause uncontrolled pressure drops in the system and a resulting loss of supply to customers, as in the case of the OCU Project.

35 LNG Supplementation:

FEI used temporary LNG supplementation on the distribution system in Whistler, BC to mitigate a capacity shortfall while the permanent pipeline solution was implemented. The volume of gas



	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
C™	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 60

supplied via LNG was significantly less than what was transported via CNG truck during the
 Enbridge incident.

In this case, a temporary regasification and injection facility was set up in Whistler, consisting of a rented mobile regasification trailer, a rented ambient air mobile vaporization trailer, a pressure regulating station, and secondary containment for the LNG trailers. Trailers were filled at FEI's Tilbury LNG facility in Delta, B.C., and trucked to the regasification facility in Whistler where the trailers were parked next to the regasification trailer. The trailers were left attached to the regasification facility, and the LNG was vaporized as needed and injected into the system.



4

5

1 C. DESCRIPTION AND EVALUATION OF ALTERNATIVES

2 12.0 Reference: DESCRIPTION AND EVALUATION OF ALTERNATIVES

Exhibit B-1-2, Section 3.1, p. 11

ITS gas supply strategy

On page 11 of the Updated Application, FEI states:

6 FEI's ITS interconnects the gas supply from the Enbridge owned Westcoast 7 Energy System in the west (Westcoast system) and the TC Energy-owned 8 Foothills Pipeline in the east (TC Energy pipeline). Under typical conditions, gas 9 is taken from the Westcoast system at the Savona Compressor Station to supply 10 FEI's customers in the Thompson and north Okanagan Regions, while FEI's 11 customers in the south and central Okanagan Regions are supplied primarily by 12 the Southern Crossing Pipeline (SCP) supplying Oliver, which, in turn, supplies 13 pipelines delivering gas through the Penticton area.

- 14 12.1 Please describe FEI's current natural gas supply strategy for the ITS and how 15 this strategy is expected to evolve over the medium and long term.
- 16

17 <u>Response:</u>

FEI's natural gas strategy for the ITS is to develop a plan to ensure there are enough physical gas supply resources in the portfolio to meet the forecast load requirements for the customers served by ITS. This is achieved by not only evaluating the resources available to the Interior customers, but also to other service regions as well, specifically the Lower Mainland. This helps FEI design a robust gas supply portfolio that matches the load requirements of its customers in all service regions with secure and cost effective supply. The fundamental principles of constructing such a portfolio include:

- Meeting peaking and/or shorter duration load requirements with cost-effective on-system
 LNG storage resources or commercial peaking supply arrangements;
- Meeting short to medium duration seasonal load requirements (5-30 days) with offsystem underground storage, depending on its location and characteristics; and
- Contracting pipeline capacity to meet long duration load requirements as pipeline capacity is the most cost-effective method to supply gas over long periods (151 to 365 days).
- 32

As FEI obtains most of its natural gas from Station 2 in northeast BC via the Enbridge-owned
 Westcoast T-South system, its current gas supply strategy is to place more emphasis on
 diversifying its supply since the October 9, 2018 pipeline rupture and the capacity restrictions
 imposed thereafter on the Westcoast system.

FEI's current and medium-term strategy for Interior customers will be to continue to source incremental supply when required at the AECO/NIT and/or East Kootenay marketplace instead



	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
T.M	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
-	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 62

of sourcing more Station 2 supply. This is also a major reason why the OCU Project aligns with 1 2 FEI's broader gas supply strategy. Purchasing incremental supply at the AECO/NIT 3 marketplace requires FEI to hold additional pipeline capacity on TC Energy's NOVA Gas Transmission and Foothills pipeline systems for which FEI would pay fixed demand charges for 4 5 365 days each year. Given the seasonality and peaking demand of the Interior customers, FEI determined that the utilization of the incremental TC Energy pipeline would be low and not a 6 7 cost-effective gas supply strategy. Instead, FEI's gas supply strategy has been to contract peaking supply arrangements with counterparties to deliver AECO/NIT gas at the East 8 9 Kootenay interconnect. This option requires FEI to pay a call option premium to have the right to 10 receive gas at East Kootenay when it is required. The option is more cost effective than AECO/NIT supply and also provides operational flexibility to optimize the supply on a daily 11 12 basis. Further, FEI would only secure these types of commercial arrangements at East 13 Kootenay because they would be more costly at Savona and at Huntingdon. For example, 14 there is approximately 2.8 Bcf/day of gas flowing past East Kootenay on a daily basis 15 (approximately 1 Bcf/day more than at Huntingdon). Therefore, commercial arrangements are 16 more readily available at East Kootenay compared to its counterpart at Huntingdon. FEI will 17 continue to monitor the changes in the Interior demand and market conditions so that the 18 strategy can be adjusted in a timely manner to support gas supply objectives of shaping supply 19 to match demand with resources available in the marketplace.

FEI's long term gas supply strategy will continue to focus on improving diversity of supply, as 20 21 well as gas supply resiliency, while providing secure and cost-effective supply to FEI's customers. In order to achieve the objectives, FEI optimizes the gas supply portfolio on an 22 23 annual basis taking into consideration the changes in demand, supply, and resources available 24 in the region. The OCU Project also aligns with FEI's long term gas supply strategy discussed 25 in the proposed Tilbury LNG Storage Expansion Project CPCN Application⁵. For example, Figure 3-8 of the Updated Application shows that, with the OCU Project, there will be sufficient 26 27 capacity to support peak demand until 2029/2030. After that period, compressor station 28 upgrades to the SCP would be required based off the current forecast and if the Tilbury LNG 29 Storage Expansion is not approved. However, if the Tilbury LNG Storage Expansion is 30 approved, FEI could delay these compressor station upgrades for capacity related reasons from 2030 to beyond 2040, thereby potentially deferring approximately \$20 to \$30 million of capital 31 32 costs.⁶ This could be achieved because the additional LNG storage and gasification capabilities 33 at Tilbury would enable FEI to backfill supply into the Lower Mainland on extremely cold winter 34 days, while diverting AECO/NIT and East Kootenay supply to the BC Interior. This may also 35 involve reducing flows into Westcoast at Kingsvale to provide supply into the OCU Project 36 capacity at Oliver.

37

⁵ <u>https://www.bcuc.com/Documents/Proceedings/2021/DOC_60434_B-1-FEI-Tilbury-LNG-CPCN-Application-REDACTED.pdf.</u>

⁶ FEI notes that there could be other compression upgrades required in a 20 year horizon as a result of pipeline integrity, compressor unit reliability and/or emission reduction efforts, which could impact the timing and the approximate deferred capital costs discussed in this IR response.

FORTIS BC

	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
TM	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 63

1		
2	12.1.1	Please explain how each alternative for the OCU Project aligns with this
3		gas supply strategy.
4		
5	<u>Response:</u>	
6 7 8 9 10 11	The three alternatives strategy discussed in FEI in developing an they all require supply aligns with other FEI g discussed in the respo	that were deemed feasible for the OCU Project align with the gas supply the response to BCUC IR1 12.1. Each of the three alternatives assists efficient gas supply portfolio by enhancing its supply diversity given that from AECO/NIT, instead of from Station 2. Further, the OCU Project also gas supply projects, specifically the Tilbury LNG Storage Expansion, also nse to BCUC IR1 12.1.
12 13		
14 15	10.1.0	Diagon diagung whether EEI's breader and supply strategy for its optime
10 16	12.1.2	system is a consideration when planning capacity ungrades on the ITS
17		system is a consideration when planning capacity upgrades on the 113.
18	Response:	
10		
19	Please refer to the res	ponse to BCUC IR1 12.1.
20		



1 13.0 Reference: DESCRIPTION AND EVALUATION OF ALTERNATIVES

Exhibit B-1-2, Section 3.3, pp. 19-20

Capacity with the OCU Project

- 4 On page 20 of the Updated Application, FEI provides the Figure 3-8 illustrating both the 5 current capacity and the capacity of the ITS following completion of the OCU Project.
- 6 7

2

3

13.1 Please provide a graph similar to Figure 3-8 illustrating the capacity of the ITS with each Alternative.

8

9 Response:

10 The following graph shows Figure 3-8 with an additional line added to show the capacity of the 11 ITS after installation of each alternative. There is effectively no capacity difference between 12 Alternatives 1, 2, or 3 prior to a future capacity upgrade (such as a compressor upgrade at 13 Kitchener), so their capacity is shown as a single line indicating the point at which a 14 compression upgrade, or other capacity solution, as described in the response to BCUC IR1 15 14.3 will be required in 2029. The ITS capacities of each of Alternatives 1, 2, and 3 combined 16 with a future compressor station upgrade at Kitchener (but with no other upgrades) are also 17 shown in the graph.

18 The capacity of Alternative 4 with lateral upgrades in 2028, and Alternative 1 with the Kitchener 19 Compressor upgrade overlay each other on the graph and have sufficient capacity to 2031; 20 each would then require additional upgrades to meet the forecast. Alternative 5 and Alternative 21 2 with the Kitchener Compressor upgrade overlay each other on the graph; each would provide 22 sufficient capacity until 2034 and would then require additional upgrades. Alternative 3 with a 23 future Kitchener Compressor upgrade has capacity to meet the forecast demand beyond 2039. 24 This difference in the longer term ability to meet forecast demand illustrates the benefit of the 25 preferred Alternative 3 reinforcement in the south over the other alternatives.







13.2 Please describe the methodology and assumptions that FEI uses to calculate the ITS capacity with each Alternative.

9 Response:

5 6

7

8

10 FEI uses the same methodology and assumptions for assessing the capacity of each 11 alternative. Depending on the nature of the upgrade alternative, the constraints determining 12 capacity limits may differ. FEI first builds a hydraulic model of the ITS with the alternative represented. 13 Starting with the assumptions presented in Section 3.3.2 of the Updated 14 Application (i.e., that the available supply pressure into the system is set, and that the MOP pressure restrictions are respected), FEI creates a number of models that include the forecast 15 16 peak day loads and that represent each year in the forecast. For additional clarity, the models 17 consider the following:

The forecast peak day loads are added to the model at each delivery point (gate station)
 where gas enters the downstream intermediate and distribution pressure systems;



- The load is distributed among the delivery points to represent the demand of both current customers and the forecast new customers in each year; and
 - The model is repeatedly loaded with the forecast demand for each successive year until a system constraint is observed.
- 56 These system constraints manifest themselves either as:
 - An unacceptably low pressure condition that occurs either at a downstream regulating station or compressor station inlet; or
 - A lack of adequate compressor power at a compression station.
- 9 10

4

7

8

FEI considers the load on the system in the year the constraint is observed as the capacity limit of the system. This capacity limit is represented on the peak demand forecast plots as a horizontal line intersecting the demand forecast in the year the constraint is observed to occur. Although this is a simple and convenient way of representing system capacity, this method does not fully convey the complexity of the various interactions within the hydraulic model that determine the limiting constraint.

For the ITS, without upgrades, the capacity limit is reached (even with short-term mitigationmeasures in place) after the winter of 2022-2023.

19 Alternatives 1, 2, and 3 reinforce the system between Penticton and Kelowna, by eliminating a 20 bottleneck and allowing demand growth to be supported by gas delivered from Yahk on the 21 SCP to Oliver Y Control Station (Oliver) and then north into the Okanagan. The next constraint 22 on the system then appears in 2029. This constraint is insufficient inlet pressure at Oliver. The 23 constraint occurs because, by that time, the Kitchener Compressor, which moves gas westward 24 through the SCP, would no longer have sufficient power to deliver gas to Oliver with adequate 25 pressure to feed to pipelines that leave that facility (the Kingsvale Oliver pipeline, and the South 26 Okanagan Natural Gas pipeline that feeds the Alternative 1, 2, or 3 pipelines). Once this 27 constraint is removed (by adding additional compression), these OCU Project alternatives would 28 have additional capacity to meet the forecast load, as described in the response to BCUC IR1 29 13.1.

For Alternatives 4 and 5, the constraint that limits capacity will not initially be the Kitchener 30 31 Compressor power as those alternatives do not increase the flow (and power) requirements 32 through that facility to the same extent as Alternatives 1, 2, or 3. For Alternative 4, the 33 constraint occurs in 2031 and is because of low pressure upstream of the Kelowna #1 Gate 34 Station. At that time, an extension of the pipeline loop (or some other comparable upgrade) 35 would be required. For Alternative 5, the constraint would appear in 2034 and also because of 36 low pressure upstream of the Kelowna #1 Gate Station. In order to address the low pressure, 37 additional send-out on a peak day above the 51.44 MMscfd identified in the Updated Application 38 would be required. An expansion at the LNG site could accommodate the additional demand; 39 alternatively, to avoid expansion at the LNG site, FEI could consider other approaches such as 40 pipeline looping to support the available LNG send-out capacity.

FORTIS BC^{**}

1 2

3

4

5

6 7

8

FEI states on page 19 of the Updated Application that the Figure 3-8 shows that, with the OCU Project, there will be enough capacity to support peak demand until the winter of 2029/2030. FEI explains in Section 3.3.2.4 the compression upgrades that would be undertaken at that time to further support peak demand to the end of the 20 year forecast period without extending the OCU Project pipeline.

- 9 13.3 Please describe any assessments to determine the feasibility of upgrading the 10 compression capability to support peak demand to the end of the 20 year 11 forecast period, including engineering and cost studies and provide the results of 12 these assessments.
- 13

14 <u>Response:</u>

15 FEI initially considered including a compression upgrade at the existing Kitchener B compressor 16 station within the scope of the OCU Project. This upgrade was based on the minimum 17 requirements to meet the forecast 20-year capacity needs based on current operations, as 18 envisioned when development of the Project started. The response to BCUC IR1 14.3 explains 19 the rationale for removing this item from the final scope of work for the OCU Project, and the 20 unknowns associated with future compression requirements. Based on this rationale and other 21 learnings since, FEI no longer considers the assessments done to date to be valid or 22 representative of FEI's future requirements.



3

1 14.0 Reference: DESCRIPTION AND EVALUATION OF ALTERNATIVES

Exhibit B-1-2, Section 3.3.2.4, p. 26

Future Compressor Upgrades

4 On page 26 of the Updated Application, FEI states:

- 5 Based on the current forecast, by the summer of 2029 FEI will need to upgrade 6 the compression capability on the SCP to improve capacity into the Central and 7 North Okanagan. FEI is currently considering several possible options to 8 increase compression capability on the SCP to meet a variety of possible future 9 needs. As the compression requirement to address future capacity needs in the 10 Okanagan is several years beyond the immediate need for the OCU Project, and 11 the optimal location and extent of required additional compression cannot yet be 12 determined, FEI did not include a compressor upgrade in the OCU Project. Compressor requirements to satisfy the longer term capacity needs would be 13 14 included, as needed, as part of any expansion project contemplated on the SCP.
- 14.1 Please explain when FEI expects to be able to provide additional information
 about any future project(s) to increase compression capability on the SCP,
 including project overview, timing, or anticipated cost.
- 18

19 Response:

FEI is not able to provide the requested information at this time because future SCP compression requirements could change as resource developments in the region unfold over time. Further, as explained in the response to BCUC IR1 12.1, the recently filed Tilbury LNG Storage Expansion Project CPCN Application, if approved, could also impact the solution and timing of the potential compression upgrade.

FEI will monitor and assess future upgrades and/or extensions to SCP as part of its long-term infrastructure planning and related developments in the region.

14.2

14.2.1 If so, please provide details of any new pipelines required and any existing pipelines requiring recertification.

Please discuss whether any FEI options to increase the compression capability

on the SCP would require new transmission pipelines or recertification of any

36 **Response:**

37 Options that improve compression capability could significantly increase the capacity of the SCP

existing transmission pipelines to a higher pressure.

to flow gas from Yahk to Oliver without recertifying the pipelines to higher pressures or requiring

FORTIS BC^{**}

new pipelines in that corridor. The OCU Project Alternatives 1, 2 or 3 are examples that would
move more gas north from Oliver though the SCP with enhanced compression. To move the
gas westward beyond Oliver, FEI would encounter capacity constraints; therefore, new pipelines
would be considered as part of any expansion project contemplated on the SCP.

- 5
- 6
- 7
- 8 9 10

11

14.3 Please explain why compression upgrades on the SCP are planned to address future capacity needs in the Okanagan (beyond 2029) and not the immediate need identified for the OCU Project.

12 **Response:**

13 The need for the OCU Project cannot be deferred by advancing the future compression 14 additions alone; the proposed pipeline is a necessary first step. The planned compression 15 upgrade, in isolation, cannot address the forecast capacity shortfall as the VER PEN 323 16 pipeline, operating at its current MOP, acts as a bottleneck in the system between Penticton and 17 Kelowna. Increasing compression upstream of the VER PEN 323 pipeline, to provide the 18 capability to improve the upstream system pressures and move more gas into the pipeline 19 toward the Okanagan, does little to alleviate the capacity shortfall. This is because the pressure 20 reduction that must be applied at the Ellis Creek Control Station and the high pressure loss in the length of the existing VER PEN 323 pipeline between Penticton (Ellis Creek) and Kelowna 21 22 would not allow any improvement in flow and pressure to be delivered as far as Kelowna in the 23 existing system. In effect, this downstream portion of the system would operate in the same way 24 as it currently does with the same constraint. Until FEI addresses the ability to move more gas from Penticton to the north at a lower rate of pressure drop per kilometre, the system cannot 25 26 take advantage of improved compression at Kitchener - or anywhere else upstream of the 27 proposed OLI PEN 406 Extension.

If the Updated Application is not approved, and as a result the OCU Project is not in service by the winter of 2023/2024 as planned, the result would be insufficient system capacity to serve customers in the region. Further, without the OCU Project, the future compressor upgrade would not be required, as installing compression alone would not improve the low pressure at stations serving FEI's customers in the north and central Okanagan.

33 FEI has chosen to not include the future compression requirements in the scope of the OCU 34 Project, as FEI will be better able to ensure that the compressor upgrade that ultimately 35 proceeds is appropriate for the needs of the ITS at that time. If this upgrade were included in the 36 scope of the OCU Project, FEI could be left with compression assets that integrate poorly or do 37 not support future needs effectively. In this case, a second upgrade project would likely be 38 required, potentially moving compressor units to a new location more appropriate for the 39 evolving system needs. Also, as discussed in the response to BCUC IR1 12.1, if the Tilbury 40 LNG Storage Expansion Project is approved, FEI could delay these compressor station 41 upgrades for capacity related reasons. As a result, FEI does not yet have all the information



1 necessary to optimize the sizing and location of the needed compressor upgrade. Since the 2 compressor upgrade is not required immediately, and cannot be used to defer the pipeline 3 upgrade if installed at this time, FEI determined that the most cost-effective solution for the OCU 4 Project is to plan future compression upgrades on the SCP to address capacity needs on the 5 ITS as they develop.

- 6
- 7
- _
- 8 9
- 10
- 11 12

14.4 If the Updated Application were not approved as applied for, what would the implications be, if any, on the need or timing of future compressor upgrades on the SCP? Please discuss.

13 **Response:**

Please refer to the response to BCUC IR1 14.3. Advancing the timeline for the compression upgrade cannot defer the need for the OCU Project pipeline upgrade, and deferring the pipeline upgrade will not delay the requirement for a compression upgrade.

- 17
- 18
- 18
- 19
- 2014.5Please discuss how the future expansion of compression capability on the SCP21and FEI's overall vision for expanding system capacity in the Okanagan factored22in FEI's decision-making when determining which alternative should be proposed23for the OCU Project.
- 24
- 25 **Response:**

Alternatives 1, 2, and 3 all enable FEI to maximize the use of the existing SCP pipeline system capacity and align with FEI's overall gas supply strategy. The need for compression will be addressed at a later point in the forecast period to ensure that the project is designed and scheduled appropriately to meet FEI's evolving customer demand needs. Please also refer to the response to BCUC IR1 12.1.



1	15.0	Refere	ence: I	DESCRIPTION AND EVALUATION OF ALTERNATIVES
2			E	Exhibit B-1-2, Section 4.1.2, p. 32
3			(Compression Option
4		On pa	ge 32 of t	he Updated Application, FEI states:
5 6 7			In order alternati Natural	to meet the Project's objectives, FEI identified and investigated five ves, including four pipeline installation options and an LNG (Liquefied Gas) storage/peak shaving option.
8 9		15.1	Please Okanag	discuss whether FEI considered adding compression to the ITS in the an area as a possible alternative to meet the OCU Project's objectives.
10 11 12			15.1.1	If yes, please describe any assessments to determine the feasibility of installing compression on the existing ITS, including engineering and cost studies and provide the results of these assessments.
13 14 15			15.1.2	If yes, please explain why FEI did not identify a compression option as a Project alternative.
16	<u>Respo</u>	nse:		
47		مراماتها.		en edding edditional communer facilities within the Covers to Doutistor

No, FEI did not consider adding additional compressor facilities within the Savona to Penticton corridor as an alternative to meet the OCU Project objectives. Due to the high variability in system load over the peak day period on the system and due to the system being broken into several different segments with different MOP constraints, FEI determined a compressor alternative to be operationally infeasible.

The system configuration and load profile would not allow a compressor to operate continuously for any period of time, resulting in frequent starts and stops of the compressor. A critical period for compressor operations is start up and shut down. There is a high possibility on any startup sequence that it will initially be unsuccessful which delays the ability of the compressor to address system peak requirements reliably. The resulting intermittent operation would not be feasible for managing peak day system loads and line pack.

28 Additionally the compressors do not provide operational benefits outside of peak days in winter. 29 For example, compressors do not add line pack to the system as the OCU Project pipeline will. 30 Increasing the available line pack provides a significant benefit for FEI Gas Control in managing 31 gas supply in daily operation of the system throughout the year. A compression alternative 32 similarly would not provide line pack in summer to support operations and maintenance work on 33 the system that the other alternatives considered can provide. Compressors suitable for 34 operation under peak demand would not be in operation when system demand is low and when 35 such operations work is performed.

Finally, a compressor alternative would be difficult to expand to address future load growth beyond the forecast period. The operating pressure reduction within the greater Kelowna area


to 4,654 kPa (675 psig)⁷ would become the next bottleneck to capacity on the ITS to serve the
 Okanagan region that a compression alternative could not address. Extending the pipeline

2 Okanagan region that a compression alternative could not address. Extending the pipeline 3 looping would be required to address this, and building on the proposed Alternative 3 loop

4 provides a means that could address peak demand growth beyond the current forecast.

5 For these reasons, FEI did not include additional compression facilities within the Thompson 6 and Okanagan regions for consideration as an alternative to address the current capacity 7 constraint.

⁷ See line 3 in Table 3-1 of the Updated Application.



3

1 16.0 Reference: DESCRIPTION AND EVALUATION OF ALTERNATIVES

Exhibit B-1-2, Section 4.2.1, p. 34

Savona Compressor Station

4 On page 34 of the Updated Application, FEI states:

5 FEI has established a working agreement with Enbridge to maintain a minimum 6 delivery pressure into Savona of 4480 kPag (650 psig) on peak days. This is 345 7 kPag (50 psig) higher than FEI's normal expected minimum delivery pressure at 8 Savona. This will improve pressure into the north and central Okanagan and is 9 required in the winter of 2021-22 and 2022-23 in advance of the completion of 10 the OCU Project, but is not sufficient on its own to mitigate forecast peak demand 11 in those winters.

12 16.1 Please provide the historical minimum delivery pressure into Savona on peak13 days for the past five years.

15 **Response:**

16 The following table shows the lowest hourly delivery pressure from the Enbridge-owned 17 Westcoast system at Savona for the coldest day in each of the last five years. In December 18 2016, Enbridge was conducting mid-winter in-line inspection on its system resulting in the 19 pressure dropping below 600 psig on the coldest day of December 16, 2016. The table also 20 shows the next coldest day for 2016 when pressures remained above 600 psig.

21

14

Minimum Delivery Pressure into Savona Tap on Coldest Days 2016-2020

Year	Date	Kelowna Temp (ºC)	Kelowna DD	Lowest Savona Tap Pressure (psig) in the Morning Peak Hour
2016	2016-12-16	-17.5	35.5	556
2010	2016-12-14	-16.9	34.9	617
2017	2017-01-11	-17.8	35.8	615
2018	2018-02-21	-13.6	31.6	624
2019	2019-02-05	-15.8	33.8	694
2020	2020-01-14	-18.9	36.9	755

22

23 24

- -

25 26

27

16.1.1 Please provide the current capacity of Savona Compressor Station. Please provide any assumptions made in determining current capacity, including the inlet pressure to the compressor station.



1 Response:

2 The FEI Savona Compressor Station is located approximately 3.7 km east of the Savona tap off 3 the Enbridge system. The station is equipped with two identical Solar Turbines Saturn 20 gas 4 turbine compressors. After allowing for piping and thermal losses, and mechanical efficiency, 5 the actual available horsepower from each unit is 1,550 HP. Therefore, the total power output of the Savona Compressor station is 3,100 HP. The highest discharge pressure is 960 psig. The 6 7 expected minimum delivery pressure of 600 psig into the Savona tap off the Enbridge system is 8 assumed. However, due to the 3.7 km distance between the Savona tap and the compressor 9 station, the pressure at the suction side of the compressors would be lower than 600 psig. At 10 the forecast peak demand in 2039-2040 with Alternative 3, the suction pressure of the station 11 with the Savona tap pressure at 600 psig is about 563 psig. When operating at the full 3,100 12 HP, the compressors would discharge at 892 psig.

17.0 **DESCRIPTION AND EVALUATION OF ALTERNATIVES** 1 **Reference:** 2 Exhibit B-1-2, Section 4.3.2, pp. 39-40 3 Alternative 2 – Modified ITS Upgrades to VER PEN 323 4 On pages 39 and 40 of the Updated Application, FEI provides the following description 5 of Alternative 2: 6 This alternative proposes the installation of a 6 km 406 mm pipeline extension of 7 OLI PEN 406 (SONG pipeline built in 1994) around the City of Penticton. The 6 8 km long extension proposed under this alternative eliminates the requirement to 9 replace and/or retest multiple segments from the southern end of Alternative 1.... 10 This alternative would require a new regulating station with a 406 mm receiving 11 barrel to be built at the northern end of the extension where the new 406 mm 12 pipeline would tie-in to the existing VER PEN 323, as the two pipelines do not 13 operate at the same MOP. All upgrades that are part of Alternative 1 which are 14 located north of the tie-in would still be required under Alternative 2; this equates 15 to replacement of 3.9 km of existing VER PEN 323 with new higher strength 323 mm pipeline followed by hydrotesting of the VER PEN 323 located north of the 16 17 tie-in location to the proposed end point of upgrades so that the pipeline can be recertified to operate at a MOP of 6,619 kPa. 18

- 19Further on page 40, FEI states that Alternative 2 would need to be completed in its20entirety prior to the winter of 2023/2024 to avoid a capacity shortfall.
- 2117.1Please explain how FEI determined that Alternative 2 would need to be22completed in its entirety prior to the winter of 2023/2024 to avoid a capacity23shortfall.

25 **Response:**

24

26 To make this determination, FEI created a model of the ITS with the 6 km loop installed, but 27 without the necessary upgrades to the VER PEN 323 pipeline. In this scenario, the pressure in 28 the VER PEN 323 pipeline cannot be increased as rehydrotesting would not have been 29 completed. The winter 2023/2024 demand forecast scenario was then run using this model. The 30 results showed projected pressures at key points in the ITS (such as the inlets to the Kelowna 31 #1 and Polson Gate Stations) dropped below FEI's acceptable thresholds. Therefore, in 32 isolation, installation of the 6 km pipeline extension does not provide a sufficient pressure 33 increase to the system to maintain capacity for the winter of 2023/2024.

34 It is not practical to increase pressure in the VER PEN 323 pipeline in stages; to avoid the 35 unnecessary cost of installing additional pressure control facilities, rehydrotesting must be fully 36 completed along the length of the pipeline from the 6 km extension tie-in point to the northern 37 tie-in point before the operating pressure can be increased.

1 2

3 4

5

6

7

	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
тм	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
-	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 76

17.1.1 Please describe any assessments to determine the ITS capacity with only the 6 km 406 mm pipeline extension and the new regulating station completed prior to the winter of 2023/2024.

8 Response:

9 While it would be possible from a scheduling perspective to complete a 6 km pipeline extension 10 and new regulating station prior to the winter of 2023/2024, this would not address the capacity 11 need for the Project. FEI's system capacity models demonstrate that without increasing the 12 pressure in the VER PEN 323 pipeline, which would require rehydrotesting to be complete, the 13 capacity shortfall cannot be met in the winter of 2023/2024. Please also refer to the response to 14 BCUC IR1 17.1.

- 15
- 16
- 17

18

19

- 17.2 Please discuss the feasibility of completing the 6 km 406 mm pipeline extension and the new regulating station prior to the winter of 2023/2024 and upgrading VER PEN 323 later.
- 20 21

22 **Response:**

Please refer to the responses to BCUC IR1 17.1 and IR 17.1.1, which explain why this scenario
 would not meet the required timelines for the necessary capacity increase.

25 Alternative 2 must be completed in its entirety prior to the winter of 2023/2024 in order to 26 maintain adequate capacity on the ITS. Completion of the 6 km pipeline extension and the new 27 regulating station would not be sufficient to address the capacity shortfall. FEI's timeline for 28 rehydrotesting and rehabilitating the VER PEN 323 pipeline remains uncertain, which makes 29 planning a staged approach challenging. The length of time required to complete hydrotesting 30 and any associated repairs is not known, and this uncertainty adds a high level of risk to planning and executing a staged project. Even if FEI determines a method of supplying the 31 32 system for the winter of 2023/2024, such as the use of CNG, there is no guarantee that the VER 33 PEN 323 pipeline would be fit for service at a higher pressure by the next winter. This could 34 leave FEI without any available mitigation measures, and customer demand which could not be 35 met.

1 18.0 Reference: DESCRIPTION AND EVALUATION OF ALTERNATIVES

2 3

Exhibit B-1-2, Section 4.3.3, p. 41

Alternative 3 – OLI PEN 406 Extension

On page 41 of the Updated Application, FEI states Alternative 3 involves the addition of
approximately 30 km of 406 mm pipeline running from OLI PEN 406 (SONG pipeline
built in 1994) east of Ellis Creek near Penticton to Chute Lake northeast of Naramata.

- 7
- 8 9

18.1 Please explain how FEI determined the pipeline length for Alternative 3.

- 18.1.1 Please describe any assessments to determine the optimal pipeline length of the OLI PEN 406 Extension, including engineering and cost studies and provide the results of these assessments.
- 10 11

12 **Response:**

13 The objective of the proposed pipeline is to overcome the capacity restriction in the VER PEN 14 323 pipeline between Penticton and Kelowna by moving the pressure control station (currently 15 at Ellis Creek in Penticton) supplying gas into the pipeline at 750 psig to a point far enough 16 north to provide the required capacity. FEI determined a project scope for Alternative 3 that 17 could meet or exceed the current 20-year forecast and which could be built on with 18 complementary projects to meet demand growth beyond the forecast horizon. To provide 19 sufficient capacity to exceed the 20-year forecast, the point for supplying gas into the VER PEN 20 323 pipeline at 750 psig needed to be 28 kilometres north of the current location. The length of 21 the proposed pipeline cannot be shortened without advancing the time that a future capacity 22 constraint would occur in the current 20-year forecast period. This is because a shorter pipeline 23 would leave a longer length of the smaller existing VER PEN 323 pipeline carrying the peak gas 24 demand, resulting in a higher pressure loss and advancing the time when the low pressure 25 constraint appears. The critical factor for increasing the system capacity is the tie-in location of 26 the new Chute Lake Station on the existing VER PEN 323, and not the length or diameter of the 27 new pipeline being installed to the tie in point. In order to accommodate a variety of project 28 needs the proposed pipeline has an alignment that extends more than 28 kilometres before it 29 intersects with the VER PEN pipeline. The additional length does not impact the ability of the 30 Project to meet the 20-year forecast.

31 FEI has identified a project similar to Alternative 3 in its long term plans for many years. The 32 project was first mentioned in the Terasen Gas Inc. 2004 Resource Plan and was described as 33 a 23 kilometre NPS 20 pipeline with a projected in-service date prior to winter 2010-2011. In the 34 intervening years the project scope and timing evolved along with new peak demand forecasts. 35 In the 2017 LTGRP, the project was described as a 28 kilometre NPS 20 pipeline with a 36 required in-service date prior to the winter of 2022-2023. The additional 5-kilometre length 37 provided the additional capacity to support the 20-year peak demand forecast available at that 38 time.

As Alternative 3 for the OCU Project moved into a higher level of development, aspects of the project other than length were also assessed. The minimum length of the pipeline was fixed as



	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
_ ™	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
_	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 78

described above, but the pipe diameter required could vary. The pipe needed to be large 1 2 enough to deliver gas from the OLI PEN 406 while retaining sufficient pressure at the end point 3 to deliver 750 psig gas into the VER PEN 323 pipeline, with additional pressure available to 4 allow it to be extended in future if required. As mentioned, earlier forms of the project 5 suggested an NPS 20 (508mm) pipeline. As the new pipeline would tie into the existing SONG pipeline, an NPS 16 (406mm) pipeline, FEI explored extending the smaller diameter NPS 16 6 7 pipe. The assessment determined that an NPS 16 extension to the SONG pipeline could 8 provide sufficient capacity to meet the current project need and be capable of being extended 9 further north if needed to meet future needs. The selection of the NPS 16 pipe provides 10 benefits by reducing the Project cost and improving the efficiency of pipeline integrity activities. 11 The pipeline will form a continuous run of NPS 16 pipeline between Oliver and the new Chute 12 Lake Station that can be inspected in a single uninterrupted in-line inspection (ILI) run.

13 14 15 16 Please discuss whether there is an opportunity for FEI to extend the OLI PEN 18.2 17 406 beyond the OCU Project to further support peak demand on the ITS. 18 18.2.1 If yes, please explain whether this option is identified in the Updated 19 Application. 20 18.2.1.1 If not, why not? 21 22 Response: 23 Please refer to the response to BCUC IR1 18.1. 24 25 26 27 Please discuss whether there is an opportunity for FEI to reduce OCU Project 18.3 28 costs by reducing the length of OLI PEN 406 Extension, while still meeting the 29 primary project objectives. 30 31 **Response:** 32 Please refer to the response to BCUC IR1 18.1. 33 34 35 36 18.4 Please discuss any potential OCU Project scheduling risks (permitting or 37 construction) that factored in FEI's decision making when determining the 38 pipeline length for Alternative 3. 39



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 79

1 Response:

- 2 As described in the response to BCUC IR1 18.1, the critical length for determining the pipe
- 3 length was the location of the tie in point which, within reasonable margins, was not affected by
- 4 the length of the new pipeline being installed. This allows the Project some margin to adjust the
- 5 pipeline length to avoid alignments that may create scheduling risk.

1 19.0 Reference: DESCRIPTION AND EVALUATION OF ALTERNATIVES

2 3

4

Exhibit B-1-2, Section 3.3.2.1, p. 24, Section 4.3.4, p. 42

Alternative 4 – 508 mm Loop from Savona

On page 24 of the Updated Application, FEI states:

5 FEI designs the ITS to deliver a minimum inlet pressure of 2415 kPag (350 psig) 6 into the major gate stations serving downstream Intermediate Pressure (IP) 7 systems on a peak day. This minimum pressure is the parameter that defines the 8 ITS capacity limit. This minimum pressure is identified as the primary capacity 9 constraint for this region in order to maintain a 350 kPag (50 psig) working 10 pressure differential across Polson Gate Station and Kelowna #1 Gate Station 11 that supply IP systems that operate at 2070 kPag (300 psig), supplying 12 thousands of customers.

On page 42 of the Updated Application, FEI states, "The fourth alternative to address the
 capacity constraint involves the installation of a 508 mm loop starting at the Savona
 Compressor Station and running eastward for approximately 68.4 km before terminating
 east of Kamloops."

17 18

19

19.1 Please explain how FEI determined the 508 mm diameter and 68.4 km length for the pipeline starting at Savona Compressor Station proposed as Alternative 4.

20 Response:

21 The determination of project scope for Alternative 4 was consistent with the approach described 22 for Alternative 3 in the response to BCUC IR1 18.1. FEI determined the length of the loop for 23 Alternative 4 by moving the point on the existing SAV VER 323 pipeline where the new control 24 station could deliver gas from the new pipeline loop into the existing pipeline to increase the 25 pressure closer to the higher load centres in the Okanagan. The diameter of the new pipe was 26 fixed at NPS 20 to match the existing pipe size between the Enbridge Compressor facilities and 27 tap location at Savona and the suction of FEI's Savona Compressor Station (approximately 4 28 kilometres to the east). The length of NPS 20 looping identified met the 20-year requirements of 29 previous peak demand forecasts. As explained in the response to BCUC IR1 13.1, this 30 alternative would require additional enhancement by 2031 to meet updated peak demand 31 forecasts.

- 33
- 34 35
- 19.1.1 Please provide the capacity of the pipeline solution proposed in Alternative 4, in both mmscfd and TJ/d units.
- 36 37



1 Response:

2 The capacity of Alternative 4 is approximately 372 TJ per day or 342 MMscfd, as illustrated in 3 the figure in the response to BCUC IR1 13.1.

4		
5		
6		
7	19.1.2	To the extent it is feasible, for each year in the forecast period (2021-
8		2039), please provide the forecasted inlet pressures on a peak day at
9		each major gate station within the ITS if the pipeline proposed in
10		Alternative 4 were to be installed.
11		

12 Response:

13 The table below shows the forecast inlet pressure for each major gate station within the ITS for

14 the period 2021 to 2035, if the pipeline proposed in Alternative 4 were to be installed by 2023.

15 As indicated in the response to BCUC IR1 19.1, Alternative 4 would need additional upgrades in

16 2031 in order continue to maintain the inlet pressures to these gate stations above the 350 psig

17 minimum requirement.

18

Upstream Pressure at Major Okanagan IP Gate Stations

Year	Kamloops #1	Polson	Kelowna #1	Kelowna - Cary Rd
	psig	psig	psig	psig
2021	640	297	316	377
2022	622	245	268	341
2023	746	445	430	486
2024	744	426	406	468
2025	743	414	391	458
2026	739	399	373	445
2027	734	383	354	431
2028	729	391	396	416
2029	724	380	373	400
2030	720	363	355	384
2031	715	345	336	367
2032	710	327	317	350
2033	705	307	295	333
2034	701	287	274	315
2035	697	265	251	296

FortisBC Energy Inc. (FEI or the Company)Submission Date:Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)March 4, 2021Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1Page 82

20.0 **DESCRIPTION AND EVALUATION OF ALTERNATIVES** 1 **Reference:** 2 Exhibit B-1-2, Section 4.4.2.1, p. 45 3 **Alternative 4 Discussion and Analysis** 4 On page 45 of the Updated Application, FEI states: 5 Alternative 4 would meet one of the objectives for this project: to increase the 6 capacity of ITS. However, the length and diameter of this pipeline would trigger 7 an environmental assessment (EA). The anticipated timeline for completion of an 8 EA is three years. Please describe the regulatory process and associated time frame for completion 9 20.1 10 of each stage of an EA, from early consultation to project approval, and compare 11 this to the regulatory process for the same project if the pipeline would not trigger 12 an EA. 13 14 Response: 15 The provincial environmental assessment (EA) process prescribed by the 2018 Environmental 16 Assessment Act and associated regulations and guidance documents (depicted and described 17 in detail available at the following link: https://www2.gov.bc.ca/gov/content/environment/natural-18 resource-stewardship/environmental-assessments/the-environmental-assessment-process/2018-act-19 environmental-assessment-process) includes five Environmental Assessment Office (EAO) led

20 activities with a cumulative 570 day legislated maximum period (approximately 19 months) and

21 two approval periods with no legislated time limit.

In addition to the approximately 19 month legislated period, there are two proponent-led phases of the EA process, Early Engagement and Application Development, which both require a substantial period of time to properly complete. FEI's experience, as confirmed by its consultants, is that it is appropriate to allocate at least 12 months for each of these items (approximately 24 months total).



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 83

Summary of the Process from Early Engagement to Post-Certificate⁸



2

FEI notes that the combined legislated and proponent period is approximately 45 months (reflecting some periods of the process without legislated time limits). This schedule assumes that the various opportunities to obtain consensus with participating Indigenous communities proceed in a timely manner and that there are no events that lead the EAO, the proponent, or a participating Indigenous community to request a pause in timing to address a technical issue, undertake studies to collect additional data, clarify assessment findings, or resolve disputes

9 related to process or lack of consensus.

Further, FEI provides a simplified regulatory process diagram below which compares a
 hypothetical linear pipeline project with and without an Environmental Assessment Certificate

12 being required.

⁸ EAO User Guide, Version 1.01. <u>https://www2.gov.bc.ca/assets/gov/environment/natural-resource-stewardship/environmental-assessments/guidance-documents/2018-act/eao_user_guide_v101_march_2020.pdf.</u>



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 84

Simplified Comparison of Linear Pipeline Project

(with and without an EAC)

			EAC	
Time (Months)		EA Certificate	BCUC CPCN	BCOGC Permits
			(
3			Early E	
6			ngagem rent wit	
9			ent h EA)	
12				
15		2		
18		ω		
21			Or	
24			ngoing En	
27			gagemen	
30			t (via EA p	
33			orocess)	
36				
39				
42		5		
45		6	Regulat	
48			tory Proc	
51			ess	
54			Dec'n	BCOG
57				GC Permit
CO				< S.
υu				

No EAC									
BCUC CPCN	BCOGC Permits								
Early Engagement									
Regulatory Process									
Dec'n	Е								
	3COGC Permits>								

	LEGEND
1	EA Early Engagement
2	EA Readiness Decision
3	EA Process Planning
4	EA Application and Review
5	EA Effects Assessement and Recommendation
6	EA Decision
7	EA Post Cerfiticate Activities (contingent on project)
8	BCUC CPCN Process
9	BCOGC Permit Process



Although simplified in the above diagram, BCOGC pre-permitting processes require further detailed engineering, preparation of environmental management plans, engagement with Indigenous groups and compilation of an application. Upon submission, BCOGC staff conduct in-depth technical review and carry out Indigenous consultation. Finally, the BCOGC makes a determination on the permit and informs affected land owners and Indigenous groups.

- 6 7 8 9 20.2 Please explain how FEI determined that the anticipated timeline for completion of 10 an EA is three years. 11 20.2.1 Please compare FEI's anticipated timeline for completion of an EA with 12 any legislated timelines within the Environmental Assessment Act or 13 with any timelines proposed by the Environmental Assessment Office 14 for the completion of an EA. 15 16 Response: 17 FEI's recent experience along with general guidance provided by external consultants, which
- 18 takes into account the legislated timelines, suggests that, at minimum, it is possible to obtain an
- 19 EA Certificate within three years although it typically takes longer. Please also refer to the
- 20 response to BCUC IR1 20.1.



3

1 21.0 Reference: DESCRIPTION AND EVALUATION OF ALTERNATIVES

Exhibit B-1-2, Section 4.4.2.2, p.45

Alternative 5

4 On page 45 of the Updated Application, FEI states:

- 5 Alternative 5 would meet the capacity objective for this project. However, 6 preliminary research indicates that this alternative would be significantly too 7 complex to design and construct prior to the winter of 2023/2024. An estimated 8 minimum of five years is required to design and execute construction of such a 9 facility following CPCN approval, pushing the completion date to 2027, or likely 10 later.
- 1121.1Please describe the design and construction process and associated time frame12for completion of each stage of Alternative 5, from early consultation to project13commissioning.

15 **Response:**

14

A Level 1 schedule, reproduced below, shows how the timelines associated with Alternative 5 were not able to meet the Project need in time to address the capacity shortfall. Combined with the expected high-level costs (please also refer to the response to BCUC IR1 21.2), these led FEI to discard Alternative 5 early in the screening process. As such, further definition of the information requested is not available.

Please note that the "... minimum of five years..." mentioned on page 45 of the Update Application represents the beginning of the Engineering task through to the end of the Construction task in the Level 1 Schedule below, and assumes CPCN approval would occur in Q4 2021.

Tool Mana		Duration		2019	1	2020		2021		2022		2023		2024		2025	2026			2027		2028		20:
Task Name		Duration	H2	H1	H2	H1	H2	H1	H2	H1	H2	H1	H2	H1	H2	H1	H2	H1	H2	H1	H2	H1	H2	Н
Interior LNG Facility		2788 day	s 📂																					
E CPCN Development		630 days																						
CPCN Application Dev	velopment and R	eview 477 days	i																					
Engineering		265 days	i i																					
Permitting		850 days	i							-														
Procurement		370 days	i																					
		1105 day	8																					
Schedule Contingency		18 mths																						
21.2	Plassa	evolain whe	ather F		ha	d c		sic		'n	ar	214	ad	diti	on		he	no	fite		201	nci:	ate	Ъ
21.2	with on-	system LNC	S storag	ge t	tha	t m	hay	be	e p	os	sib	le i	for	Alt	eri	nat	ive	e 5.			550	5010	ale	;u
	21.2.1	lf not, plea	ise exp	lair	ר w	hy	no	t.																

	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
SC.	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 87

1 2

- 21.2.2 If yes, please describe any studies FEI conducted and provide the results of these assessments.
- 3 4 Bosp

4 <u>Response:</u>

5 Additional benefits associated with on-system LNG storage were considered early in the 6 screening process, but no detailed studies of these potential benefits were undertaken due to 7 reasons mentioned below.

8 The preliminary Class 5 estimate produced for the OCU Project (see Table 4-2 in the OCU 9 CPCN Application, reproduced below) indicated that this alternative could be up to five times the 10 cost of the least expensive alternative identified. As a result of this and the lengthy execution 11 schedule (as discussed in the response to BCUC IR1 21.1) that indicated this alternative was 12 not feasible in the timeline required, FEI did not undertake further investigation of this 13 alternative.

Alternative	Description	Total Pipe Installed (km)	Capital Cost Estimate (2019\$ Millions)
1	ITS Upgrades to VER PEN 323	15	40 to 100
2	Modified ITS Upgrades to VER PEN 323	19	50 to 130
3	OLI PEN 406 Extension	30	100 to 250
4	508 mm Loop from Savona	54	200 to 500
5	LNG Facility Near Vernon	n/a	250 to 600



1 22.0 Reference: DESCRIPTION AND EVALUATION OF ALTERNATIVES

2 Exhibit B-1-2, Section 4.1, p. 32; Section 4.6.1, p. 49 3 Asset Management Capability Alternative Evaluation 4 On page 32 of the Updated Application, FEI states that the OCU Project has the 5 following project objectives: 6 1. Increase the delivery capacity of the ITS to meet peak demand requirements and 7 to maintain safe and reliable gas service to FEI customers in the central and 8 north Okanagan regions; and 9 2. Ensure all construction related activities are completed in time for the winter of 2023/2024 to avoid service interruptions to customers. 10

11 On page 49, FEI provides Table 4-5 which shows Asset Management Capability 12 Alternative Evaluation criterion and associated weighting.

Alternative 2: Alternative 3: OLI Alternative 1: ITS Upgrades Score Weighting Modified ITS Upgrades Score Criterion PEN 406 Extension Score System Capacity Increase 50% 5 2 3 **Operational Flexibility** 50% 4 Weighted Total:* 100% 3.5 4.0 4.5

Table 4-5: Asset Management Capability Alternative Evaluation

13

14 15

16 17

- 22.1 Please provide further details on FEI's OCU Project objective of increasing the delivery capacity of the ITS to meet peak demand requirements. For example, is the objective of the OCU Project to meet peak demand requirements in the winter of 2023/2024, winter of 2029/2030 or over the entire 20 year forecast period?
- 18 19

20 Response:

FEI's OCU Project objectives are both to construct a solution that can support the increased ITS peak demand requirements over the 20 year forecast period, and to ensure that the Project is completed in time for the winter of 2023/2024 to maintain safe and reliable gas service and avoid any service interruptions to its customers.

- 25
- 26
- 27
- 28 22.2 Please explain how FEI defines and measures "operational flexibility" in its
 29 Alternative evaluation.
- 30



1 Response:

2 Operational flexibility focuses on the additional options that an alternative provides FEI to deal 3 with unexpected situations. This could include a greater ability to respond to pipeline 4 emergencies, such as third-party, seismic, or hydrological damage, or undertaking maintenance 5 activities while still allowing FEI to provide continuous delivery of safe and reliable energy.

6 Currently, gas supplied to the greater Kelowna region passes through the existing VER PEN 7 323 pipeline from Penticton towards Kelowna. In the Project area, the pipeline travels through 8 urban, rural, mountainous, and agricultural land, and crosses multiple watercourses. Each of 9 these environments expose the pipeline to potential risks that could result in damage, requiring 10 a pressure reduction or pipeline shut-in.

A major driver to reducing this risk and providing operational flexibility is having multiple paths through which the gas can travel to its destination – also referred to as pipeline looping. By having multiple paths, some or all of the gas can still reach its destination should flow through one of the paths be reduced or shut off. Thus, alternatives that provide multiple routes for the gas to travel received higher operational flexibility scores:

- Alternative 1 would result in only a single path (the existing VER PEN 323), so any capacity reduction or outage would affect the entire line, limiting FEI's options in an emergency.
- Alternative 2 would result in looping of the area through Penticton, resulting in two paths for that part of the system: one that can carry the full required capacity (the new OLI PEN 406 extension), and one that can carry a portion of the required capacity (the old VER PEN 323). If a disruption to the OLI PEN 406 extension occurred during warmer or non-peak times, the old pipeline could still supply some or all of the required gas.
- Alternative 3 will result in looping the entire length, resulting in the same benefits as Alternative 2, but extending them over the entire length of the Project area, and not limited to the area around Mount Campbell.
- 27
- 28
- 29
 30 22.3 Please discuss whether FEI considered including resiliency of the ITS as a
 31 criterion in its evaluation of alternatives.
- 32 33

22.3.1 If not, why not?

34 **Response:**

Yes, FEI considered including resiliency of the ITS but did not select it as one of the evaluationcriteria for the reasons mentioned below.

In particular, FEI considered whether certain alternatives could increase the percentage of gas in the ITS sourced from the TC Energy system, thereby reducing FEI's reliance on the



1 Enbridge-owned Westcoast system. Reduced reliance on a single source increases a system's 2 ability to manage supply in the event of a disruption to that source, improving resiliency. 3 However, when compared against each other, none of the three feasible alternatives provided a 4 significant change to the gas balance in the system and thus did not represent a considerable 5 resiliency benefit. Additionally, all three feasible alternatives were nearly identical from a 6 resiliency perspective. As such FEI determined that this was not a valuable metric for 7 comparison.

8 Increasing the operational flexibility of the system provides FEI with an improved ability to shut 9 in portions of its system either for planned work or if required for emergency response. Thus 10 improved operational flexibility is tied to a corresponding improvement in system resiliency.

- 11
- 12
- 13
- 14 22.4 Please explain in detail FEI's rationale for the System Capacity Increase 15 weighting of 50 percent, given that the primary objective of the OCU Project is to 16 meet peak demand requirements.
- 17 18 Response:

FEI's alternative evaluation followed a two-step process. Alternatives were initially screened 19 20 against the Project objectives, which included an increase to the ITS capacity to meet forecast 21 peak demand requirements and to ensure that the Project is completed in time for the winter of 22 2023/2024 to avoid service interruptions to customers.. Essentially, for an alternative to meet 23 Project objectives, it was required to provide sufficient transmission pipeline capacity for the 20-24 year forecast period (assuming necessary compression upgrades could be completed as 25 required). Thus, any project alternative which passed initial screening was capable of providing 26 the minimum required capacity benefit to the system.

27 The System Capacity Increase criterion would place a higher value on alternatives which 28 provided a greater capacity increase above and beyond the minimum threshold set by the 29 primary Project objectives. However, since all feasible alternatives which passed initial 30 screening provided a similar capacity increase to the system, all three received the same score.

31 Since the requirement set by the first step of the evaluation process guaranteed a sufficient 32 capacity benefit, FEI's team agreed that any additional capacity increase is of equal value to 33 increases in operational flexibility.

34 35 36 37 22.5 Please discuss how the Asset Management Capability Alternative Evaluation 38 criterion and associated weighting were determined. 39



1 Response:

The evaluation criteria and associated weightings were developed by an internal team of FEI
subject matter experts, including representatives from the Asset Management, Engineering,
Project Management, Regulatory Affairs, Community and Indigenous Relations, Environmental

- 5 Management, and Property Services departments.
- 6 All parties considered which evaluation criteria were the most important from their perspective, 7 using a template of proposed evaluation criteria to record their input. A workshop was then held 8 to incorporate input from experts in each individual group to determine a set of evaluation 9 criteria and associated weightings for the OCU Project. This provided the basis for the 10 evaluation criteria and weightings selected. Evaluation criteria were further refined as the 11 Project progressed and the Project team's understanding of the specific needs of the Project 12 improved.
- 13
- 14
- 15
- 16 17
- 22.6 Please discuss whether FEI applies the criterion and associated weighting shown in the preamble to its other capacity upgrade projects.
- 1822.6.1If not, please provide the Asset Management Capability Alternative19Evaluation criterion and associated weighting FEI used in other capacity20upgrade projects.
- 21

22 Response:

FEI has not had any recent major projects that were capacity driven. Other recent major projects have been driven either by integrity concerns, third-party work, or resiliency.

As such, for each major project, FEI defines the key drivers and impacts of a project and, comparing it to representative past projects that FEI has undertaken, identifies the evaluation criteria to further assess feasible project alternatives. FEI deliberately limits the number of criteria for a given project to ensure that the key drivers to decision making are not diluted by less applicable criteria.

FORTIS BC^{**}

2

3

4

FortisBC Energy Inc. (FEI or the Company)Submission Date:Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)March 4, 2021Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1Page 92

1 23.0 Reference: DESCRIPTION AND EVALUATION OF ALTERNATIVES

Exhibit B-1-2, Section 4.6.2.2, p. 53

Alternative 1 & 2 – VER PEN 323 retesting

- On page 53 of the Updated Application, FEI states:
- 5 Testing this pipe to a significantly higher level of stress than in 1957 leads to 6 uncertainty about FEI's ability to successfully carry out the regualification tests. 7 This presents a significant scheduling risk to the implementation of Alternative 1 8 or Alternative 2. Retesting promotes opening of existing cracks that are near 9 failure so that they fail during the test and can be removed from the system. 10 However, to complicate matters, it may also promote growth of small cracks that 11 would have otherwise been acceptable, resulting in a new set of critical cracks 12 left in the system after completion of the repairs. These new critical cracks may 13 fail during the subsequent attempt at a successful test, resulting in a cycle of leak 14 detection, repair and testing.
- 15 23.1 Please confirm whether FEI is able to conduct inline inspections on the VER PEN
 16 323 pipeline.
- 17 18

23.1.1 If confirmed, please discuss the overall integrity of the VER PEN 323 pipeline based on the inline inspection results.

19 20 <u>Response:</u>

FEI is able to conduct in-line inspections (ILI) on the VER PEN 323 pipeline to locate and size imperfections including geometric (e.g., dents, wrinkles, and buckles) and metal loss (e.g., corrosion and gouges) features. FEI is not currently able to conduct ILI on the VER PEN 323 pipeline to identify cracking imperfections, but is developing the ITS Transmission Integrity Management Capabilities (TIMC) project to make the necessary system and pipeline alterations to allow the use of crack detection tools (FEI anticipates to file this application in 2022).

FEI interprets the term "overall integrity" as referring to FEI's knowledge of the entire VER PEN 323 pipeline based on its condition monitoring activities, which include an assessment of known time-dependent threats of corrosion and cracking. FEI's assessment of the overall integrity of the VER PEN 323 pipeline, based on current knowledge, is that it is suitable for continued service and that with current and planned ongoing integrity management activities it will remain appropriate for safe and reliable operations.

FEI's current integrity management activities identified geometric and metal loss imperfections on the VER PEN 323 pipeline. These known imperfections on the VER PEN 323 pipeline are managed through recurring ILI and associated integrity dig activities, supplemented by sitespecific repairs where required. ILI is an industry-preferred integrity management methodology as it enables operators to mitigate the potential for rupture and leak failures and supports active and proactive monitoring of ongoing threats. ILI also provides cost-effective integrity management because it identifies imperfections or defects at site-specific locations that can be



1 repaired, reducing the need for large-scale and costly system-level pipeline rehabilitation efforts

2 (such as pipeline replacement).

FEI's current integrity management activities have also identified cracking imperfections on the
VER PEN 323 pipeline through opportunity digs. However, due to the limited lengths of pipe that
have been exposed relative to the full length of buried pipelines, the opportunity digs are not
expected to have identified all cases of cracking.

- •
- 8
- 9 10

11

23.2 Please discuss FEI's assessment of the likelihood that the VER PEN 323 pipeline has "existing cracks that are near failure so that they fail during the test."

12 **Response:**

FEI believes there is a reasonable likelihood that the VER PEN 323 pipeline has "existing cracks that are near failure so that they fail during the test". As such, OCU Project alternatives that would involve re-hydrotesting have been appropriately evaluated with a low score of 1. This evaluation is based on:

- FEI's observations of cracking imperfections on the VER PEN 323 pipeline during previous opportunity digs;
- Knowledge of the original pressure test being limited to 110 percent of the design pressure in accordance with the industry standard in 1957 (and not the current standard of 125 percent); and,
- An industry-recognized potential for crack-like imperfections in seam welds on vintage
 pipelines (i.e., pipelines constructed prior to 1970).
- 24



PROJECT DESCRIPTION 1 D.

2	24.0 Refe	erence:	PROJECT DESCRIPTION
3			Exhibit B-1-2, Section 5.6.1, p. 78
4			Project delivery method
5	On p	bage 78 d	of the Updated Application, FEI states:
6 7 8 9 10 11		Given that u and ir a serv These contra	the scale and scope of the Project, FEI will use a project delivery method tilizes separate contracts for engineering design, construction management espection, and construction. The engineering design will be completed using vices contract for the complete design and development of bid packages. The bid packages will then be used to seek competitive pricing from actors for the construction of the works.
12 13 14 15	24.1 <u>Response:</u>	Pleas other	e discuss whether FEI has used the selected project delivery method for projects of this scale and scope.
16 17 18 19 20 21 22 23	FEI has su separate c construction utilized se Managemen Pressure S three gas I scope of ea	uccessful ontracts n on the eparate nt) and system U ine proje ich projec	ly used a design-bid-build (DBB) project delivery method that utilized for engineering design, construction management and inspection, and Inland Gas Upgrades (IGU), and a similar design-bid-build approach that contracts for EPCM (Engineering, Procurement and Construction construction on two other projects, the Lower Mainland Intermediate pgrade (LMIPSU), and the Coastal Transmission System (CTS). These cts are of similar scale and share similar characteristics but the specific et is unique and was required to address a particular need.
~ 1			

24			
25			
26			
27		24.1.1	If no, please explain the rationale for the selection of the OCU Project
28			delivery method.
29			
30	Response:		
31	Please refer t	to the resp	ponse to BCUC IR1 24.1.
32			
33			
34			
35		24.1.2	Please discuss the pros and cons of the selected delivery method with
36			respect to the allocation of risks related to cost escalation and schedule
37			between FEI and its consultants or contractors.



2 Response:

- 3 In a DBB delivery method, the risk for design is allocated to the designer and the risk for
- 4 construction is allocated to the contractor. The following table highlights the pros and cons of
- 5 the DBB delivery method as it relates to cost escalation and schedule.

	ation	
Pros		Cons
 In DBB the design is completed to 10 percent prior to bid, so the risk of cost escalation due to change orders requ design changes during construction is minimal. 	0 • t iring	Because the contractor had no input into the design, the risk of cost escalation due to change orders that result from design changes increases during the execution phase.
 The DBB delivery method is a well established and widely used method is pipeline projects that do not have a seconstraint or other major execution rist the risk of cost escalation, if contracted is not incorporated, is minimal as in or alternate delivery methods. There are no major technology risks Project, so the likelihood of cost escal due to errors and omissions that arise the completed design are minimal. FEI and the design firm have a better understanding of the permit requirem commence the works for the Project, is minimal cost escalation risk due to works permits in this method. 100 percent design and tender doc thereby minimizing the risk of differing conditions cost escalation and change. 	 to deliver chedule sks, so or's input ther with the lation e from ents to so there notice of pletely e those uments g site e orders. 	Since the contractor had no input on constructability during design, there is a possibility of cost escalation to address constructability issues and site conditions during execution. There is a risk that some municipal permits require contractor input that if not addressed before contract start could cause cost escalation. A contractor may have a better means and method to address certain site conditions which if not accounted for in the design, may cause a cost escalation by requiring a design change.



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 96

Scheo	dule
Pros	Cons
 Once the design is 100 percent completed the contractor takes responsibility to complete the work on an agreed to schedule within a specified time, subject to certain exceptions that allow for an extension of time, meaning there is little risk to the contracted schedule completion date. The designer has the opportunity to include all known requirements in the design minimizing the risk to schedule impacts during construction - although there could be some minor schedule impact while design is being finalized to obtain as much site information as possible. All permits can be applied for before construction commences reducing the impact to the schedule. 	 If the constructability issues result in significant modification to the design, the contractor's extension of time request can be lengthy causing a schedule delay that may be addressed by having the contractor accelerate works but at a cost to FEI. Some permits may benefit from contractor's knowledge and not having contractor input can delay the start date for site activities. Certain site conditions may benefit from contractor input and if not considered could cause minor schedule delay.

A DBB delivery method is suitable for the OCU Project because there is sufficient time available

3 to complete the engineering design, then bid and award the construction contract and meet the

4 schedule. The DBB delivery method also provides FEI the ability to tender the construction

5 work package after design risks are mitigated and addressed in the design package.



1	25.0	Refere	nce:	PROJECT DESCRIPTION
2				Exhibit B-1-2, Section 5.4.2.8, p.72
3				Water Crossings
4		On pag	ge 72 of	the Updated Application, FEI states:
5 6 7			All pip method identifi	eline crossings within the Project will be constructed using open cut ds with the exception of Penticton Creek. In general, the types of crossings ed along the proposed OLI PEN 406 pipeline route include:
8		•	Road (Crossings;
9		•	Water	Crossings; and
10		•	Pipelin	e and Utility Crossings.
11 12		25.1	Please	identify all Water Crossings along the proposed OLI PEN pipeline route.
13	<u>Respo</u>	onse:		
14 15	Please pipelin	e refer to le route.	Attach	ment 25.1 for a list of all water crossings along the proposed OLI PEN 406
16 17				
18 19 20 21 22		25.2	Please Crossii choosi	e describe the construction methods FEI considered for each Water ng along the OLI PEN pipeline route and explain the primary reason(s) for ng the proposed crossing method.
23	Respo	onse:		
24 25 26 27 28 29	FEI co route o identifi constru sensiti alterna	nsidered during th ied that uction th ve enviru ative cro	d sever ne 30 p all wat nrough ronmen ossing r	al crossing methods for water crossings along the OLI PEN 406 extension bercent design stage of the Project. Other than Penticton Creek, FEI has er crossings will be crossed using an open trench method. Open trench water crossings is the traditional installation method for pipelines in less ts where construction space is not constrained. During detailed design, methods such as trenchless methods may be chosen for selected water

30 crossings in consultation with the environmental consultant and Indigenous groups.

Open trench water crossing construction is commonly planned in conjunction with a dam and pump dewatering method while trenchless crossing construction is commonly planned using HDD or boring. The tables below illustrates the advantages and disadvantages of each type of crossing construction method.



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 98

Crossing Method Analysis – Open Trench

Advantages	Disadvantages
 Cost – Open trench construction requires minimal specialized equipment, typically a smaller crew and easier design philosophy resulting in a lower cost impact compared to a trenchless construction method. Schedule – Commonly available equipment (excavator) and high constructible design result in a quick installation process, reducing the overall crossing construction duration. Operations and maintenance – The pipeline is located close enough to the surface such that it can be excavated in the future should the need occur. 	 Environmental – An Environment Impact Assessment is required to be completed in accordance with the environmental codes and recommended guidelines. Schedule – Depending on aquatic habitat findings (e.g., fish spawning/migration, food supplies, silt build up, etc.) short timing windows could be enforced, thus limiting the construction window. Construction – Isolation and de-watering techniques may be required.
Crossing Method	Analysis – HDD
Advantages	Disadvantages
 Environmental – No instream / riparian zone work, as minimal impact to the water body occurs (under normal conditions). Schedule – More flexible construction timing window. HDD can avoid congested or environmentally sensitive areas, if properly completed. Operations and maintenance – Pipe located at a lower depth of installation can limit future risks associated with exposure from scouring during freshet. Routing – HDD can reduce construction challenges leading up to water crossings. For example, an HDD method could be used in relation to existing utility infrastructure, nearby road crossings, and avoid construction on steep slope embankments. 	 Cost – Requires specialized equipment and skilled workers, hence the use of trenchless crossings is typically more expensive than open trench excavation. The drilling process must be continuously monitored and controlled, requiring highly skilled operators. Crew Resources – Acquiring and scheduling the specialized equipment, materials, and crew could cause scheduling complications (longer lead times or lower availability). Environmental – Drilling in soft or shallow soil areas increases the risk of drilling fluid being released into the waterway. Failure Risk – HDD activities have an inherent risk from uncertain subsurface conditions along the drill path, which increases cost and schedule risks due to potential failed attempt(s).

2

3

4

1 26.0 Reference: PROJECT DESCRIPTION

Exhibit B-1-2, Section 5.6.5, p.79; Section 5.10.4.4, p.90

Penticton Creek Horizontal Directional Drill (HDD) Installation

- On page 79 of the Updated Application, FEI states:
- 5 The main objective of the early works construction phase is to complete the HDD 6 [horizontal directional drill] work. While the feasibility study concluded that HDD is 7 a feasible option to cross Penticton Creek, there is still a risk that the HDD 8 installation could be unsuccessful. FEI plans to address the risk as soon as 9 possible in the Project to allow adequate time to implement the contingency plan 10 of using an open trenching method across the drainage within the mainline 11 contractor's scope of work.
- 12 On page 90, FEI explains:
- 13 There is a high risk to the Project should the HDD fail, as the contingency plan 14 consists of attempting a subsequent drill, and failing that the plan is to open 15 trench across a very steep ravine. FEI and SMCI have identified an open trench 16 route across Penticton Creek and this option is currently under evaluation. FEI 17 will proceed with the design and permitting of both the HDD and the open trench 18 options to minimize delays should the HDD prove not feasible. Table 5-12 19 outlines the range of possible outcomes stemming from an unsuccessful HDD 20 across Penticton Creek.
- 26.1 Please provide details of any construction challenges with the proposed
 Penticton Creek HDD installation and explain how these challenges factored into
 FEI's decision to complete the HDD as part of its early works construction phase.
- 25 **Response:**

24

As explained in section 5.10.4.4 of the Updated Application:

27 The preliminary feasibility assessment completed by TerraHDD, a company 28 specializing in HDD concluded that the Project could drill a path under Penticton 29 Creek. HDD at this location minimizes stakeholder and environmental impacts 30 and is the lowest cost option for the Project. Significant geotechnical work was 31 undertaken to evaluate the feasibility of HDD but there is always uncertainty 32 remaining as most of the subsurface conditions along the drill path cannot be 33 fully assessed. Therefore, the success of HDD is not realized until the drilling is 34 complete and the pipe is pulled into the hole.

The preliminary geotechnical feasibility assessment was made based on an intensive desktop study, a field drilling investigation program including four deep exploration holes, and a geophysics survey for the contemplated HDD area. The assessment indicated that installation of the pipe via HDD is feasible, but there are construction risks associated with the geotechnical



1 conditions in this area. These conditions include the presence of highly fractured rock, rock 2 formations that vary significantly in their strength, and a thick overburden of sandy and gravely 3 soils with cobbles and boulders. In addition to the risks associated with these conditions, there 4 is subsurface risk associated with the unknown ground conditions, which is an inherent risk to 5 any HDD project, especially those with a long drilling path. Such risk arises from the fact that it 6 is not possible, within practical economic limits, to have a detailed geotechnical characterization 7 of each and every soil and rock formation along the HDD drilling path.

8 FEI scheduled the HDD to commence during the early works phase primarily for the following9 two reasons:

- The design, permitting and various plans required to complete the HDD are mostly
 independent from the mainline activities and can easily be advanced during the detailed
 design phase to advance construction activities.
- Completing the HDD early in the Project will allow FEI to confirm the risk and better
 position the Project for future works. If the HDD is not successful, FEI will have sufficient
 time to properly plan and implement the contingency plan (open trench construction).

While FEI indicated in the Updated Application that an HDD is the preferred option across
Penticton Creek, that may change during detailed design. If the open trench option proves
more feasible than the HDD during detailed design, FEI may proceed with an open trench cut as
the preferred option, with the HDD as the contingency plan.

21

16

- 22
- 22
- 23
 24 26.2 Please discuss any potential environmental and public impacts associated with
 25 an HDD failure.
- 26

27 **Response:**

There are two potential failure mechanisms associated with HDD construction: failure to successfully complete the HDD bore, or an inadvertent release of drilling fluid to the environment during drilling. The potential environmental and public impacts for each are explained below. FEI would not expect any of the impacts to result in long-term harm to the public or environment, as mitigation measures will be utilized to address outcomes from potential HDD failures.

For an HDD bore failure, there is potential for surface water to infiltrate the ground water through the conduit created by the abandoned drill hole. The potential environmental impact associated with this failure is a change to local hydraulic conditions and ground settling if the hole were to collapse. This potential environment impact would be mitigated by filling the drill hole with grout as described in the response to BCUC IR1 26.3. Additionally, if the HDD is unsuccessful and open trench construction is required, in-stream works would be required to install the pipe across Penticton Creek.



For an inadvertent release of drilling fluid to the environment, the potential environmental impacts are drilling fluid pooling on land and/or drilling fluid being released to Penticton Creek. Drilling fluid, a mixture of bentonite clay and water, is considered chemically benign, however due to its small particle size, releases to an aquatic habitat have the potential to harm fish and other organisms. In this situation, FEI would mobilize cleanup crews to collect drilling fluid releases and restore impacted habitat.

While there are potential environmental and public impacts associated with an HDD failure, the benefits of a successful HDD are that the environmental and public impacts are minimized compared to an open trench cut. For HDD work taking place on the Project, FEI will conduct a thorough feasibility assessment to understand the probability of success before attempting an HDD and, as noted earlier, will utilize mitigation measures to address the outcomes of an HDD failure.

- 13
- 14
- 15

16

17

18

- 26.3 Please describe how the drill hole would be abandoned if HDD installation is unsuccessful and quantify any associated abandonment costs.
- 19 **Response:**

Should the HDD installation be unsuccessful and the drill attempt need to be abandoned, FEI would complete appropriate activities to abandon the HDD. The driller would remove any accessible materials from the site and fill the drill bore with grout in stages to limit impact to the environment by way of inadvertent release through fractures. This abandonment process would limit any future impacts to the environment and public by limiting collapse and non-natural water channels for surface or ground water.

26 The associated abandonment costs are estimated to be approximately \$650 thousand.

27 28		
29		
30	26.4	Please discuss any changes to the pipeline alignment crossing Penticton Creek
31		should the HDD fail.
32		
33	<u>Response:</u>	
34	FEI is active	y developing an alternate route alignment that would use a conventional open
35	trench crossir	ng of Penticton Creek should the HDD crossing be determined not feasible during

35 trench crossing of Penticton Creek should the HDD crossing be determined not feasible during 36 detailed design, or if the HDD fails during construction. FEI completed preliminary route 37 selection for the alternate alignment during the Class 3 cost estimate phase. The preliminary 38 route is shown in the figure below.



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 102

Alternate Open Trench Crossing of Penticton Creek



2

3 The proposed alternate alignment construction would utilize open trench excavation and 4 installation for the entire length. Although the open trench crossing alignment measures 5 approximately 850 metres from crest to crest, the actual pipeline length is approximately 2,300 6 metres.

FORTIS BC^{**}

1	27.0	Refere	ence:	PROJECT DESCRIPTION			
2				Exhibit B-1-2, p. 82			
3				Kettle Valley Rail Trail			
4	On page 82 of the Updated Application, FEI states:						
5 6 7 8	The Kettle Valley Rail Trail (KVR) is a national historical site located in Naramat and runs in parallel with some sections of the OCU Project route. The KVR is popular among cyclists who want to bike from Naramata to Kelowna. As such FEI has recognized the importance of this historical site in its Project planning.						
9 10 11 12		27.1	Please be requ run para	provide a summary of any permits or land access agreements which will ired for any segments of the OLI PEN 406 proposed pipeline that cross or allel to the KVR.			
13	<u>Respo</u>	onse:					
14 15 16 17 18	In addition to applying to the BCOGC for a pipeline construction permit, FEI will apply to the Recreation Sites and Trails BC (RSTBC) branch of the Ministry of Forests Lands Natural Resource Operations and Rural Development (MFLNRORD) for an authorization under section 16 of the <i>Forest Recreation Regulation</i> under the <i>Forest and Range Practices Act</i> to conduct Project related activities within the proximity of the KVR Trail.						
19 20 21 22	In 2020, FEI began engaging with the RSTBC branch of MFLNRORD to confirm the permit application requirements. The Project team is currently compiling the deliverables for the application. The application submission is anticipated in Q2 2021 with approval anticipated by late Q4 2021.						
23 24							
25 26 27 28 29	Respo	onse:	27.1.1	Please provide an update on the status of these permits or land access agreements.			
30	Please refer to the response to BCLIC IR1 27.1						
31 32							
33 34 35 36			27.1.2	Please discuss the risk of delay to the Project Schedule due to permitting regarding the KVR.			



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 104

1 Response:

There is a low risk of delay to the Project schedule due to permitting regarding the KVR. FEI has commenced the compilation of the permit application requirements as described in BCUC IR 27.1 and plans to submit it in Q2 2021. The permit approval process is expected to take approximately six months and is expected to be obtained in time for construction start in Q4

6 2021. In the unlikely event the permit approval process takes longer, FEI's contingency plan is

7 to commence work in other areas that do not require a permit from the KVR authority.



9

1 28.0 Reference: PROJECT DESCRIPTION

Exhibit B-1-2, Section 5.9.6, p.85

- 3 Other Pending or Anticipated Application/Conditions
- On page 85 of the Updated Application, FEI states that it "expects the Project will
 not require an Environmental Assessment Certificate under the BC
 Environmental Assessment Act."
- 7 28.1 Please explain why FEI expects the OCU Project will not require an
 8 Environmental Assessment Certificate.

10 Response:

- 11 The BC *Environmental Assessment Act* and the Reviewable Projects Regulation state that 12 natural gas transmission pipelines that meet the following relevant guidelines are reviewable 13 projects:
- A project with diameter of greater than 323.9 mm (12.75 inches) and a length of 40 km or greater, if the land on which the pipeline is built is not alongside and contiguous to an area of land previously for a transmission line, transmission pipeline, public highway or railway, or
- If the project would meet the threshold if the threshold was reduced by 15 percent (i.e. 34 km)
- 20

Despite having a diameter of 406 mm (16 inches), the total length of the preferred alternative is 30 km, and approximately 80 percent parallels existing linear corridors such as existing electric and gas rights of way and roads. Therefore, the preferred alternative for the OCU Project will not require an Environmental Assessment Certificate.

- 25
- 26
- _0
- 27
 28 28.2 Please discuss the potential impact to OCU Project schedule if an Environmental 29 Assessment Certificate is required.
- 30
- 31 **Response:**

32 FEI's expectation is that the Project would be delayed by approximately three years if an 33 Environmental Assessment Certificate was required for the OCU Project.



1 29.0 Reference: PROJECT DESCRIPTION

Exhibit B-1-2, Section 5.10.4.4, p. 90

Market risk

- 4 On page 90 of the Updated Application, FEI states, "FEI identified that there is a 5 market risk to the Project due to factors such as contractor capacity, the 6 availability of qualified pipeline contractors in 2022 and 2023 and market risk 7 where bids are uncompetitive."
 - 29.1 Please elaborate on the information or experience FEI relied upon in identifying this market risk.
- 9 10

8

2

3

11 Response:

FEI relied on a check estimate prepared by Innovative Pipeline Projects Ltd., Calgary AB, to understand the uncertainty in the market risk associated with contractor capability and availability when the OCU Project is planned to be constructed in 2022-2023. Since the check estimate suggested that there could be an uplift in bid prices, FEI undertook a reserve risk analysis to address the uncertainty and included an amount as a management reserve in the unlikely event the market risk materializes.

18
19
20
29.1.1 Please explain whether FEI has re-evaluated the market risk since its initial risk analysis. If yes, please discuss any changes to market risk. If not, why not.
24
25 <u>Response:</u>
26 FEI has not formally to evaluated the market risk beyond what was submitted in the Undeted

26 FEI has not formally re-evaluated the market risk beyond what was submitted in the Updated 27 Application. Management of risk is a continuous process throughout a project's lifecycle and 28 FEI continues to monitor all the Project risks, with treatment applied as appropriate. A treatment 29 currently being applied is FEI's continuous engagement with contractors for all projects within 30 the Major Projects portfolio. This will enable FEI to identify early any changes to contractor 31 capacity and availability. With respect to a re-evaluation of risks (termed risk quantification), this 32 is ordinarily done at a phase gate or key milestones or if a significant event or threat is identified 33 during risk monitoring. Currently, FEI plans to re-evaluate the market risk at the design 34 completion milestone scheduled for August 2021.

- 35
 - 36
- 37
- 29.2 Please explain what impact the identified market risks may have on the OCU
 39 Project schedule.



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 107

4 5

6 7

2 Response:

3 There is no schedule impact associated with the market risk, as it is purely a financial risk.

8 9

10 11 **Response:** 29.2.1 Please discuss whether any risks to the OCU Project schedule are accounted for in the assessment of the Management Reserve amount. If so, how?

The risks to the OCU Project schedule are not accounted for in the Management Reserve. The Management Reserve in the Updated Application is a dollar amount to cover the likely cost impacts should bids be higher than the Class 3 estimate. This impact is funded as a cost Management Reserve because should the risk materialize, the magnitude of the impact would consume the Project's contingency and thus the risk cannot be effectively managed using contingency. The risk impact to the schedule is mitigated as described in the response to BCUC IR1 29.2.


1	30.0	Refere	nce:	PROJECT DESCRIPTION
2				Exhibit B-1-2, Section 5.4.4, p. 74
3				Pipeline Deactivation
4		On pag	je 74 o	f the Updated Application, FEI states:
5 6			A 1,20 Ellis C	00 m section of the existing OLI PEN 406 will be deactivated between the creek tie-in point and the existing Ellis Creek Pressure Control Station.
7 8 9 10			This work onto the onto the onto the onto the onto the ontot onto the ontot on	vill include removing a section of pipe at the tie-in location, welding a cap he deactivated section, installing a blind at the inlet to the Ellis Creek ure Control Station, purging the line and maintaining a low pressure blanket itrogen.
11 12 13 14 15			Deacti minim establ require planni	ivation of this section of OLI PEN 406 was chosen over abandonment to ize ecological and socio-economic disturbance to the area and allow re- ishment of gas supply to the Ellis Creek Pressure Control Station if ed in the future to support forecast peak demand beyond the 20 year ng window. Deactivation will follow all regulatory and code requirements.
16 17		30.1	Please OLI Pl	e confirm, or explain otherwise, that, after the deactivation of this section of EN 406, this portion of the assets will also be removed from FEI's ratebase.

19 Response:

Not confirmed. As described in the response to BCUC IR1 30.5, FEI requires the ability to reactivate this pipeline section as part of future integrity management activities. The value to FEI of the right-of-way and pipeline is significant as it provides flexibility for integrity management activities for no incremental cost.

The BCUC in its Decision and Order G-246-20, dated October 5, 2020 on BC Hydro's F2020 to F2021 Revenue Requirements Application approved for inclusion in BC Hydro's rate base the costs of the West End Vancouver Purchase (the East End Vancouver Land Purchase was approved in the BC Hydro F2017 to F2019 RRA Decision) which was to advance two substation construction projects. In reaching its decision, the BCUC Panel referenced a previous BCUC decision regarding the Waneta Dam transaction:⁹

In the Waneta Decision, the BCUC, identified two exceptions to the Used and Useful principle set out above, namely that assets which are not currently physical (sic) used and useful in utility service may still be "Used and Useful", and therefore included in rate base, if they are "expected to be used in the reasonably foreseeable future", or if a portion of the asset is needed now, and the remainder "may not be needed for quite some time."

⁹ Page 91. Also refer to BCUC Order G-130-18, BCUC Decision to the BC Hydro Waneta 2017 Transaction Application, page 71.

FORTIS BC

1 2 3 4 30.2 Please provide the amount of depreciation remaining to be recorded on this 5 section of pipeline and the remaining useful life of the asset. 6

7 <u>Response:</u>

- 8 The asset value, accumulated depreciation, and net book value of the OLI PEN 406 pipeline,
- 9 and the portion of the 1,200 m section that is to be deactivated is provided in the following table.

		\$000's				
Length	Particulars	Acquisition Value	Accumulated Depreciation	Net Book Value		
	OLI PEN 406mm Pipeline					
	Land Rights	\$2,298	\$176	\$2,122		
31.873km	TP Transmission Mains	33,261	15,369	17,892		
	Total	\$35,559	\$15,545	\$20,014		
	Deactivated Portion					
	Land Rights ¹	\$18	\$1	\$17		
1.2km	TP Transmission Mains	1,252	599	653		
	Total	\$1,270	\$600	\$670		

10 <u>Note:</u>

Allocation based on Deactivated Portion = Acquisition Value / Total Land Rights Acquisition Value x
 Accumulated Depreciation (\$18 / \$2,298 x \$176)

The actual remaining useful life is dependent on the ongoing condition of the pipeline. However, FEI's 2017 Depreciation Study filed and approved with FEI's Multi-year Rate Plan sets the average service life for transmission mains as 65 years. The OLI PEN 406 pipe was installed in 1994 and by the end of 2023 this line will have been in service for 29 years leaving an additional 36 years of financial service life (65 - (2023 - 1994) = 36). However, the actual life of a pipeline is dependent on the ongoing condition of the line and the continuous effectiveness of FEI's integrity management activities which can extend a pipeline's life beyond 65 years.

- 20
- 21
- 22
- 2330.3Please provide the costs of deactivation and on-going maintenance of OLI PEN24406.Please discuss the ecological and socio-economic disturbance to the area25that would occur if the pipeline was abandoned.
- 26



1 Response:

The deactivation costs for the 1,200 m section of the existing OLI PEN 406 are approximately \$80 thousand. This will include removing a section of pipe at the tie-in location, welding a cap onto the deactivated section, installing a blind at the inlet to the Ellis Creek Pressure Control Station, purging the line, and filling it with a low pressure blanket of nitrogen.

Annual ongoing maintenance costs of the deactivated section of the existing OLI PEN 406 are
approximately \$3.5 thousand per year. This segment of pipe would be managed under
applicable FEI standards and guidelines including right-of-way patrol and inspections,
vegetation management, third-party driven inspections, nitrogen blanket pressure inspection
and calibration, and cathodic protection testing and maintenance.

Abandonment of the proposed deactivated section of the existing OLI PEN 406 would imply the permanent removal from service of the 1,200 m pipe segment. Consistent with industry standard practice, FEI abandonment specifications require excavation, cutting, and capping every 200 metres along the abandoned pipeline section and includes grout filling of the entire length.

16 The abandonment process for the section of the existing OLI PEN 406 would have the potential 17 to disturb contaminated soils in and around the industrial parks located along Okanagan 18 Avenue, potential archaeological sites, and disturbance to sensitive creek crossings. It would 19 also negatively impact some local businesses, as the OLI PEN 406 traverses several industrial 20 parks and the excavation work required to support the abandonment process could impede their 21 operations.

- 22
- 23
- 24
- 30.4 Please clarify whether FEI undertook an assessment of the costs associated with
 deactivating this section of pipeline compared to abandonment.
- 27
- 30.4.1 If yes, please provide the financial assessment.
- 28 29
- 30.4.2 If not, please explain why no assessment was undertaken.

30 **Response:**

31 FEI undertook development of scope of work and cost estimates for both deactivation and 32 abandonment of the section of OLI PEN 406 pipeline.

The scope of work for abandonment would follow FEI abandonment specifications and is consistent with industry standard practice. At the tie-in location, a four metre section of pipe would be removed and a cap welded onto the abandoned section. At the Ellis Creek Pressure Control Station, a section of the OLI PEN 406 pipe would be removed from the road edge to the station facilities and a cap welded onto the abandoned section. Between the two isolated ends, FEI would excavate every 200 metres, segment the pipe, and install a cap on each side. Each



segmented section would be grout filled to prevent pipe collapse (since cathodic protection 1 2 would be discontinued it is expected that the pipe would corrode away over time). The site 3 would be restored consistent with preexisting conditions. For the 1,200 metre section of the 4 existing OLI PEN 406 line, approximately five sites would require excavation. FEI has estimated 5 the costs associated with abandonment of the section of pipe to be approximately \$200 6 thousand.

7 The scope of work for deactivation would be much more simple and consists of removing a 8 section of pipe at the tie-in location, welding a cap onto the deactivated section, installing a blind 9 at the inlet to the Ellis Creek Pressure Control Station, purging the line, and maintaining a low 10 pressure blanket with nitrogen. The costs associated with deactivation of the section of pipe are 11 approximately \$80 thousand.

- 12
- 13

15

16

- 14
 - 30.5 Please discuss under what circumstances that FEI would reactivate this section of the OLI PEN 406 pipeline.
- 17 18 Response:

19 FEI is currently developing the Interior Transmission System (ITS) Transmission Integrity 20 Management Capabilities (TIMC) project application to identify and address cracking threats on 21 the ITS pipelines and intends to file it in 2022. One of the pipelines of potential concern is the 22 VER PEN 323, including the section between the Ellis Creek Pressure Control Station and the 23 proposed Chute Lake Pressure Control Station.

24 Should the BCUC approve the ITS TIMC project, and if cracking is found in the VER PEN 323 25 section which would require significant rehabilitation or replacement, FEI may choose to 26 reactivate the 1,200 m section of the OLI PEN 406 to provide additional redundancy and 27 resiliency to the Penticton and Summerland systems.

28 29 30 31 30.6 Please explain the factors that could cause FEI to consider abandonment of the 32 deactivated pipeline in future. 33 34 **Response:**

35 At this time, FEI has no reason to believe it would abandon the deactivated pipeline in the 36 future.



3



1 31.0 Reference: PROJECT DESCRIPTION

Exhibit B-1-2, Section 5.10.4.3, pp. 90-92

Contingency Estimate

4 On page 91 of the Updated Application, FEI states, "Contingency is normally funded at 5 the P50 confidence level. Based on FEI's risk tolerance, the Project contingency will be 6 \$25.1 million (13 percent) at the P50 confidence level."

On page 90 of the Updated Application, FEI provides the following table showing the
results of the Monte Carlo analysis:

Figure 5-6: Quantitative Risk Analysis - Monte Carlo Simulation

Base Estimate:	\$187,960	Currency:	\$CAN		
Probability	Indicated	Contin	gency		
of Underrun	Funding Amount	Costs (thousands)	Percent of Base Est.		
5%	171,500	(16,500)	-9%		
10%	179,500	(8,500)	-5%		
15%	185,200	(2,800)	- 1%		
20%	190,100	2,100	1%		
25%	194,800	6,800	4%		
30%	198,700	10,700	6%		
35%	202,400	14,400	8%		
40%	206,100	18,100	10%		
45%	209,700	21,700	12%		
50%	213,100	25,100	13%		
55%	217,000	29,000	15%		
60%	220,400	32,400	17%		
65%	224,400	36,400	19%		
70%	228,400	40,400	21%		
75%	233,200	45,200	24%		
80%	238,600	50,600	27%		
85%	244,700	56,700	30%		
90%	252,900	64,900	35%		
95%	265,000	77,000	41%		

9

10

11

12

31.1 Please discuss how FEI determined the P50 confidence level to be the appropriate contingency for the OCU Project.

13 **Response:**

The rationale for selecting a P50 level of confidence is consistent with the AACE definition for contingency and aligns with the industry practice for contingency funding, which was confirmed by a leading industry expert.

FEI engaged Validation Estimating LLC (John Hollmann), to conduct a risk analysis, to develop
a contingency estimate, and to confirm the reasonableness of FEI's selection of contingency at
the P50 level of confidence for the Project. Mr. Hollmann concluded in the memo provided as
Confidential Appendix C-4 to the Updated Application, page 2, the following:

In summary, a decision by FEI to fund contingency and escalation at the p50
 confidence level is appropriate. Also, funding one of the two identified low
 probability/high impact risks at a p70 confidence level as a management reserve,
 in particular the risk event with the greatest potential impact, is prudent without
 being overly cautious.

FORTIS BC^{**}

1 In summary, the choice of a P50 level of confidence aligns to industry practice, was confirmed 2 by a leading industry expert, and is appropriate to establish a contingency amount. As such, a

3 higher confidence level was not considered.

- 4 5 6 Please explain whether FEI considered any alternative confidence level, other 7 31.2 8 than the P50 confidence level. 9 If yes, please discuss the alternative(s) considered by FEI, including the 31.2.1 10 advantages and disadvantages of each and please explain why each 11 alternative was rejected. 12 31.2.2 If not, please explain why not. 13 14 Response: 15 Please refer to the response to BCUC IR1 31.1. FEI engaged a leading industry expert to 16 confirm the reasonableness of FEI's selection of contingency at the P50 confidence level. FEI 17 did not consider funding contingency at any other confidence level. 18 19 20 21 On page 91 of the Updated Application, FEI states: 22 The probability of both management reserve risks occurring is low, therefore, FEI 23 will hold one reserve fund to cover the impact should either of the risks occur. 24 Given there are two risks covered by a single management reserve, FEI has 25 chosen to fund the P70 value of the larger risk or \$23.6 million. 26 On page 92 of the Updated Application, FEI states, "FEI will fund escalation at \$11.6 27 million which corresponds to the P50 level of confidence." 28 31.3 Please discuss FEI's rationale for selecting the P50 confidence level to estimate 29 escalation. Please discuss why FEI considers the P50 level to be appropriate to 30 estimate escalation for the OCU Project. 31 32 Response: 33 Please refer to the response to BCUC IR1 31.1 where FEI explained the rationale for selecting a 34 P50 level of confidence to derive the contingency amount. FEI used a similar rationale to select the P50 value as the basis for the level of confidence used to fund escalation. 35
- 36
- 37



1						
2 3	31.4 Please explain whether FEI considered any alternative confidence levels to estimate escalation, other than the P50 confidence level.					
4 5 6		31.4.1	If yes, please discuss the alternative(s) considered by FEI, including the advantages and disadvantages of each and please explain why each alternative was rejected.			
7 8 9	Response:	31.4.2	If not, please explain why not.			
10 11 12	Please refer to the response to BCUC IR1 31.3. FEI engaged a leading industry expert to confirm the reasonableness of FEI's selection of escalation at the P50 confidence level. FEI did not consider funding escalation at any other confidence level.					
13 14						
15 16 17 18 19	31.5	Please was use reserve	provide the total OCU Project cost estimate if the P70 confidence level ed to estimate contingency and escalation, as well as the management.			
20	Response:					
21 22 23	At a P70 conf Project cost confidence lev	idence le would in vel there	evel for contingency, management reserve, and escalation, the total OCU crease from \$271.3 million to \$295.9 million. Note that at the P70 is no change to the management reserve which remains at \$23.6 million.			

As a result of the changes in the contingency and escalation, the AFUDC would also increase.
 The following table outlines the costs at both the P50 and P70 confidence level and the change

26 in costs represented in millions of dollars.



	FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	Submission Date: March 4, 2021
FORTISBC	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 115

		Amount	Amount	
Line	Item	P50	P70	Difference
1	Construction Cost Estimate (Contractor)	153.4	153.4	\$
2	Construction Cost Estimate (FEI)	34.5	34.5	\$
3	Owner Costs (\$25.1M)			
4	Inspection Services (\$8.6M)			
5	AC Mitigation, Cathodic Protection, Deactivation (\$0.7M)			
6	Sub-Total Construction Base Cost Estimate (2020\$)	187.9	187.9	\$
7	Project Development Costs (Capitalized Estimate)	6.2	6.2	\$
8	Contingency	25.1	40.4	\$15.3
9	Sub-Total Cost Estimate (2020\$)	219.2	234.5	\$15.3
10	Management Reserve	23.6	23.6	\$
11	Cost Escalation Estimate	11.6	19.5	\$7.9
12	Sub-Total Construction Cost Estimate (As-spent)	254.4	277.6	23.2
13	AFUDC	16.8	18.3	1.5
14	Grand Total Project Cost Estimate (As-spent)	271.3	295.9	24.7



4



1 E. PROJECT COST ESTIMATE

2 32.0 Reference: PROJECT COST ESTIMATE

Exhibit B-1-2, Section 6.2, p. 83

Summary of Project Costs

5 On page 83 of the Updated Application, FEI provides the following table showing a 6 summary of the total cost estimate of the OCU Project:

Line	Item	Amount	Reference
1	Construction Cost Estimate (Contractor)	\$153.4	Appendix A-3 ³⁰
2	Construction Cost Estimate (FEI)	\$34.5	Appendix B
3	Owner Costs (\$25.1M)		Appendix B
4	Inspection Services (\$8.6M)		Appendix B
5	AC Mitigation, Cathodic Protection, Deactivation (\$0.7M)		Appendix B
6	Sub-Total Construction Base Cost Estimate (20205)	\$187.9	Section 5.10,3
7	Project Development Costs (Capitalized Estimate)	\$6.2	Section 6.2
8	Contingency	\$25.1	Section 5.10.4.5
9	Sub-Total Cost Estimate (20205)	\$219.2	
10	Management Reserve	\$23.6	Section 5.10.4.5
11	Cost Escalation Estimate	\$11.6	Section 5.10.4.6
12	Sub-Total Construction Cost Estimate (As-spent)	\$254.4	
13	AFUDC	\$16.8	
14	Grand Total Project Cost Estimate (As-spent)	\$271.3	

Table 6-1: Summary of Forecast Capital and Deferred Costs (\$millions)

7

8

32.1 Please discuss the accuracy range of the OCU Project cost estimate.

9

10 Response:

11 The accuracy range of the OCU Project is -5% to +35% at an 80 percent confidence interval of 12 actual costs from the cost estimate. As described in AACE RP 97R-18 Cost Estimate 13 Classification System – As Applied in Engineering, Procurement, and Construction for the 14 Pipeline Transportation Infrastructure Industries one of the secondary characteristics of a Class 15 3 estimate is the expected accuracy range of low: -10% to -20% and high: +10% to +30%. This range of ranges represents typical percentage variation but as indicated in AACE RP 97R-18, 16 17 "individual estimates should always have their accuracy ranges determined by a quantitative risk analysis study that results in an estimate probability distribution." FEI conducted such a 18 19 quantitative risk analysis, included in Confidential Appendix C-2 - Validation Estimating 20 Contingency Report, to establish the OCU Project's accuracy range.

- 21
- 22
- 23
- 2432.2Please explain how FEI developed FEI's portion of the construction base cost25estimate of \$34.5 million, including the sources of information used to develop26the cost estimate.



2 Response:

3 FEI's portion of the construction base cost estimate was developed using an established 4 internal cost estimating process which has been followed in similar CPCN applications. The 5 process began with defining the purpose of the estimate, followed by a plan (in the form of 6 scheduled activities) of how to acquire information to complete, verify, and assemble the 7 estimate for the required class of estimate. Next, using a combination of internal experience 8 and knowledge, and external support for specialized services, FEI undertook the planning 9 process and completed the planning deliverables listed in AACE RP 97R-18, such as:

- Defining the project delivery method;
- 11 Developing a project execution strategy;
- Obtaining permits;
- 13 Identifying stakeholders; and
- Developing the Work Breakdown Structure (WBS) for all Project Services work
 packages.
- 16

Concurrently, the construction schedule is developed by FEI's engineering consultant, and FEI 17 18 develops a master schedule to show the activities and interfaces required to support the 19 construction timelines. Various leads are assigned to the project to identify the resources 20 required to support project execution. Once the necessary resources are identified, the 21 durations and quantities are identified, and the schedule is optimized through resource leveling 22 where possible. Hourly rates and related expenses are then allocated to the quantity and 23 resource duration, and summed to produce a total cost. FEI's portion of the cost estimate was 24 then reviewed and totaled with the construction cost estimate, contingency, and escalation to 25 form the Project Class 3 estimate.

Please also refer to Confidential Appendix B, FEI Construction Cost Estimate, for a review ofthe Owner's costs WBS.

- 28
- 29
- 30
- Further, on page 83 of the Updated Application Update, FEI states, "Project development costs include all of the costs associated with developing an AACE Class 3 cost estimate in accordance to AACE International Recommended Practices Nos. 18R-97 and 97R-18 as required by the CPCN Guidelines and are estimated to be \$6.2 million (2020\$)."
- 3632.3Please provide a detailed breakdown and explanation of the Project37Development costs of \$6.2 million by line item and year incurred.
- 38



1 Response:

- 2 Table 1 below provides details of the Project Development costs of \$6.2 million by line item and
- 3 year incurred.
- 4

 Table 1: Project Development Cost Breakdown

			Pr	ojec	t Developme	ent -	Capitalized \$	000	S
Particulars		2018			2019		2020		Total
	•		•	•	4 070	•	0.004	•	0.040
Engineering Design	\$		8	\$	1,273	\$	2,061	\$	3,342
Engineering Survey			-		84		111		194
Engineering Estimate Validation			-		-		319		319
Engineering Geotechnical			-		14		903		916
Project Services - Project Management			-		(503)		708		205
Project Services - Communications			-		10		118		128
Project Services - Community Relations			-		13		119		132
Project Services - Enviromental/Archaeology			-		9		112		121
Project Services - Indigenous Relations			-		24		78		102
Project Services - Legal			-		-		158		158
Project Services - Operations Support			-		3		-		3
Project Services - Procurement			-		12		81		94
Project Services - Property Services			-		0		421		421
Project Services - Regulatory / Permitting			-		13		83		96
Total	\$		8	\$	951	\$	5,271	\$	6,230

5

6 7

The following tables provides an explanation of the various types of Project Development costs:

8

Table 2: Engineering – Description of Activities

Activity	Description
Design	Costs associated with developing the Engineering deliverables of the OCU Project to the appropriate level for the CPCN application.
Survey	Costs associated with field survey to support design work for the OCU Project.
Estimate Validation	Costs associated with third party validation of the Class 3 cost estimate for the OCU Project.
Geotechnical	Costs associated with geotechnical work required to support engineering deliverables required to bring the OCU Project to the appropriate level of definition for the CPCN Application.

9 10

Table 3: Project Services – Description of Activities

Activity	Description
Project Management	Costs associated with Project Management activities, including cost and schedule oversight, project controls.
Communications	Costs associated with external facing communication of the Project to interested parties.
Community Relations	Costs associated with managing and incorporating feedback from the various communities impacted by the OCU Project.



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 119

Activity	Description
Environmental / Archaeology	Costs associated with undertaking, reviewing, and accepting required Environmental and Archaeological assessments to support the OCU Project.
Indigenous Relations	Costs associated with managing and incorporating feedback from the various Indigenous communities impacted by the OCU Project.
Legal	Costs for Project legal support .
Operations Support	Costs for Project operations support.
Procurement	Costs for Project procurement support.
Property Services	Costs associated with acquiring the necessary land rights to support the Project.
Regulatory / Permitting	Costs associated with developing the required regulatory and permitting plans for the OCU Project.



3

1 33.0 Reference: PROJECT COST ESTIMATE

Exhibit B-1-2, Section 6.3.2, p. 96, footnote 35, p. 96

Application and Preliminary Stage Development Costs

4 On page 96 of the Updated Application, FEI states:

5 FEI is seeking BCUC approval under Sections 59-61 of the UCA for deferral 6 treatment of the Application and Preliminary Stage Development costs. The 7 Application costs are based on a written hearing process and include expenses 8 for legal review, consultant costs, BCUC costs and BCUC-approved intervener 9 costs. The Preliminary Stage Development costs are related to expenses 10 incurred for engaging third-party consultants for feasibility evaluation, preliminary 11 development and assessment of the potential design and alternatives as required 12 to complete this Application. ... FEI proposes to transfer the balance in the deferral account to rate base on January 1, 2022 and commence amortization 13 14 over a three-year period.

15Table 6-3 below shows the December 31, 2020 net-of-tax balance for the16Application costs and the Preliminary Stage Development costs is forecast to be17a credit of \$795 thousand.

Particulars	Application Costs	Preliminary Stage Development Costs	Total
Pre-tax Costs	\$400	\$902	\$1,302
Income Tax Recovery:			
Costs held in deferral account ³⁴	\$(108)	\$(244)	\$(352)
Capitalized Costs ³⁵		\$(1,682)	\$(1,682)
Total Tax Offset	\$(108)	\$(1,926)	\$(2.034)
Financing, WACC after tax	\$10	\$(73)	\$(63)
Total	\$302	\$(1.097)	\$(795)

Table 6-3: Forecast Application Costs and Preliminary Stage Development Costs (\$000s)

18

In footnote 35 to Table 6-3 on page 96 of the Updated Application, FEI states, "Income tax recovery on the development costs that were capitalized but are deductible for tax purposes. The amount shown is equal to the costs capitalized of \$6.2 million times the income tax rate of 27%."

33.1 Please provide a breakdown of the Application costs of \$400,000 and the
 Preliminary Stage Development costs of \$902,000 by each activity (e.g.
 consultant costs, legal costs etc.) for each year incurred.

26 27 **Response:**

The excerpt from the Updated Application quoted in the preamble includes an error in the referenced date. The net-of-tax balance of \$(795) thousand is at December 31, **2021**, not 2020.



- 1 The following table provides a breakdown of the forecast Application costs of \$400 thousand, by
- 2 year and type of cost. Only actual costs will be recorded in the deferral account.

	CPCN Application Costs \$000's								
Particulars		2020		2021		2022		Total	
BCUC	\$	-	\$	60	\$	-	\$	60	
Intervenor PACA Award		-		70		-		70	
Legal		40		190		-		230	
Expert / Consultant		-		5		-		5	
Notice / Publication		-		32		-		32	
Administrative		-		3				3	
Total	\$	40	\$	360	\$	-	\$	400	

4 In preparing this response, FEI has shifted \$20 thousand of Application costs from 2020 to 2021

5 as this better aligns costs to the end of 2020 and projected costs for 2021. These costs are

6 associated with external legal counsel support. (For original timing of total gross Application

7 costs see Confidential Appendix E-2, Schedule 9, Line 12).

8 The following table provides a breakdown of the Preliminary Stage Development costs, \$902 9 thousand, by year and activity. An explanation of the activities follows after the cost table.

	P	relin	ninary Stage	De	velopment	\$C	000's		
Particulars	2018		2019		2020			Total	
Engineering Design	\$ 114	\$	-	\$		-	\$		114
Project Management	-		788			-			788
Total	\$ 114	\$	788	\$		-	\$		902

10

11

FEI is forecasting \$902 thousand for Preliminary Stage Development Costs. These are actual costs incurred by FEI up to November 30, 2019 associated with the project management, engineering and consultants for assessing the potential design and alternatives for the Project. Engineering and Project Management after November 30, 2019 were related to the AACE Class 3 cost estimation and project development of the preferred alternative and are part of the \$6.2 million that is discussed in BCUC IR1 32.3.

18 Engineering Design includes costs associated with developing the engineering deliverables of 19 the OCU Project to the appropriate level for the CPCN Application. Project Management 20 includes costs associated with project management activities, including cost and schedule 21 oversight, and project controls.

- 22
- 23
- 24

28

2533.2Please clarify whether the income tax recovery of the capitalized costs relates to26the Capital Cost Allowance (CCA) deduction of the capitalized Project27Development Costs.



1 Response:

2 The Income Tax Recovery does not relate to the Capital Cost Allowance deduction of the 3 capitalized Project Development Costs. The capitalized Project Development Costs of \$6.2 4 million are not added to the Undepreciated Capital Cost (UCC) pools but are instead tax 5 deductible in the year incurred. Therefore, the income tax recovery is derived by expensing, for Income Tax payable purposes, the capitalized portion of the Development Costs, \$6.2 million, 6 7 multiplied by the tax rate of 27 percent (\$6,230.4 thousand x 27% = \$1,682 Income Tax 8 Recovery).

9 By including the tax recovery in the proposed deferral account, to be amortized over three 10 years, the value of the tax recovery benefit is returned to ratepayers much sooner than if FEI 11 were to include the \$6.2 million in its UCC pools, which would then cause the income tax 12 recovery benefit be returned to ratepayers over 65+ years.

13 It is FEI's standard regulatory practice to record the tax benefit in a net-of-tax deferral account.

14 This enables matching of the tax benefit to customers to the recovery of associated costs. This 15 practice was confirmed in BCUC Order G-53-94, Page 2.

16 Deferred Account Balances in Rate Base

17 If deferred expenses or credits are included in the utility's actual tax calculation in the 18 year they are first recorded, then the amounts shall be recorded in rate base on a net of 19 tax basis. If such expenses or credits are not included in the utility's tax calculation then the amounts shall be on a before tax basis. 20

- 21
- 22
- 23
- 24
- 33.3 Please explain why FEI proposes to include the income tax recovery of the capitalized costs of \$6.2 million in the deferral account.
- 25 26
- 27

28 **Response:**

- 29 Please refer to the response to BCUC IR1 33.2.
- 30
- 31
- 32
- Please provide FEI's rationale for proposing to amortize the deferral account over 33 33.4 34 a three-year period.
- 35



1 Response:

The proposed three-year amortization period for the OCU Application and Preliminary Stage
Development Costs deferral account is consistent with similar deferral account treatment
approved for recent FEI CPCN applications:

- BCUC Order G-12-20 for the Inland Gas Upgrades Project approved a single Application
 and Preliminary Stage Development Costs deferral account with a three-year
 amortization period;
- BCUC Order C-11-15 for the Lower Mainland Intermediate Pressure System Upgrade
 Project approved two separate deferral accounts for the Application and Project
 Development costs, both with three-year amortization periods; and
- BCUC Order C-2-14 for the Muskwa River Crossing Project for the Fort Nelson Service
 Area approved a single Application and Project Development Cost deferral account with
 a three-year amortization period.
- 14

Given the size of the projected balance in the deferral account, FEI believes either a one or two
 year amortization period could also be appropriate. FEI ultimately selected an amortization
 period of three years which is consistent with recent BCUC approvals.

18 19 20 21 33.5 Please explain whether FEI considered any alternative amortization periods, 22 other than three years. 23 33.5.1 If yes, please discuss the alternative amortization period(s) considered 24 by FEI, including the advantages and disadvantages of each and 25 please explain why each alternative was rejected. 26 33.5.2 If not, please explain why not. 27

28 **Response:**

FEI did not consider other amortization periods for the proposed deferral account for the OCU Project. In the table below, FEI shows the change in the total Project rate impact if the amortization period is changed to one year, two years, four years or five years. The change in amortization period has no impact on the long term average percentage change on delivery rates and the levelized rate impact.

Over the five years from 2022 to 2026, varying the amortization period results in customers being marginally better off in some years, some years would have no impact, and in other years customers would be marginally worse off, depending on the amortization period.



- 1 As discussed in response to the BCUC IR1 33.4, FEI is proposing to amortize the application
- 2 and development costs over a three-year period, which is consistent with past BCUC CPCN
- 3 decisions.
- 4

Rate Change Impact From Varying Amortization Period That Begins in 2022

Rate Impact \$ / GJ	2022	2023	2024	2025	2026
3 Year Amortization ¹⁾	\$ (0.002)	\$ (0.001)	\$ 0.100	\$ 0.107	\$ 0.108
1 Year Amortization	\$ (0.006)	\$ 0.001	\$ 0.102	\$ 0.106	\$ 0.107
Change from 3 Year Amortization	\$ (0.004)	\$ 0.002	\$ 0.002	\$ (0.001)	\$ (0.001)
2 Year Amortization	\$ (0.003)	\$ (0.002)	\$ 0.102	\$ 0.107	\$ 0.108
Change from 3 Year Amortization	\$ (0.001)	\$ (0.001)	\$ 0.002	\$ -	\$ -
4 Year Amortization	\$ (0.002)	\$ (0.001)	\$ 0.100	\$ 0.105	\$ 0.108
Change from 3 Year Amortization	\$ -	\$ -	\$ -	\$ (0.002)	\$ -
5 Year Amortization	\$ (0.001)	\$ (0.001)	\$ 0.100	\$ 0.105	\$ 0.107
Change from 3 Year Amortization	\$ 0.001	\$ -	\$ -	\$ (0.002)	\$ (0.001)
1) Reference: Confidential Appendix E-	2, Schedule	e 10, Line 3	9		

6 Note: The rate impacts shown above are for the overall OCU Project, not just for the deferred application

7 and development costs. Also, the change would affect all non-bypass ratepayers.

8



3

1 34.0 Reference: PROJECT COST ESTIMATE

Exhibit B-1-2, Section 6.4, pp. 96–97

Rate Impact

4 On page 97 of the Updated Application, FEI provides the following table showing the 5 annual delivery rate impact compared to the 2021 applied for non-bypass revenue 6 requirement and the incremental annual delivery rate impact in percentage in 2024:

Particulars	Impact
Incremental Revenue Requirement (\$000s)	\$19,448
% Increase to 2021 Applied for Revenue Requirement, Non-Bypass (August, 2020) ³⁷	2.21%
Delivery Rate Impact (2024) \$ / GJ	\$0.100
Levelized Rate Impact \$ / GJ (2019 - 2088)	\$0.073

Table 6-4: Summary of Rate Impact for the Project

8 Further, on page 97 of the Updated Application, FEI states that "the Project will result in 9 an estimated delivery rate impact of 2.21 percent in 2024 when all construction is 10 complete and after all assets are placed in service in 2023."

- 1134.1Please discuss the assumptions used to calculate the rate impact, including the12assumptions associated with the load forecast including growth in customer13accounts and rationale for each assumption.
- 14

7

15 **Response:**

16 FEI did not consider growth in customer accounts, growth in volumes, or growth in delivery 17 margin revenue when calculating the Project rate impacts. This approach is consistent with 18 previous FEI CPCN applications. The purpose of the rate impact calculations in the Updated 19 Application is to show the impact to existing rates, or in this case, relative to what was approved 20 in the FEI Annual Review for 2021 Rates; i.e. holding the delivery margin revenue and volumes 21 constant over the years. This results in a high-level estimate of the rate impact relative to the 22 most recently approved rates. The actual rate impacts of the Project will not be known until a 23 future Annual Review or Revenue Requirements proceeding when the costs of the Project are 24 added to rate base at that time. Any increased growth in the delivery margin or volumes would 25 only reduce the rate impact shown in Table 6-4.

- 27
- 28
 29 34.2 Please clarify whether FEI considered any potential increase in volumes sold, as
 30 a result of the OCU Project, when determining the rate impact provided in Table
 31 6-4.

		FortisBC Energy Inc. (FEI or the Company) Submission Date: Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) March 4, 2021								
	Response to	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1								
1 2	34.2.1	If yes, to what extent to does the increased revenue impact of the project?	offset the rate							
3 4	34.2.2	If no increase in volumes is reflected in the rate impact, why not.	, please explain							
5										
6 <u>Respon</u> s	se:									
7 Please re	Please refer to the response to BCUC IR1 34.1.									
8										



1 F. ENVIRONMENT AND ARCHEOLOGY

2 35.0 Reference: ENVIRONMENT AND ARCHEOLOGY

Exhibit B-1-2, Section 7.1, p. 98

3 4

First Nations engagement and consultation

5 FEI states on page 98 of the Updated Application that draft versions of both the 6 Environmental Overview Assessment (EOA) and Archaeological Overview Assessment 7 (AOA) were provided to Indigenous communities who requested drafts for their review 8 and comment. At the time of writing, FEI had not received any comments; however, any 9 comments that are received will be incorporated during the detailed engineering phase 10 of the Project.

- 1135.1Please provide an update on engagement with Indigenous communities with12regards to the EOA and the AOA, including anticipated timelines for future13engagement.
- 14

15 **Response:**

16 Engagement with potentially impacted Indigenous groups has occurred throughout the Project 17 to date, and will continue throughout the remaining Project phases, on a community by 18 community basis. With regard to the updates on the AOA and EOA, FEI sent the reports to 19 Indigenous groups with a stated interest.

The Penticton Indian Band reviewed the EOA report and provided comments while Westbank First Nation deferred comment on the EOA to the Penticton Indian Band. Comments provided by the Penticton Indian Band did not materially change the EOA and therefore will be addressed during the environmental field program and in the Project Environmental Management Plan.

A confidential AOA was facilitated by the Penticton Indian Band, and conducted by the Syilx Traditional Ecological Knowledge Keepers (TEKK) – a group of individuals from communities across the Syilx traditional territory. The recommendations of this AOA will be addressed during the Archaeological Impact Assessment.



1 36.0 Reference: ENVIRONMENT AND ARCHEOLOGY

Exhibit B-1-2, Appendix F, Table 6.1, p. 42

Overview of Potential Effects and Risks

- 4 Table 6.1 of Appendix F identifies several follow-up activities to mitigate project risks 5 related to Land Use and the use of public roadways including engagement with the 6 Ministry of Transportation and Infrastructure.
- 7 8

9

2

3

36.1 Please describe the engagement that has occurred with the Ministry of Transportation and Infrastructure to date.

10 Response:

11 In June 2020, FEI began communications with various contacts at the Ministry of Transportation

and Infrastructure (MoTI) to understand who within MoTI should be consulted, and to provide a

13 general awareness of the Project. In September 2020, FEI conducted two formal meetings with

14 MoTI staff members.

15 The first meeting provided an overview of the route and allowed both FEI and the MoTi teams to

16 gain an understanding of potential Project interactions with MoTI infrastructure. MoTI also

17 reviewed the permitting process, the requirements in the MoTI Utility Policy Manual, and the

- 18 application process for a variance if the gas line design is not in accordance with the MoTI Utility
- 19 Policy Manual.

The gas line design for the OCU Project does not meet some of the criteria specified within theMoTI Utility Policy Manual as follows:

- approximately 550 metres of the proposed alignment falls inside, or within 30 metres of
 and parallel to the MoTI Saliken Drive right of way (ROW), near the City of Penticton;
- 24 2. the crossing of Saliken Drive is proposed to be completed using an uncased open trench25 method;
- 3. the crossing of Chute Lake Road is currently designed to cross the MoTI ROW at an
 angle less than 70 degrees; and
- 4. the crossing of Chute Lake Road is proposed to be completed using an uncased open trench method.
- 30
- The second meeting was held to discuss the specific details of and the need for variances. FEI submitted the variance application in January 2021 and expects a response from the MoTI in March 2021.
- 34

35

....

FORTIS BC^{**}



Table 6.1 identifies several Moderate to High project risks related to Surface Water
 Quality and Quantity, noting "construction timing (i.e., avoid periods of heavy
 precipitation" as a possible follow up activity.

- 4 5

6

36.2 Please discuss any adjustments to the construction schedule to mitigate these project risks.

7 <u>Response:</u>

8 The construction contract will include an environmental management plan which specifies all of 9 the environmental requirements for the Project and the contractor will be required to prepare an 10 environmental protection plan (EPP). FEI has planned construction work to proceed throughout 11 the year. The contractor will be responsible for scheduling their work locations and activities to 12 meet the contract requirements and in accordance with their EPP.

In the construction contract there will be an "adverse weather" clause so that FEI and the contractor may effectively address poor weather conditions such as heavy rain and snow. In addition, the contract will include unit price items for environmental protection measures such as silt fences, erosion control matting, etc. An allowance for adverse weather and extra work (if required) has been included in the Project contingency funding.

- 18
- 19
- 20

23

- Table 6.1 notes high project risks associated with Fish and Fish Habitat, and follow-up activities include:
 - Conduct instream works within reduced risk work window.
- To the extent practicable, undertake construction within the least-risk timing
 windows for applicable species.
- 26 36.3 Please discuss how FEI has adjusted its plan for instream works to align with the 27 reduced risk work window.

2829 **Response:**

The current schedule in the Updated Application has not been adjusted for instream works. During the detailed design phase of the Project, FEI will finalize the environmental requirements and the construction methodology for each water crossing in collaboration with the Penticton Indian Band and Westbank First Nation. Once complete, the requirements will be documented in an Environmental Management Plan (EMP) and provided to the construction contractor for compliance.

36 FEI expects that the contractor will undertake all instream works on fish bearing and fish habitat-

- 37 streams during the reduced risk window of August 7 to October 15, other species-specific (i.e.,
- 38 amphibians) reduced risk windows as appropriate, or when the watercourses are dry.
- 39



3

1 37.0 Reference: ENVIRONMENT AND ARCHEOLOGY

Exhibit B-1-2, Section 7.2.1.2, p. 100; Appendix F, Table 6.2, p. 44

Contaminated Sites and Environmental Permitting

- 4 FEI states on page 100 of the Updated Application:
- 5 Locations where there is a medium to high potential for encountering soil or 6 groundwater contamination within the Project footprint may impact construction 7 cost, and timelines. These areas are defined as APECs [area of potential 8 environmental concern]. One high risk and one low risk APEC were identified in 9 the contaminated sites study area. ... The high risk APEC is associated with an 10 active landfill that includes operations dating back to 1972.
- Hemmera recommends on page 44 of Appendix F that planning and construction be
 coordinated with the Campbell Mountain Landfill to comply with conditions of their landfill
 operating permit.
- 1437.1Please discuss what steps FEI has taken to engage with the operators of the15Campbell Mountain Landfill to date.
- 16

17 **Response:**

The Campbell Mountain Landfill is operated by the Regional District of Okanagan-Similkameen(RDOS) and located on land leased from the City of Penticton.

20 FEI met with the RDOS Electoral Area 'E' (Naramata) Director and City of Penticton staff 21 (including the Mayor) in Q1 2020 to provide a high level overview of the Project and the gas line 22 route. Since May 2020, FEI and the Campbell Mountain Landfill operators have met numerous 23 times to discuss the Project and to address any concerns or questions the operators had with 24 respect to the pipeline alignment crossing through the landfill property. From those interactions, 25 FEI adjusted the route to address their concerns. FEI is currently working with the Campbell 26 Mountain Landfill operator's preferred environmental consultant, Sperling Hansen, to better 27 understand the environmental implications of constructing a gas line through a short section of 28 the landfill. FEI will continue to consult with the operators of the Campbell Mountain Landfill 29 until all outstanding issues are resolved.

- 30
- 31
- 32 33
- 37.2 Please discuss the potential impact of this high risk APEC (VP1) on construction cost and timelines.
- 34 35

36 **Response:**

The cost and schedule implications associated with contaminated soil at the landfill were unknown at the time of developing the AACE Class 3 cost estimate for the Project, and



	FortisBC Energy Inc. (FEI or the Company)	Submission Date:
тм	Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
	Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 131

therefore it is treated as a project-specific risk. The AACE Class 3 cost estimate includes a budget to further investigate APEC VP1 at the Campbell Mountain Landfill and once the investigation is complete, FEI's environmental consultant will provide advice on how to handle the contaminated soil, if any is identified. As the APEC VP1 study will take place well in advance of construction, FEI does not expect a schedule delay, however there may be additional costs required to handle the contaminated soil and if so they will be drawn from the Project contingency.



3

1 38.0 Reference: ENVIRONMENT AND ARCHEOLOGY

Exhibit B-1, Section 7.2.3, p. 103; Appendix F, Table 6.3, p. 45

Permitting

4 FEI states on page 103 of the Updated Application that all required environmental 5 permits and approvals for the Project will be identified and applied for during the detailed 6 engineering phase of the Project.

- A list of anticipated permits and approvals along with the estimated timeframe forissuance is provided in Table 6.3 of Appendix F.
- 38.1 Please confirm if FEI has submitted a request for project review to Fisheries and
 Oceans Canada yet, including the date of submission if applicable. If not, please
 indicate when FEI intends to submit the request.
- 12

13 Response:

FEI has not submitted a request for review of the Project to Fisheries and Oceans Canada at
this time. FEI expects that the first request for Project review will be submitted late Q1 2021 with
an additional request for Project review to be submitted in mid Q3 2021.

- 17
- 18
- 19
- 2038.2Please confirm if FEI has submitted an application for the Waste Discharge21Authorisation to the BC Oil and Gas Commission, including the date of22submission if applicable. If not, please indicate when FEI intends to submit the23application.

24 25 **Response:**

At this time, FEI does not expect to need a BCOGC Waste Discharge Authorization. If during detailed engineering it is determined that a Waste Discharge Authorization is required, FEI would apply for it in approximately Q3 2021.

29
30
31
32
38.3 Please confirm if FEI has received formal confirmation of the exemption from the Regional District of Okanagan-Similkameen for:
34
the Environmentally Sensitive Area Development Permit; and
the Watercourse Development permit.



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 133

1 Response:

- 2 Formal confirmation of the exemptions is not required as natural gas public utility work is
- 3 exempted from the requirement for Environmentally Sensitive Area Development Permits and
- 4 Watercourse Development Permits in Sections 23.2.8 and 23.3.8, respectively, of the Electoral
- 5 Area "E" Official Community Plan Bylaw No. 2458, 2008.¹⁰
- 6

¹⁰ <u>https://www.rdos.bc.ca/assets/bylaws/planning/AreaE/2458-A.pdf.</u>



4

1 G. CONSULTATION AND ENGAGEMENT

2 39.0 Reference: CONSULTATION AND ENGAGEMENT

Exhibit B-1-2, Section 8.2.5.3 pp. 113, 114

Consultation with Landowners

5 FEI notes on page 113 of the Updated Application that as a result of consultation with 6 landowners, FEI was able to make adjustments to the route which ultimately decreased 7 the number of directly impacted landowners from 57 to 38. Of the 57 original landowners 8 to whom FEI sent the initial notification letter, five of those landowners responded. FEI 9 subsequently followed up with landowners that did not respond to the initial notification 10 letter.

11 FEI states on page 114 of the Updated Application that it began negotiations to acquire 12 the necessary land rights in August and September 2020. The landowners were given a 13 document package that included an independent real estate market appraisal of their 14 property based on the latest IOP, the standard form of Agreement to Grant Statutory 15 Right of Way and Temporary Work Space.....FEI is committed to negotiating fair 16 agreements with landowners along the route and will continue to engage with 17 landowners post CPCN filing to acquire the requisite land rights. Should FEI be unable 18 to reach agreement with landowners, FEI will follow the internal escalation procedure 19 outlined in the Land Acquisition Plan, including pursuing its rights to expropriate land in 20 accordance with applicable legislation. As at the filing date FEI has come to agreement 21 with 13 of 38 private landowners. [Emphasis added]

- 39.1 Of the 38 directly impacted landowners, please confirm if all of them have now
 responded to FEIs notification. If not confirmed, please clarify how many have
 not responded, and outline the steps FEI is taking to ensure notifications have
 been received.
- 26

27 <u>Response:</u>

- 28 FEI confirms that all 38 directly impacted landowners have responded to its notification.
- 29
- 30
- 31

32

33

- 39.2 Please provide an update with regard to the signing of agreements with the 38 private landowners.
- 3435 <u>Response:</u>

36 Since filing the Updated Application, FEI has refined the route to address landowner feedback, 37 constructability challenges, and contingency plans, resulting in an additional two impacted 38 landowners. The following table provides a summary of land convisition progress to date

38 landowners. The following table provides a summary of land acquisition progress to date.



FortisBC Energy Inc. (FEI or the Company)	Submission Date:
Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application)	March 4, 2021
Response to British Columbia Utilities Commission (BCUC) Information Request (IR) No. 1	Page 135

	Required	Obtained
Private rights-of-way	35	22
Private temporary workspace	2	1
Municipal City of Penticton rights-of-way	3	0
Total	40	23

FEI continues to work with the remaining unsigned property owners to address their concerns. While FEI's objective is to secure required land rights for the Project through open and transparent negotiations with landowners, FEI anticipates that there may be instances where a negotiated settlement with a landowner cannot be reached. In these cases, FEI would expect to expropriate in order to secure the required land rights, along with providing fair market value compensation.

- 8
- 9
- 9
- 10
- 11 12
- 39.2.1 If applicable, please discuss the possible impact of an expropriation process on the project schedule.
- 13

14 **Response:**

FEI's objective is to reach mutually acceptable negotiated agreements with landowners. Should an agreement not be reached and result in the potential for Project construction delays, FEI will take steps to expropriate the required land rights. Should FEI need to proceed with expropriation in a particular situation, FEI would make an application under Section 6 of the *Gas Utility Act* or section 34(3) of the *Oil and Gas Activities Act* as appropriate for approval to expropriate the necessary land. Should FEI have to undertake expropriation, costs are not expected to vary beyond those in the estimate.

- 22
- 23
- 24

25

26

- 39.3 Please discuss what steps FEI takes to ensure the independence of the real estate company.
- 27

28 **Response:**

FEI has already engaged an independent, third-party real estate appraisal firm and provided it with a scope of work to prepare necessary valuation reports to assist in land acquisition negotiations with private landowners. The appraiser has had the opportunity to meet with landowners to understand and evaluate their concerns during site inspections. FEI was provided with drafts of appraisal reports prior to finalization and had the opportunity to ask questions of the appraisers as necessary.



All appraisal reports are completed in compliance with the Canadian Uniform Standards of
 Professional Appraisal Practice (CUSPAP) and each appraiser is bound by the Appraisal
 Institute of Canada Code of Ethics.

- 4
 5
 6
 7 39.4 Please clarify where the budget for all payments associated with property acquisition (including both statutory rights of way and temporary work space) appears in the project cost estimate. Responses can be provided confidentially if necessary.
- 12 Response:
- 13 Please refer to the response to BCUC Confidential IR1 4.2.
- 14



1	Н.	PROVINCI	AL GOVERNMENT ENERGY OBJECTIVES
2	40.0	Reference:	PROVINCIAL GOVERNMENT ENERGY OBJECTIVES
3			Exhibit B-1-2, Section 9.2, p. 125
4			Policy Considerations
5 6 7		FEI states of British Colu economic d	on page 125 of the Updated Application that the OCU Project will support the umbia energy objective found in section 2(k) of the CEA "to encourage evelopment and the creation and retention of jobs."
8		Section 2 of	[*] BC's Clean Energy Act outlines BC's energy objectives, including:
9			
10		(b)tc	take demand-side measures and to conserve energy,
11			
12		(g)tc	reduce BC greenhouse gas emissions
13			
14 15			(iii)by 2020 and for each subsequent calendar year to at least 33% less than the level of those emissions in 2007,
16 17			(iv)by 2050 and for each subsequent calendar year to at least 80% less than the level of those emissions in 2007, and
18 19			(v)by such other amounts as determined under the <u>Climate Change</u> <u>Accountability Act</u> ;
20		(h)tc	encourage the switching from one kind of energy source or use to another
21		that	decreases greenhouse gas emissions in British Columbia;
22		(i)to	encourage communities to reduce greenhouse gas emissions and use
23		ener	gy efficiently;
24		(j)to	reduce waste by encouraging the use of waste heat, biogas and biomass;
25		(k)to	encourage economic development and the creation and retention of jobs;"
26 27 28		40.1 Plea BC g	se discuss the extent to which project is consistent with and will advance the government's energy objectives as set out above.

29 Response:

30 As described in the Updated Application, the Project primarily supports objective (k) to 31 encourage economic development and the creation and retention of jobs. The Project provides 32 vital capacity to serve the growing energy needs of homes, business and industry in the central 33 and north Okanagan regions which, in the absence of the Project, are expected to experience a 34 capacity shortfall in the winter peak of 2023/2024. As described in Section 1.2.1 of the Updated 35 Application, Kelowna has been one of the fastest growing cities in Canada in the past decade 36 and is forecast to grow at a similar rate in the coming two decades. The continued supply of 37 safe, reliable and affordable energy to new and existing customers in the region will support 38 economic activity and the creation and retention of jobs.



- 1 In addition, the construction of the Project is expected to have positive employment impacts by
- 2 contributing to the local economy in the central and north Okanagan regions. In particular, the
- 3 procurement of local materials, and the use of local services such as lodging and dining, will

4 contribute local economic activity.

5 More generally, the Project is aligned with the provincial energy objective to reduce greenhouse 6 gas emissions. The gas energy delivery system, including the Project, delivers low carbon 7 energy (i.e. renewable gas) to customers in the province. FEI continues to increase its supply 8 of renewable gas in alignment with the provincial CleanBC target to achieve 15 percent 9 renewable gas content by 2030. Over the longer term to 2050, FEI envisions a future where the 10 majority of the energy it delivers, including through the Project, is renewable.

Attachment 25.1

ATTACHMENT 25.1: CLASS 3 ESTIMATE WATERCOURSE CROSSINGS LIST

Project KP	Tie-in KP	Segment	Northing	Easting	Crossing name	Input Category	Construction Methodology	Environmental Protection and Management Regulation Classification	Riparian Management Area	Local Watershed Code ¹	Stream Order	Fish Bearing	Location or Crossing Description	Streamside Protection and Enhancement Area
1+007.08	31+794.28	1	5483860.278	316166.377	Ellis Creek Tributary	Stream	Open Cut	NCD	n/a	300-432687-623544-1139914	1	No	An unnamed watercourse overlaps the study area	15-30
										(Tributary to Ellis Creek)			and runs parallel to before crossing the pipeline under Saliken Drive.	
1+638.69	32+425.89	1	5484479.368	316258.796	Unnamed Watercourse	Stream	Open Cut	NCD	n/a	300-432687-623544-102657- 539790	1	No	An unnamed watercourse overlaps with the study area and the pipeline.	15-30
2+854.30	33+641.50	2	5485687.124	316316.206	Penticton Creek	Stream	HDD	52	50	300-432687-637835-179687 (Penticton Creek)	3	Yes	Penticton Creek overlaps with the study area and the pipeline and flows into Okanagan Lake.	30
3+555.27	34+342.47	3	5486368.897	316294.019	Penticton Creek Tributary	Stream	Open Cut	NCD	-	300-432687-637835-211241 (Penticton Creek tributary)	1	No	An unnamed watercourse crosses with the study area and pipeline and joins Penticton Creek to the east of the study area before Penticton Creek crosses the alignment.	15-30
5+584.00	36+371.20	4	5488005.892	315493.008	Randolph Creek Tributary	Stream	Open Cut	NSCI	n/a	300-432687-644621-853582 (Randolph Creek tributary)	1	No	An unnamed watercourse crosses with the study area and pipeline northwest of Reservoir Road and joins Randolph Creek within the study area	**
5+656.95	36+444.15	4	5488068.663	315455.838	Randolph Creek	Stream	Open Cut	NSCI	n/a	300-432687-644621-853582 (Randolph Creek)	1	**Yes (downstream of study area)	Randolph Creek crosses with the study area and pipeline and flows into Okanagan Lake.	**
5+880.13	36+667.33	4	5488272.839	315384.396	Randolph Creek Tributary	Stream	Open Cut	NSCI	-	300-432687-644621-764561 (Randolph Creek tributary)	1	No	An unnamed watercourse crosses with the study area and pipeline and joins with Randolph Creek to the west of the study area.	**
7+824.90	38+612.10	4	5490100.627	315189.957	Strutt Creek	Stream	Open Cut	S6	30	300-432687-646321 (Strutt Creek)	3	No	Strutt Creek crosses the study area and the	15-30
8+801.88	39+589.08	5	5490998.263	314967.889	Johnson Spring Creek	Stream	Open Cut	NSCI	n/a	300-432687-647543 (Johnson Spring Creek)	1	Yes (downstream of study area)	Johnson Spring Creek crosses the study area and the pipeline and flows into Okanagan Lake.	**
10+564.50	41+351.70	5	5492635.968	314680.390	Turnbull Creek	Stream	Open Cut	\$3	30	300-432687-655718-140892 (Turnbull Creek)	1	Yes	Turnbull Creek crosses the study area and the pipeline and flows into Okanagan Lake.	30
14+234.14	45+021.34	6	5495895.996	315010.320	Arawana Creek Tributary	Stream	Open Cut	NSCI	n/a	300-432687-664623-601339 (Tributary to Arawana Creek)	1	No	An unnamed watercourse crosses the study area and the pipeline, and joins Arawana Creek outside the study area	**
14+357.26	45+144.46	6	5496007.401	315060.974	Arawana Creek	Stream	Open Cut	\$3	40	300-432687-664623-262113	2	UKN	Arawana Creek crosses the study area and the	30
15+313.28	46+100.48	6	5496811.776	314883.023	Naramata Creek	Stream	Open Cut	S2	40	300-432687-668498-081260 (Naramata Creek)	3	Yes	Naramata Creek overlaps with the study area and the pipeline and flows into Okanagan Lake.	30
18+192.56	48+979.76	7	5499518.500	314177.142	Robinson Creek	Stream	Open Cut	53	40	300-432687-674998 (Robinson Creek)	2	Yes	Robinson Creek crosses the study area and the	30
19+782.54	50+569.74	7	5501018.937	313684.375	Trust Creek	Stream	Open Cut	\$3	40	300-432687-675833-666895 (Trust Creek)	1	Yes	Trust Creek crosses the study area and the pipeline and flows into Okanagan Lake.	30
20+009.12	50+796.32	7	5501235.621	313618.235	Watercourse	Stream	Open Cut							
24+008.38	54+795.58	7	5505085.167	313954.0624	Watercourse	Stream	Open Cut							
24+023.53	54+810.73	7	5505097.442	313962.9349	Watercourse	Stream	Open Cut	1	These crossings	were identified during field recona	ssaince by Gold	er Geotechnical a	nd are not included in P-00760-ENV-EOA-0001.	
25+150.75	55+937.95	7	5505980.509	314656.2958	Watercourse	Stream	Open Cut	1						
25+310.75	56+097.95	7	5506086.576	314774.4243	Watercourse	Stream	Open Cut	1						
26+365.93	57+153.13	7	5506810.739	315531.6577	Chute Creek	Stream	Open Cut	S2	50	300-432687-688607-416446 (Chute Creek)	3	Yes	Chute Creek overlaps with the study area and the pipeline and flows into Okanagan Lake.	30
27+782.00	58+569.20	8	5507603.742	316600.1479	Chute Creek Tributary	Stream	Open Cut	NCD	n/a	300-432687-688607-484441 (Chute Creek tributary)	1	No	An unnamed watercourse overlaps the study area and the pipeline and joins Chute Creek south of the study area before Chute Creek crosses the study area.	**

Excerpted from Table 4.5 - Watercourses Overlapping the General Study Area, Classifications, and Riparian Setbacks (P-00760-ENV-EOA-0001 - ENVIRONMENTAL ASSESSMENT REPORT)

Notes:

NSCI = no stream channel identified; NCD= Non-classified Drainage; N/A = not applicable; FWA = Freshwater Atlas; UKN = unknown

= not assessed during PFR

¹ 1:20,000 FWA watershed codes have a 300 prefix.

² Calculated from a Simple Assessment at the crossing location.

**If there is no watercourse present, then SPEA setbacks do not apply.