



**Diane Roy**  
Vice President, Regulatory Affairs

**Gas Regulatory Affairs Correspondence**  
Email: [gas.regulatory.affairs@fortisbc.com](mailto:gas.regulatory.affairs@fortisbc.com)

**Electric Regulatory Affairs Correspondence**  
Email: [electricity.regulatory.affairs@fortisbc.com](mailto:electricity.regulatory.affairs@fortisbc.com)

**FortisBC**  
16705 Fraser Highway  
Surrey, B.C. V4N 0E8  
Tel: (604)576-7349  
Cell: (604) 908-2790  
Fax: (604) 576-7074  
[www.fortisbc.com](http://www.fortisbc.com)

November 10, 2021

Residential Consumer Intervener Association  
c/o Midgard Consulting Inc.  
Suite 828 – 1130 W Pender Street  
Vancouver, B.C.  
V6E 4A4

Attention: Mr. Peter Helland, Director

Dear Mr. Helland:

**Re: FortisBC Energy Inc. (FEI)**

**Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)**

**Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2**

---

On December 29, 2021, FEI filed the Application referenced above. In accordance with the regulatory timetable established in British Columbia Utilities Commission Order G-185-21 for the review of the Application, FEI respectfully submits the attached response to RCIA IR No. 2.

If further information is required, please contact the undersigned.

Sincerely,

**FORTISBC ENERGY INC.**

***Original signed:***

Diane Roy

Attachments

cc (email only): Commission Secretary  
Registered Parties



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 1

	<b>Table of Contents</b>	<b>Page No.</b>
1		
2	A. Project Need and Justification.....	1
3	B. Description and Evaluation of Alternatives .....	16
4		

5 **A. Project Need and Justification**

6 **30. Reference: Exhibit B-22, FEI Response to RCIA IR1, IR 2.1**

7 In the response to RCIA IR1 2.1, FEI states: “One possible scenario in a system  
8 experiencing a hydraulic collapse, is that the pressure experienced by customers in the  
9 affected areas may drop low enough such that the customers’ appliances fail to operate.  
10 The pressure may then recover somewhat (since some consumer appliances have shut  
11 down), resulting in repeated pressure increase/decrease cycles as appliances attempt to  
12 recover. In a hydraulic collapse, FEI anticipates that such situations would be occurring at  
13 multiple locations and would be widely distributed through the system.”

14 30.1 Does FEI have experience responding to safety incidents or emergencies where  
15 the customer appliance safeguards failed? If so, please provide any available data  
16 that indicates the frequency or severity of these incidents.

17 **Response:**

18  
19 FEI typically responds when an appliance safeguards might fail, as an incident of this kind could  
20 result in a gas odour call. With the implementation of a new workforce management system in  
21 October 2020, FEI has been able to extract data queries regarding customer premises that list  
22 failed safeguards as a specific finding. In the year since the system began operation, FEI has  
23 logged the following calls that could have resulted in gas entering customer premises after  
24 pressurizing the system had FEI not isolated the customer premises at the meter:

- 25 • 29 calls where an issue was identified as “No pilot safety/control”;
- 26 • 61 calls where an issue was identified as “Defective control valve”; and
- 27 • 283 calls identified as “Gas leak at appliance”.

28  
29 The occurrence of incidents resulting in personal injury or significant property damage are very  
30 rare and FEI’s data does not necessarily document the severity of these incidents. However, each  
31 of the listed incidents resulted in gas to the appliance being shut off and the occupant issued a  
32 “Red Tag”, indicating the appliance needs maintenance and the customer must arrange repair  
33 before operating the appliance. Notice is also given to Technical Safety BC when appliances are  
34 red tagged.



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 2

- 1 FEI is not called in all cases where an appliance safeguard is found faulty. Appliances, including
- 2 the appliance safeguards, are customer-owned devices. The customer may elect to engage a
- 3 licensed gas fitter directly to address maintenance. As a result, FEI does not possess a complete
- 4 record of appliance safeguard failures.
- 5

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 3

1    **31.    Reference: Exhibit B-22, FEI Response to RCIA IR1, IR 4.2**

2           In RCIA IR1 4.2, RCIA states: “Explain why Guidehouse considers impact to be of greater  
3           importance than probability when considering the risks facing a gas utility such as FEI.”

4           Guidehouse responds: “The possibility of an event is an important consideration.  
5           Moreover, Guidehouse observes that the critical factors to consider include defining the  
6           risk, both in terms of the probability of the risk and the consequences. Guidehouse  
7           observes that probability of an occurrence often clouds decision-making relative to  
8           consequence mitigation.”

9           RCIA observes that the response to IR1 4.2 does not clarify why Guidehouse considers  
10          impact to be of greater importance than probability when considering the risks facing FEI,  
11          as requested in the IR.

12          31.1    Explain why Guidehouse considers impact to be of greater importance than  
13                  probability when considering the risks facing a gas utility such as FEI.

14  
15    **Response:**

16    The following response has been provided by Guidehouse:

17    Relative to probability, consequence is of greater importance in the case of a material disruption  
18    to the T-South pipeline specifically because of the determined unacceptable outcome that results.  
19    The consequence of a supply disruption on the T-South Pipeline during a period of heavy usage,  
20    such as during the peak winter season, is well established. The consequences of the supply  
21    disruption risk factor make up an unacceptable set of outcomes and therefore must be avoided  
22    or mitigated. Therefore, consequence is of greater importance in FEI’s case than probability, due  
23    to the unacceptable outcome that results.

24    When mitigating intolerable or unacceptable consequences, including the supply disruption of the  
25    T-South Pipeline as is the case of the TSLE proposed project, decision-making is binary: Either  
26    FEI will be adequately prepared in the event of a supply disruption to mitigate the disruption, or it  
27    will not.

28    If the impact is not mitigated, FEI and its customers will suffer the consequences that occur after  
29    a significant supply disruption.

30  
31

32  
33          31.2    Explain what Guidehouse means by “probability of an occurrence often clouds  
34                  decision-making relative to consequence mitigation.” Does this mean that decision  
35                  makers place too much emphasis on probability or too little emphasis? Why does  
36                  Guidehouse have this view?

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 4

1

2 **Response:**

3 The following response has been provided by Guidehouse:

4 Risk-based decision-making is applied in many different circumstances and not always within the  
5 context of catastrophic and/or intolerable circumstances where severity can be a more important  
6 consideration than probability of occurrence. When considering intolerable consequences in risk  
7 analysis, such as the case of hydraulic collapse of the FEI system, probability can cloud decision-  
8 making. In the case of supply disruption of the T-South Pipeline and its related consequence to  
9 FEI and FEI's customers, the focus on probability of occurrence is a distraction from the key  
10 question which is: "How can FEI best prepare to mitigate the consequence of a supply disruption  
11 during a period of heavy usage?"

12 Decision makers often place too much emphasis on probability when addressing low probability  
13 but high consequence events. Low probability and high consequence events continue to be high  
14 risk events regardless of their probability. High risk must be mitigated in alignment with what a  
15 utility can tolerate. Guidehouse considers that a resilience investment is akin to purchasing  
16 insurance.

17 As reviewed by Zuppinger and the Project Management Institute (PMI) in 2012; based on the  
18 influential work of Taleb 2004, Fooled by Randomness<sup>1</sup>, it is assessed that improbable events  
19 should not be overlooked in risk analysis. Black swan events, although improbable, are not  
20 impossible and if the consequence is too severe to be tolerated, the risk must be managed  
21 effectively so that they do not take us by surprise. Probability is important, but can be misleading  
22 in risk assessment by creating biases that convince of the unlikeliness without understanding the  
23 real severity of the risk in question.

24 In the insurance context, the probability of an event occurring illustrates why probabilities can  
25 cloud consequence-based decision making. The probability of getting into or causing an  
26 automobile accident is low; however, the consequences are often high. We do not purchase  
27 insurance based on a probability adjusted basis. We purchase insurance based on whether or  
28 not we can tolerate the consequences of the event.

29 If the determination is made that the likely outcome of a significant supply disruption on T-South  
30 is intolerable (which FEI has concluded it is), risk management principles would suggest cost  
31 effective steps be taken to protect against occurrence of those consequences.

32

---

<sup>1</sup> Assessing Risk is it a Black Swan, 2012. <https://www.pmi.org/learning/library/assessing-risk-black-swan-fukushima-6084>.

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 5

1    **32.    Reference: Exhibit B-22, FEI Response to RCIA IR1, IR 8**

2           In the response to RCIA IR1 8.3, FEI states: “In FEI’s experience, when a system pressure  
3           collapse occurs, air enters the collapsed system through various pathways.”

4           32.1    Provide details of FEI’s specific experience with system pressure collapses, such  
5           as when, where, the geographic extent, and number of customers affected.

6  
7    **Response:**

8    Please refer to the response to BCUC Confidential IR1 15.3 for information related to the Fort  
9    Nelson gas emergency and the response to BCUC Confidential IR1 1.3 for information related to  
10   the Parksville gas emergency.

11  
12

13  
14           32.2    Explain how FEI verified that air was entrained in the system while the system was  
15           at zero pressure. In particular, explain how FEI verified that air was entrained  
16           through fitting and pipeline leaks (as opposed to obvious locations such as  
17           damaged pipe and facilities).

18  
19   **Response:**

20   The two pressure-collapse examples, referenced in RCIA IR2 32.1, were a result of valve failures  
21   and lasted approximately one day. Because of the short duration of these incidents, FEI did not  
22   confirm whether air entered the collapsed system in significant volumes.

23   Even so, FEI’s experience has confirmed a significant amount of air can enter a pressure-  
24   collapsed system if given enough time. This experience is based on customer houselines that  
25   have been disconnected from FEI’s system for days or weeks. In these situations, when FEI  
26   returns to reconnect the customer and relight their appliance(s), FEI often finds a significant  
27   amount of air in the houseline. The large volume of air is confirmed by the amount of purging at  
28   the appliance undertaken before the appliance is able to be relit and operate properly. Because  
29   these houselines are closed systems, the air could only have entered through a leaking  
30   connection or an appliance that is weeping gas through a slightly open gas safety valve, which is  
31   effectively a leak.

32   In the large-scale system pressure collapse contemplated as part of this application, it would take  
33   weeks before FEI could manually disconnect all the affected customers. During this time, the air  
34   that would enter customer houselines would be able to move into FEI’s pressure collapsed  
35   system. Also, above ground leaks on FEI’s system would be another entryway for air to enter the  
36   pressure collapsed system.

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 6

1 After a long duration pressure collapse, as contemplated in the TLSE application, FEI would  
2 always assume air has entered the system through customer houselines, fittings, leaks, or third-  
3 party damage. In this situation, FEI would isolate all affected customers from the collapsed  
4 system, pressurize the system with natural gas, leak survey the newly pressurized system, repair  
5 any leaks, purge the system with nitrogen if required, purge every service to ensure all potential  
6 air is removed from the system, and then conduct customer relights, which would take months to  
7 complete.

8  
9

10

11 32.3 Explain the steps FEI took in these examples to purge the system of air and  
12 whether these steps are any different from the approach described in the  
13 Application and Workshop.

14

15 **Response:**

16 During the pressure collapse examples provided in RCIA IR2 32.1, FEI followed its re-  
17 pressurization operating procedure which consists of:

- 18
- 19 • Isolating all affected customers from the collapsed system;
  - 20 • Re-pressurizing the system with natural gas;
  - 21 • Purging at the meter set; and
  - 22 • Relighting customer appliances.

23 The only difference between these steps and what is stated in the Application and Workshop  
24 involves undertaking leak survey activity and subsequent system repairs. Because the pressure  
25 collapse examples provided in RCIA IR2 32.1 were short durations and FEI had field personnel  
26 working throughout the area affected by the pressure collapse, FEI determined there was no risk  
27 of third-party damage to the collapsed system; consequently, FEI did not perform a leak survey.

28 The steps taken to reconnect an individual customer, after they have been disconnected from  
29 FEI's system, follow FEI's standard operating procedure listed above:

- 30
- 31 • Re-pressurizing the customer houseline with natural gas by opening the meter set valve;
  - 32 • Purging the houseline of air at the appliance(s); and
  - 33 • Relighting the customer's appliance(s).

34 As discussed in the response to RCIA IR2 32.2, when a customer's houseline has been  
35 disconnected from FEI's system for days or weeks, FEI often finds a relatively large volume of air  
36 in these houselines. Because the houseline is a closed system, air can only have entered through



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 7

- 1 a leaking connection or an appliance that is weeping gas through a slightly open gas safety valve,
- 2 which is effectively a leak.
  
- 3



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 8

1    **33.    Reference: Exhibit B-22, FEI Response to RCIA IR1, IR 13**

2           In the response to RCIA IR1 13.1, FEI states: “During the October 2018 no-flow event, of  
3           the approximately 230 large customers (both firm and interruptible) that FEI contacted  
4           individually to curtail their consumption, approximately 50 customers were either firm or  
5           held an amount of firm capacity.”

6           33.1    Did all 230 customers curtail their consumption as requested by FEI? If not, how  
7           many continued to consume gas, or continued for an extended period prior to  
8           curtailing their consumption?  
9

10    **Response:**

11    FEI performed a high-level regional review of the change in daily consumption of the curtailed  
12    customers and observed compliance from the majority of the customers who were requested to  
13    curtail their usage following the 2018 T-South Incident.

14

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 9

1    **34.    Reference: Exhibit B-15, FEI Response to BCUC IR1, IR 1.5, 3.4, 65.1**

2    In BCUC IR1 3.4, the BCUC requests: “Please discuss whether FEI considers it is possible  
3    to undertake a probability estimate of the occurrence of a disruption event occurring on a  
4    pipeline, based upon the frequency events outlined in the tables in Appendix B, the total  
5    length of pipelines in the regions reviewed, and the length of time.

6                3.4.1 Please discuss any limitations of this approach.”

7    In response, FEI states: “The following explanation was provided by PwC, with which FEI  
8    agrees.

9                ‘Natural gas disruption represents “black swan” events that are of an unforeseen, binary  
10    nature that either happen or they don’t. For this reason a probabilistic or risk adjusted  
11    approach is not applicable and system resiliency investment decisions should be  
12    considered on the basis of total potential impact that may occur in the event of disruption.  
13    While likelihood was considered at the highest level (i.e., disruption events do happen  
14    periodically), we did not undertake an assessment of this type. The intent was that the  
15    study would assess the potential impact of natural gas disruption and provide the province  
16    and the energy industry with data to help weigh the costs and benefits of different  
17    infrastructure investments to enhance system resiliency in the province.’

18    FEI also provides the following response:

19                Please refer to the response to BCUC IR1 1.5 where FEI has provided the cumulative  
20    probability of a disruption event based on Canadian and US industry pipeline performance  
21    data.”

22                In the response to BCUC IR1 1.5, FEI states: “However, FEI retained JANA Corporation  
23    (JANA) to conduct an independent, expert probabilistic analysis of a pipeline incident  
24    occurring on the Westcoast T-South system.”

25                34.1    Reconcile PwC’s position in BCUC IR1 3.4, which FEI agrees with, which is that a  
26    probabilistic or risk adjusted approach is not applicable, with FEI contracting JANA  
27    to conduct a probabilistic analysis of the rupture of T-South.

28  
29    **Response:**

30    Please refer to the responses to BCUC IR2 68.11 and BCOAPO IR2 2.1.

31    The following response has been provided by PwC:

32    PwC was not retained to review the referenced JANA analysis so can not comment on this  
33    reconciliation.

34    For additional clarity, PwC’s study was not constrained by the type of disruption (cause) or specific  
35    assets disrupted.

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 10

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35

34.2 Explain why FEI arranged for JANA to conduct the probabilistic analysis in response to information requests and not in advance of filing the CPCN Application.

**Response:**

Please refer to the response to BCOAPO IR2 2.1.

In the response to RCIA IR1 4.2, Guidehouse states: “The possibility of an event is an important consideration. Moreover, Guidehouse observes that the critical factors to consider include defining the risk, both in terms of the probability of the risk and the consequences.”

In the response to BCUC IR1 9.3, Guidehouse states: “It is not only the probability of a major system disruption that defines the level of risk, but also the significance, or impact of the event. In the example of FEI, it is the case that a major system disruption of its upstream supply delivery will severely impact the achievement of its objectives, which are FEI’s ability to serve its customers.

Our key finding that “FEI has fittingly applied the appropriate risk management approach” is based on our evaluation of the analysis that FEI performed to understand the magnitude of impact to its ability to deliver gas in the event of a major system disruption during a period of peak demand.”

34.3 Explain why Guidehouse’s finding that FEI fittingly applied the appropriate risk management approach is based on FEI’s assessment of the impact, but not the probability, of a disruption.

34.3.1 If Guidehouse’s finding that FEI fittingly applied the appropriate risk management approach is based on an assessment of probability as well as impact, explain how Guidehouse arrived at this finding in advance of FEI obtaining JANA’s report on the probability of a T-South rupture.

**Response:**

The following response has been provided by Guidehouse:

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 11

1 Where consequences are intolerable and impactful for FEI and its customers, such as the case  
2 of supply disruption of the T-South Pipeline, effective risk management is comprised of developing  
3 responses and controls to prepare for, withstand and recover from the risk of a significant event  
4 that, left unmitigated, would lead to adverse consequences.

5 Guidehouse observes that generally accepted definitions of risk include:

- 6 • The impact of uncertainty on objectives (ISO 31000)<sup>2</sup>; and
- 7 • The possibility that an event will occur and adversely affect the achievement of objectives  
8 (COSO ERM).<sup>3</sup>

9  
10 Furthermore, Guidehouse observes that generally accepted definitions of risk management  
11 include “A process ... [to] manage risk to be within [the entity’s] risk appetite, to provide  
12 reasonable assurance regarding the achievement of entity objectives.” (COSO ERM)<sup>4</sup>, i.e., risk  
13 management efficiency is achieved by managing risk to the tolerable level, cost-effectively. It  
14 should be noted that the least cost option may not be the most cost-effective option when  
15 considering all outcomes of an investment.

16 FEI has relied on the appropriate approach to understand the consequences of the risk, in this  
17 case a major supply disruption, e.g., understanding the “the impact of uncertainty on objectives”  
18 and evaluated all possible mitigants that could provide “reasonable assurance regarding the  
19 achievement” of FEI’s objectives. We arrived at the conclusion by developing a risk mitigation  
20 evaluation framework situation and then assessed how FEI’s approach followed the framework.

21 We arrived at this conclusion in advance of JANA’s report because the probability of occurrence  
22 is not the critical or determining factor in assessing the effectiveness of the risk management  
23 decision, given that the consequences are deemed intolerable.

24 The critical factor is whether or not the entity’s risk management approach effectively mitigates  
25 unacceptable consequences of the known risk event.

26

<sup>2</sup> <https://www.iso.org/iso-31000-risk-management.html>.

<sup>3</sup> <https://www.coso.org/Pages/erm.aspx>.

<sup>4</sup> <https://www.coso.org/Documents/COSO-ERM-Executive-Summary.pdf>.



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 12

1 **35. Reference: Exhibit B-15, FEI Response to BCUC IR1, IR 10.6; Exhibit B-24, FEI**  
2 **Response to Sentinel IR1, IR 30a**

3 In the response to BCUC IR1 10.6, FEI states: “FEI is completing the initial scoping and  
4 planning for a Regional Gas Supply Diversity (RGSD) solution which would entail building  
5 a new pipeline route to the Lower Mainland connecting to the Southern Crossing Pipeline  
6 (SCP) in the BC Interior (i.e., Diverse Pipelines). The design of the RGSD project would  
7 be optimally sized to form a cost-effective resiliency solution in combination with FEI’s  
8 other gas supply assets.”

9 In the response to Sentinel IR1 30a, FEI states: “FEI anticipates that the earliest filing date  
10 for a CPCN application would be sometime in 2023.”

11 35.1 What is FEI’s timeline, or range of potential timelines, for completing construction  
12 of a SCP expansion pipeline to the Lower Mainland?

13 **Response:**

14 Based on FEI’s preliminary evaluation, it is anticipated that the earliest completion of construction  
15 for the SCP expansion could be the end of 2028; however, a number of factors could extend this  
16 timeline. These factors will only become apparent once Indigenous and stakeholder engagement,  
17 detailed technical analysis, and environmental assessment work and approval processes are  
18 underway.  
19

20



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 14

1 all of the Lower Mainland commercial and industrial customers and any advanced meters not  
2 connected to the AMI network.

3 There are two other points of note when considering the above:

4 1. FEI's order of curtailment in a controlled shut down would follow the BCUC-approved  
5 System Preservation and Restoration (P&R) Plan, which differs from the order implied by  
6 the time it takes to disconnect (for instance, it also considers minimizing overall impacts  
7 and health and welfare).

8 2. Determining whether a hydraulic collapse would occur is not as simple as determining  
9 whether it takes longer than three days to shed load. As customers are progressively  
10 disconnected/shut off, the system load would also be declining, such that available storage  
11 volumes would last longer for supporting the remaining customers on the system.

12  
13

14

15 36.2 If FEI has the TLSE at its disposal and therefore could maintain supply for three  
16 days at the winter peak, would FEI immediately commence performing a controlled  
17 shutdown in the event of a similar T-South rupture where one tube is damaged  
18 and the other isolated as a precaution? Or would FEI try to wait out the no-flow  
19 event utilizing the TLSE inventory?

20

21 **Response:**

22 In the time gained by having the additional storage provided by the TLSE tank, FEI would assess  
23 the situation and the potential options available for mitigating the situation in order to determine  
24 at what point a controlled shutdown would need to commence in order to avoid an uncontrolled  
25 hydraulic collapse. It is difficult to provide a definitive response to the question, given the number  
26 of factors at play. However, in response to all T-South no-flow incidents, FEI would immediately  
27 commence planning for a potential controlled shutdown response as a precautionary measure.

28

29

30

31 36.2.1 If FEI waits for two or three days before determining that it must  
32 commence a controlled shutdown (due to the uncertain timing of the no-  
33 flow event ending), is there sufficient time to complete the controlled  
34 shutdown (with AMI in place)?

35



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 15

1 **Response:**

2 FEI would initiate a controlled shutdown as soon as the specifics of an incident require such a  
3 response. The TLSE Project will give FEI time to develop, prepare for, and execute an appropriate  
4 response. Even with AMI, it takes time to shed significant load, so emergency planning needs to  
5 account for that lead time. If FEI were to wait two or three days, it would only be as a result of the  
6 situation allowing for such a delay, reflecting the system load and FEI's response plan at the time.  
7 Please also refer to the responses to BCUC IR2 70.1 and RCIA IR2 36.2, which describe how  
8 FEI would immediately begin planning a shutdown either with or without AMI as a precautionary  
9 measure and then begin executing a controlled shutdown as soon as necessary thereafter.

10





FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 17

1 Base Plant was 49 years old (i.e., almost 10 years past its expected average service life) when  
2 the study was approved by the BCUC in 2020.

3  
4

5

6 37.2 Explain the advantages and disadvantages of removing the Base Plant tank in  
7 advance of completing the TLSE tank. How will FEI manage peaking during the  
8 period without the Base Plant tank or TLSE tank?

9

10 **Response:**

11 FEI has planned the construction for the TLSE Project such that the Base Plant tank will be  
12 available until two of the new vapourizers are in-service using LNG provided from the T1A tank.  
13 The advantage of removing the Base Plant tank in advance of completing the TLSE tank is that it  
14 provides additional construction and laydown area, in addition to providing better accessibility to  
15 the site during the tank construction period. The disadvantage of removing the Base Plant before  
16 completing construction of the TLSE tank would be the resulting reduction in the amount of  
17 storage available on-site for peak demand periods or emergency situations.

18 The current schedule for demolition of the Base Plant tank is based on the best information  
19 available at this time. The final construction sequencing will be dependent on several factors,  
20 including the progress of detailed design, planning and optimization from the EPC contractor  
21 engaged for the Project and the availability of LNG from the T1A tank in the intervening period  
22 between when the Base Plant tank is demolished and the TLSE tank is put into service. For  
23 example, if LNG sales through Rate Schedule 46 limit the amount of LNG available during that  
24 intervening period, it may be necessary to stage the demolition of the Base Plant tank after the  
25 TLSE tank is put into service. Ultimately, FEI will select the most cost-effective and efficient way  
26 to complete the TLSE Project, while maintaining its ability to provide peaking and emergency  
27 service during the Project's construction period.

28

29

30

31 37.3 Provide the current annual operating and maintenance costs of the Base Plant  
32 tank

33

34 **Response:**

35 The 2020 operating and maintenance costs for the Base Plant facilities (including the tank) were  
36 approximately \$2.2 million. The 2021 costs are projected to be consistent with 2020.

37



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 18

1   **38.   Reference: Exhibit B-15, FEI Response to BCUC IR1, IR 16.1**

2           In the response to BCUC IR1 16.1, FEI states: “AMI will provide complementary resiliency  
3           benefits to the TLSE Project. However, AMI alone would not prevent a pressure collapse  
4           in all scenarios, nor would it prevent wide-scale customer outages.”

5           38.1   In what scenarios would AMI’s remote shutoff capability, augmented by site visits  
6           to larger volume customers whose meters do not have this capability, be unable  
7           to isolate FEI’s system and prevent a pressure collapse?  
8

9    **Response:**

10   Please refer to the response to BCUC IR2 69.1.

11

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 19

1     **39.     Reference:     Exhibit B-15, FEI Response to BCUC IR1, IR 22.5, 11.9.2, 30.1, 23.1;**  
2                                 **Exhibit B-1-4, Updated Public Application, p. 112**

3             At page 112 of the Updated Public Application, FEI states: “Constructing more  
4             regasification capacity and storage at Tilbury will allow FEI to deliver a large amount of  
5             supply within a short period of time, providing FEI with additional operational flexibility to  
6             manage daily balancing.”

7             FEI further states: “FEI plans the next-day gas supply based on a weather forecast, which  
8             can deviate significantly from the actual weather experienced during the day as Lower  
9             Mainland demand increases by approximately 25 MMcf/day when temperature decreases  
10            by one degree Celsius.”

11            In the response to BCUC IR1 22.5, FEI states: “Additional liquefaction capacity will not  
12            need to be reserved. There will be an interconnection between the Tilbury 1A tank and  
13            the TLSE tank that allows FEI to utilize 5 MMcf/day of liquefaction from the new Tilbury  
14            1A liquefier to refill the Base Plant. Given that the daily balancing from the TLSE Project  
15            would only come from the “third Bcf” of storage, the 5 MMcf/day of liquefaction will be  
16            sufficient for refilling purposes.”

17            39.1     Does FEI currently use the Tilbury Base Plant for balancing? If so, what is the  
18                       highest draw for balancing purposes made in recent years?  
19

20     **Response:**

21            FEI does not use the Tilbury Base Plant as a primary daily load balancing tool. FEI’s off-system  
22            storage resources (Aitken Creek, Jackson Prairie, and Mist) are generally used for daily load  
23            balancing in normal operations. FEI’s on-system storage resources (Mt. Hayes and Tilbury) are  
24            typically reserved for handling shorter-interval weather events and emergency situations, but can  
25            be used by FEI to balance the system if needed.

26  
27

28            39.2     What is the highest daily draw that FEI anticipates making from TLSE in order to  
29                       assist in balancing?  
30

31

32     **Response:**

33            Please refer to the response to RCIA IR2 39.1.

34            The amount of volume used for daily load balancing would depend on several factors, including:  
35            the variance in the short-term weather forecast (i.e., weather forecast 24 hours out versus actual);  
36            the current inventory level of FEI’s off-system and on-system storage assets; and the line pack  
37            status of the Westcoast T-South pipeline and FEI’s own pipeline. These factors make it difficult



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 20

1 for FEI to determine the amount of send-out from Tilbury that can be labeled as a balancing  
2 activity. Please also refer to the response to CEC IR1 26.1 for the quantity of Tilbury LNG that  
3 was sent out from the Base Plant for each of the last 10 years.

4  
5

6

7 39.3 Explain whether 5 MMcf/d liquefaction is sufficient in the instance where FEI  
8 makes multiple significant draws (>10 MMcf) from TLSE for balancing purposes in  
9 a short period of time.

10

11 **Response:**

12 FEI considers that 5 MMcf/day of liquefaction will be sufficient because FEI's off-system storage  
13 resources in the gas supply portfolio will also be available for daily load balancing requirements,  
14 as discussed in the response to RCIA IR2 39.1. Optimizing all of FEI's storage resources for daily  
15 load balancing helps to mitigate the risks of future dependence on making multiple significant  
16 draws for balancing purposes.

17

18

19

20 39.4 Explain whether 5 MMcf/d liquefaction is sufficient if volumes must be replenished  
21 simultaneously resulting from depletions due to balancing, peaking use, and  
22 resiliency (i.e. no-flow event).

23

24 **Response:**

25 FEI considers that 5 MMcf/day of liquefaction will be sufficient for the purposes of daily load  
26 balancing and peaking use for the following reasons:

27 • Under normal operations, the supply for peaking use and daily load balancing would only  
28 come from the "third Bcf" of the TLSE Project. The 5 MMcf/day allocated for gas supply  
29 and operational benefits will provide FEI approximately 1.8 Bcf of supply (i.e., 5 MMcf x  
30 345 days = 1,725 MMcf<sup>7</sup>); and

31 • As discussed in the response to RCIA IR2 39.1, FEI's off-system storage resources  
32 (Aitken Creek, Jackson Prairie, and Mist) offer greater flexibility in terms of daily load  
33 balancing; therefore, the supply from the TLSE Project may not be heavily relied upon for  
34 this requirement.

---


<sup>7</sup> FEI has used 345 days and not 365 days to reflect that the plant will have annual turnarounds and/or maintenance to perform each year.



1 If a no-flow event were to occur, the sufficiency of the 5 MMcf/day of liquefaction for replenishing  
 2 the LNG inventory after T-South supply resumes will depend on the severity of the no-flow event.  
 3 However, FEI may be able to utilize a portion (if not all) of the Tilbury 1A liquefaction capability  
 4 (i.e., 28 MMcf/day), depending on the sales commitments to Rate Schedule 46 customers.

5  
6  
7  
8  
9

In the response to BCUC IR1 11.9.2, FEI shows the T1A storage tank levels, which indicate the periods of filling using the T1A liquefaction facilities.



10  
11  
12  
13  
14

39.5 Provide the number of days when the T1A liquefaction facilities were used to refill the T1A tank for each of the past three years.

15 **Response:**

16 The number of days that the Tilbury T1A liquefaction facilities were used is provided below:

	2019	2020	2021
Number of days T1A liquefaction in operation	78	80	32

17  
18  
19

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 22

1           39.6    It appears that FEI operates the T1A liquefaction facilities continuously for a period  
2                   of time to increase storage inventory, but then allows the inventory to draw down  
3                   over a period of months before restarting liquefaction. Explain whether FEI could  
4                   operate the T1A liquefaction facilities more frequently in order to maintain the T1A  
5                   inventory at a level closer to the tank capacity of 1 BCF. What are the downsides  
6                   of operating in this manner? Can liquefaction occur simultaneously with LNG  
7                   withdrawal?

8  
9           **Response:**

10          Please refer to the response to BCUC IR2 76.2.

11  
12  
13  
14           In the response to BCUC IR1 30.1, FEI states: “Under Direction No. 5 to the BCUC, FEI  
15           has approval to proceed with installation of a second liquefaction train (Tilbury 1B) to  
16           support additional LNG sales under RS 46, making additional liquefaction potentially  
17           available beyond the 33 MMcf/day currently at Tilbury 1A which could shorten the time.”

18          39.7    What conditions would trigger FEI or FortisBC to construct the additional  
19                   liquefaction facilities?

20  
21          **Response:**

22          The decision to move forward with the Tilbury 1B facilities will be based on a combination of  
23          Indigenous and stakeholder input, as well as commercial (primarily demand) and technical  
24          factors.

25          FEI continues to engage with Indigenous groups and stakeholders to seek feedback about the  
26          proposed Tilbury 1B facilities and will look to incorporate it throughout development.

27          The commercial justification will include overall market conditions for the global uptake of LNG as  
28          a marine fuel, the availability of bunkering service providers in the Port of Vancouver capable of  
29          providing ship to ship bunkering services to the marine customers, and willingness of current and  
30          prospective customers to enter into offtake agreements, all of which will drive actual and forecast  
31          demand.

32          The technical justification will include consideration for the long lead time required to complete  
33          the engineering, design and construction of the Tilbury 1B facilities. As such, FEI will need to  
34          ensure it is executing this project at the appropriate time.

35  
36

FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 23

1  
2 In the response to BCUC IR1 23.1, FEI states: “Of the 3 Bcf of storage provided by the  
3 proposed new TLSE Project storage tank, 2 Bcf is required to address the risk reflected in  
4 the MRPO. Accordingly, from a planning perspective, FEI will reserve 2 Bcf in the tank  
5 solely for resiliency purposes. The remaining 1 Bcf of storage will also provide resiliency  
6 benefits. However, because it is in excess of the MRPO, the remaining 1 Bcf can be used  
7 more flexibly. It would be available to provide either resiliency or the ancillary benefits to  
8 FEI and its customers described in Section 4.4.1.5 of the Application, including  
9 accommodating LNG from the Liquefaction Facility, in certain circumstances.”

10 39.8 What is the storage space required in the 3 Bcf TLSE tank to perform peak shaving  
11 and balancing through an entire winter, assuming only 5 MMcf/d of liquefaction is  
12 available to replenish volumes throughout the winter?  
13

14 **Response:**

15 Please refer to the response to BCUC IR1 22.7.  
16  
17

18  
19 39.8.1 Would FEI have concerns if the BCUC made it a condition of the CPCN  
20 approval that this volume be reserved for peak shaving and balancing  
21 operations?  
22

23 **Response:**

24 FEI would have concerns with the suggested condition. At a high level, imposing such a condition  
25 would be detrimental for ratepayers as it would limit FEI’s flexibility in how it could use the  
26 additional 1 Bcf of storage. There are other ancillary benefits beyond peak shaving and balancing  
27 which the 1 Bcf of storage could be utilized for, and the opportunity to make use of each of the  
28 ancillary benefits may vary from year to year. For example, in the response to BCUC IR1 16.24,  
29 FEI discussed that the additional 1 Bcf could provide operational benefits such as adjusting gas  
30 flows in the Coastal Transmission System (CTS) pipeline system for integrity management tools.  
31 Additionally, the incremental 1 Bcf of LNG storage provides a resiliency margin above the  
32 Minimum Resiliency Planning Objection (MRPO). This could help FEI manage either a longer  
33 duration initial no-flow event or any reduced supply for a period of time following a no-flow event  
34 (as explained in the response to BCUC IR1 4.5). Thus, in FEI’s view it would not be reasonable  
35 to lock FEI into specific uses for the additional 1 Bcf of storage.

36 The BCUC has ongoing oversight of FEI’s operations and can evaluate FEI’s use of the facility  
37 through its existing regulatory processes.  
38



FortisBC Energy Inc. (FEI or the Company) Application for a Certificate of Public Convenience and Necessity (CPCN) for the Tilbury Liquefied Natural Gas (LNG) Storage Expansion (TLSE) Project (Application)	Submission Date: November 10, 2021
Response to the Residential Consumer Intervener Association (RCIA) Information Request (IR) No. 2	Page 24

1     **40.     Reference: Exhibit B-15, FEI Response to BCUC IR1, IR 23.1**

2             In the response to BCUC IR1 23.1, FEI states: “The Tilbury Phase 2 Expansion Project  
3             has two components: (i) the 3 Bcf storage tank, and (ii) a liquefaction facility.”

4             In the response to BCUC IR1 23.2, FEI states: “As stated above, the primary resource  
5             which could be shared if the entire Tilbury Phase 2 LNG Expansion Project (both the TLSE  
6             Project and Liquefaction Facility) is completed is the new storage tank; however, as  
7             discussed in the response to BCUC IR1 23.1, 2 Bcf of the storage tank will be reserved at  
8             all times for minimum resiliency requirements. In order for this sharing to occur, the  
9             Liquefaction Facility would be interconnected to the 3 Bcf storage tank so that it could  
10            produce LNG and also accept boil-off gas from the 3 Bcf tank for reprocessing.”

11            40.1     When does FEI anticipate the Phase 2 liquefaction facilities to be operational?

12                    40.1.1     Will the Phase 2 liquefaction facilities be available to initially fill the TLSE  
13                                 volumes? Explain why or why not.

14  
15     **Response:**

16     FEI does not currently have an estimate for when the Phase 2 Liquefaction Facility will be  
17     operational, as this timing is dependent on commercial arrangements. To provide some  
18     perspective on project timing, when firm commercial terms for the Liquefaction Facility are set, it  
19     would take approximately five years from the commencement of pre-FEED engineering to the  
20     Liquefaction Facility entering commercial service. As a result, the Liquefaction Facility will not be  
21     available to assist with filling the TLSE tank.

22  
23

24  
25            40.2     Explain whether the fact that FEI plans for additional liquefaction facilities in Phase  
26                    2 is the reason that liquefaction facilities are not proposed for the TLSE.

27

28     **Response:**

29     Not confirmed. As explained in the response to BCUC IR1 30.1, FEI plans to use the existing  
30     liquefaction capacity available on the Tilbury site to fill the new TLSE tank. Had FEI required new  
31     liquefaction as part of the TLSE Project (i.e., as part of the CPCN project), FEI would have  
32     included the request in this Application. Further, regardless of whether the Liquefaction Facility  
33     contemplated in the Tilbury Phase 2 LNG Expansion Project environmental assessment process  
34     is built, additional liquefaction facilities are not required for the TLSE Project to achieve its  
35     resiliency benefits.

36