



Sarah Walsh
Director, Regulatory Affairs

Gas Regulatory Affairs Correspondence
Email: gas.regulatory.affairs@fortisbc.com

Electric Regulatory Affairs Correspondence
Email: electricity.regulatory.affairs@fortisbc.com

FortisBC
16705 Fraser Highway
Surrey, B.C. V4N 0E8
Tel: (778) 578-3861
Cell: (604) 230-7874
Fax: (604) 576-7074
www.fortisbc.com

October 25, 2023

British Columbia Utilities Commission
Suite 410, 900 Howe Street
Vancouver, B.C.
V6Z 2N3

Attention: Patrick Wruck, Commission Secretary

Dear Patrick Wruck:

Re: FortisBC Energy Inc. (FEI)

Application for a Certificate of Public Convenience and Necessity (CPCN) for the Okanagan Capacity Upgrade (OCU) Project (Application) ~ Project No. 1599152
Response to the British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No. 2

On November 16, 2020, FEI filed the Application referenced above. In accordance with British Columbia Utilities Commission Order G-273-23 establishing a further regulatory timetable for the review of the Application, FEI respectfully submits the attached response to BCUC Panel IR No. 2.

For convenience and efficiency, if FEI has provided an internet address for referenced reports instead of attaching the documents to its IR responses, FEI intends for the referenced documents to form part of its IR responses and the evidentiary record in this proceeding.

If further information is required, please contact the undersigned.

Sincerely,

FORTISBC ENERGY INC.

Original signed:

Sarah Walsh

Attachments

cc (email only): Registered Interveners

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 2 |

1 OCU [Okanagan Capacity Upgrade] Project and the high cost and challenges
2 associated with upgrading the electric system to handle peak heating energy
3 requirements as evidenced by the Kelowna Electrification Case Study, FEI
4 anticipates that even if the Renewable Gas Connections Program is not approved
5 and electric heat pumps become the predominant technology for heating in
6 buildings, customers are expected to continue using gas (including low carbon and
7 renewable gases) to meet their peak heating needs.

8 On page 4 of FEI's Stage 2 Comprehensive Review and Application for a Revised
9 Renewable Gas Program, FEI states:

10 Approval of FEI's proposed Renewable Gas Connections service as described in
11 Sections 7 and 8 of the Application and the corresponding new RS [Rate Schedule]
12 1PLC [Permanent Low Carbon], RS 2PLC, RS 3PLC and RS 5PLC in Attachment
13 D-2 of the Application.

14 Appendix D-2¹ to the Stage 2 Application includes the following definition for Permanent
15 Connection Low Carbon Gas Service:

16 Permanent Connection Low Carbon Gas Service Means firm Gas Service
17 consisting of 100 percent Renewable Gas that is exclusive to and mandatory for
18 Permanent Connection Low Carbon Gas Service Customers under Rate
19 Schedules: (a) 1PLC for Residential Permanent Connection Low Carbon Gas
20 Service; (a) 2PLC for Small Commercial Permanent Connection Low Carbon Gas
21 Service; (b) 3PLC for Large Commercial Permanent Connection Low Carbon Gas
22 Service; and (c) 5PLC for General Firm Permanent Connection Low Carbon Gas
23 Service.

24 In the document titled "20%-Better Energy Efficiency & Zero Carbon Step Code British
25 Columbia Building Code 2018 – Revision 5,"² on page 1 the Building and Safety
26 Standards Branch states:

27 As of May 1, 2023, the first incremental change to the BCBC requires new
28 construction to be 20% more energy efficient... Effective May 1, 2023, most new
29 buildings will be required to comply with the energy efficiency requirements of the
30 BC Energy Step Code. The BC Energy Step Code's performance-based energy
31 efficiency approach requires that a building's designed performance be evaluated
32 through whole building energy modelling and on-site airtightness testing to validate
33 how the building's design and construction meets performance targets for the
34 desired 'Step' of the BC Energy Step Code.

¹ Appendix D-2 "Proposed Tariff Revisions to Enable Renewable Gas Connections and Voluntary Renewable Gas Services".

² https://www2.gov.bc.ca/assets/gov/farming-natural-resources-and-industry/construction-industry/building-codes-and-standards/bulletins/20_better_ee_zcsc.pdf

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 3 |

1 Additionally, page 3 states:

2 The Zero Carbon Step Code has four levels of increasing stringency for Part 9 and
3 Part 10 buildings. The first level of the Zero Carbon Step Code is called EL-1
4 ('Measure-Only') as it only requires measurement of a building's emissions. EL-2
5 is the next level and will likely require decarbonization of either space heating or
6 domestic hot water systems. The next level is EL-3 which will require
7 decarbonization of both space heating and domestic hot water systems. EL-4 is
8 the fourth and final level and indicates that the operation of the is as close to zero
9 emissions as possible. Initially, the Zero Carbon Step Code requirements will be
10 voluntary. The CleanBC Roadmap to 2030 commits to requiring increasingly
11 stringent emission requirements for new buildings in 2024 and 2027. In 2030 the
12 BCBC [BC Building Code] will require all new buildings to be zero carbon.
13 [emphasis added]

14 2.1 Please explain the expected impact upon the Interior Transmission System (ITS)
15 peak demand of the requirement in the BCBC for new construction to be 20 percent
16 more energy efficient, compared to the peak demand shown in FEI's
17 Supplementary Filing Forecast.

18
19 **Response:**

20 The BCBC requirement for new construction to be more energy efficient applies to building
21 efficiency overall and does not specify that the efficiency requirement is based on reducing energy
22 use on the design day or design hour peak.³ Therefore, the impact of efficiency improvements
23 required by the BCBC are more relevant to annual demand forecasting than peak demand
24 forecasting. Further, FEI considers that such a required reduction in annual demand does not
25 necessarily translate to a proportional reduction in peak demand and that its peak demand
26 forecasting method has appropriately addressed this uncertainty, as discussed below:

- 27 • While some measures such as building envelope improvements may lower the peak
28 demand requirements for some buildings, other measures such as on-demand hot water
29 and smart thermostats may have the impact of concentrating the peak into a shorter time
30 period and potentially increasing peak demand for those uses as a result.⁴
- 31 • Due to the nature of gas metering technology currently in use, FEI does not have actual
32 peak use data at a useful level of granularity at this time with which to evaluate the impact

³ The BC Step Code states that energy performance is to be expressed in Thermal Energy Demand Intensity (TEDI) and Total Energy Use Intensity (TEUI) based on different climate zones within the province. See information bulletin: <https://energystepcode.ca/requirements/#bcbc-2018-rev-5>; and technical bulletin: https://www2.gov.bc.ca/assets/gov/farming-natural-resources-and-industry/construction-industry/building-codes-and-standards/bulletins/b19-08_step_code_revision_2_bulletin_2020_01_08.pdf.

⁴ Exhibit B-2, BCUC IR1 5.2 and 5.2.1; Exhibit B-14, BCUC IR2 42.1.1, 42.3.1, 42.3.2.

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 4 |

1 of such building efficiency improvements on peak period demand trends and customer
2 actions in situ during such periods.⁵

- 3 • While current building trends related to the implementation of the Energy Step Code are
4 already embedded in the actual data used to assess peak demand requirements, the
5 extent is unclear. FEI's analysis of customer demand and its work on energy efficiency
6 programs indicate that generally, residential buildings in colder climates in BC such as the
7 Southern Interior tend to already be more efficient than those in warmer parts of the
8 Province such as the Lower Mainland, dampening any influence the Energy Step Code
9 might be having on annual or peak demand analysis.
- 10 • Given the challenges and time required for shifting peak demand from the gas to the
11 electric system as highlighted in the Kelowna Electrification Case Study,⁶ the gas system
12 is critical for energy system resiliency in the region served by the OCU Project and FEI
13 therefore expects peak demand growth to continue.

14 In consideration of the above factors, FEI provides the following analysis to show that the OCU
15 Project is needed even when considering hypothetical cases where peak demand might be
16 impacted by the requirements of the BCBC and ZCSC.

17 In response to BCUC Supplementary IR1 13.2, FEI was asked to evaluate what pipeline length
18 would be sufficient to meet the 20-year peak demand based on the Supplementary Filing
19 Forecast. The resulting demand and pipeline length was determined to be 379 TJ/day and
20 approximately 26 km, respectively.

21 Under a scenario where the Supplementary Filing Forecast of peak demand growth occurs
22 through 2030, and assuming limited growth beyond 2030 as suggested in the preamble, the peak
23 demand would be approximately 352 TJ/day. Using the same methodology that was used to
24 determine the required pipeline length in the response to BCUC Supplementary IR1 13.2, the
25 required length would still be approximately 16 km. This assumes no further growth of any kind
26 would occur.

27 BCUC Panel IR2 3.3 asks that FEI consider alternatives, besides shortening the pipe, for
28 scenarios where the 20-year demand growth is up to 75 percent less than the Supplementary
29 Filing Forecast. However, to provide a more balanced scenario analysis, and in consideration that
30 both decreases and increases in potential future peak demand growth are plausible, the figure
31 below shows the pipe length required under scenarios where the Supplementary Filing Forecast's
32 20-year demand growth increases and decreases by 25, 50 and 75 percent.


33 Further, in the response to BCUC Supplementary IR1 1.1, FEI explained that its peak demand
34 forecasts are prepared annually and are generally completed by the end of Q3 of any given year,
35 which was why FEI provided the 2022 Peak Demand Forecast from BCUC IR2 103.1 of the 2022
36 LTGRP proceeding with an adjustment to account for 2022 actual core customer data (i.e., the

⁵ Exhibit B-2, BCUC IR1 4.1 and 4.1.2; Exhibit B-14, BCUC IR2 42.1.1 and 42.4; Exhibit B-22, BCUC IR3 65.1.

⁶ FEI 2022 Long Term Gas Resource Plan (LTGRP), Exhibit B-20, Evidentiary Update.

1 Supplementary Filing Forecast). FEI has now completed its 2023 peak demand forecast as part
 2 of its annual planning cycle. Given the Panel’s questions regarding different peak demand
 3 forecast scenarios, FEI considered it appropriate to provide the now completed 2023 peak
 4 demand forecast as it represents the most up to date information available. The 2023 peak
 5 demand forecast was prepared using the same methodology as prior peak demand forecasts and
 6 shows a higher rate of growth than the Supplementary Filing Forecast due in large part to a higher
 7 growth in residential accounts supported by the most recent CBOC Housing Starts Forecast. By
 8 2045, the 2023 peak demand forecast suggests a demand requirement of 397 TJ/day and would
 9 require approximately 31 km of pipe to accommodate.

10 These scenarios are all shown in the figure below which relates the length of the Project to the
 11 capacity required. The figure was made using data provided in the response to BCUC
 12 Supplementary IR1 13.2. ITS capacity values were provided for scenarios where the OCU Project
 13 length was decreased by 4 km, 25 percent and 50 percent. Those data points are plotted as a
 14 function of pipeline length in the figure below. The capacity benefit relates to the length of pipe
 15 constructed by a second order trendline that can be used to approximate the required length for
 16 a given capacity requirement.



17

18

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 6 |

1 The above figure not only confirms that the OCU Project is needed, but it also illustrates the
2 diminishing value realized by decreasing pipe length as the change in capacity is proportional to
3 the square of the change in length. That is, reducing the pipe length by 50 percent reduces the
4 capacity benefit by approximately 75 percent.

5 Ultimately, and regardless of the forecast and assumptions made regarding long-term peak
6 demand in the ITS, in all scenarios there continues to be growth in peak demand and a need for
7 increased capacity, which is addressed by the OCU Project.

8 Further, while the timing and impact of the BCBC requirements on ITS peak demand may be
9 unclear, there is a clear trend in historic customer attachments and growth in peak demand and
10 these trends are expected to continue in the near to medium term. Regardless of the growth rate
11 assumed, the regions within the ITS have shown vibrant growth trends and with the historic peak
12 demand already exceeding the capacity of the ITS, any incremental demand further supports the
13 need for incremental capacity in the ITS to mitigate a growing risk of customer outages and
14 increasingly costly short-term mitigations.

15
16

17

18 2.2 Please discuss whether FEI anticipates that level EL-1 of the ZCSC will have any
19 impact upon gas consumption.

20

21 **Response:**

22 FEI does not anticipate that adoption of level EL-1 of the ZCSC will have an impact on gas
23 consumption because compliance for this level only requires the local government to measure
24 GHG performance; there is no requirement that a GHG emissions target be met.

25
26

27

28 2.3 Please explain for each of level EL-2 to EL-4 of the ZCSC, whether peak gas
29 demand for new customers would be expected to be lower than the peak demand
30 assumed for new customers in FEI's Supplementary Filing Forecast, and if so,
31 please estimate the amount of the decrease.

32

33 **Response:**

34 To the extent that the ZCSC remains voluntary for municipalities to 2030, FEI anticipates that the
35 ZCSC will have little impact on new customer peak demand and that the BCBC Step Code will
36 have some influence as discussed in the response to BCUC Panel IR2 2.1. In cases where the
37 ZCSC is made mandatory through either municipal by-law adoption or through the BCBC
38 implementation in 2030, FEI anticipates that the impact of the ZCSC on new customer peak

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 7 |

1 demand will depend on whether or not the use of renewable natural gas (RNG) is a recognized
2 pathway for meeting the ZCSC requirements and the extent to which the use of RNG is
3 competitive with electric heating solutions that are supported by ratepayer and taxpayer funded
4 incentives.

5 If RNG is a viable and competitive space and water heating energy option for new gas customers,
6 then FEI anticipates that the gas system will continue to serve peak demand requirements for
7 these customers at similar peak demand levels to today, as RNG will meet the requirements of
8 all levels under the ZCSC. In this case, the gas system will help to avoid growth in peak energy
9 requirements on the electricity system caused by fuel switching to electricity and thus will help to
10 avoid electricity system constraints and the accelerated need for additional electric infrastructure
11 as explained in the Kelowna Electrification Case Study.

12 If RNG is not viable or competitive for space and water heating energy in new residential and/or
13 commercial buildings, FEI anticipates that the ZCSC will have some impact on the growth in peak
14 demand on the gas system. In this case, the amount of the impact is not fully known, but FEI
15 offers the following:

- 16 • Under ZCSC EL-2, FEI expects that building carbon intensity levels in buildings using high
17 efficiency gas fired space heating and hot water equipment can be met using conventional
18 natural gas appliances and as such, EL-2 can be expected to have minimal impact on the
19 forecast for peak gas demand as customers can be expected to continue using gas for
20 peak heating needs.
- 21 • Under ZCSC EL-3, high efficiency gas appliances using conventional natural gas will not
22 be able to meet the stated carbon intensity levels if used year-round; however, FEI is not
23 clear at this time if high-efficiency dual (electric and gas) fuel heating systems using
24 conventional natural gas can meet the EL-3 requirements when used solely for peak
25 heating needs. If so, FEI anticipates that dual fuel heating systems will be an alternative
26 to all-electric systems due to their resiliency benefits. In the case where the gas system
27 continues to support peak energy demand requirements for customers, FEI anticipates
28 individual new customer changes to peak demand will be fairly minor. FEI does not have
29 sufficient information at this time to predict how much uptake of such an alternative can
30 be expected and is not able to accurately predict the amount of impact that EL-3 would
31 have on its forecast for peak demand under these circumstances.
- 32 • Under ZCSC EL-4, high-efficiency gas appliances using conventional natural gas as a fuel
33 will not meet the stated carbon intensity levels. In this case, FEI anticipates that growth in
34 peak demand will begin to flatten to a greater extent than in the current forecast for peak
35 demand in the region served by the proposed OCU Project. The full extent of such
36 flattening in peak demand is not entirely known since FEI understands that conventional
37 natural gas for some ancillary uses such as cooking and clothes drying can be done within
38 the EL-4 stated carbon intensity levels and FEI may continue to add customers if EL-4
39 becomes mandatory in its current form. In this circumstance, since new peaking heating
40 load will be shifted to the electric system, FEI anticipates that the electricity system

1 constraints and new electric system infrastructure requirements such as outlined in the
2 Kelowna Electrification Case Study, will begin to materialize more rapidly.

3 As stated in the response to BCUC Panel IR2 2.1, given the immediate need for the OCU Project,
4 there is not a level of the ZCSC that avoids the need to increase capacity into the Okanagan
5 region.

6
7

8
9 2.4 Please further explain how RNG would be able to meet EL-4 in the ZCSC. Please
10 outline any assumptions used with respect to carbon intensity.

11

12 **Response:**

13 RNG has a lower emissions factor than natural gas or electricity and thereby can meet EL-4. If
14 FEI assumes an emissions factor of 0.2665 kgCO_{2e}/GJ for RNG as published by the Province of
15 BC,⁷ the following example shows how this target can be met with RNG and electricity but not
16 natural gas. The emissions factor for electricity from BC Hydro in 2021 is 2.69 kgCO_{2e}/GJ.

17 As per the performance path approach of the ZCSC, EL-4 for a house requires that the:

- 18 • Maximum GHGi by house expressed in kgCO_{2e}/m²/yr: 1.5
- 19 • Maximum GHG by house expressed in kgCO_{2e}/yr: 500

20

| Fuel type | BC Energy Step Code Level 3 Home built in Climate Zone 5 Modeled Emissions for a Sample Single Family Detached Home (3,030 sqft) | | |
|---|---|----------|---|
| | 100% NG | 100% RNG | 100% Electricity |
| Space Heating appliance | Gas Furnace, 95% Annual Fuel Utilization Efficiency (AFUE) | | Electric Furnace/Baseboards |
| Water Heating appliance | Tankless Gas Heater, 0.92 Efficiency Factor (EF) | | Electric Tank Heater (40 US gallons, 0.83 Efficiency Factor (EF)) |
| GHGi (kgCO _{2e} /m ² /yr) | 9.9 | 0.3 | 1.0 |
| GHG/yr (kgCO _{2e} /yr) | 2787 | 96 | 279 |
| ZCSC EL-4 Emission Level achieved? | No | Yes | Yes |

⁷ See tab, “BC Stationary Fuel Combustion”, bottom of the table.
https://www2.gov.bc.ca/assets/gov/environment/climate-change/cng/guidance-documents/emission_factors_catalogue.xlsx 0.0002665 kgCO_{2e}/MJ = 0.2665 kg/GJ = 0.001 kg/kWh, as of Oct 16, 2023.

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 9 |

1 For the prescriptive pathway, EL-2 to EL-4 require that energy sources supplying heating systems
2 have an emissions factor of less than or equal to 0.011 kgCO₂e/kWh, which includes both the
3 principal and supplementary heating systems. This target can be met with both RNG and
4 electricity.

- 5 • Electricity emissions factor: 0.011 kg CO₂e/kWh⁸
- 6 • RNG emissions factor 0.001 kg/kWh⁹

7 Please also refer to the response to BCUC Panel IR2 2.4.1 for a discussion of updates to the
8 BCBC required to incorporate RNG as a compliance pathway.

9
10

11

12 2.4.1 Please discuss the risks that a future zero-carbon requirement for new
13 buildings in the BCBC could preclude the use of renewable natural gas.

14

15 **Response:**

16 For clarity, FEI understands that the current EL-4 is the fourth and final step of the ZCSC and is
17 identified as the Province's equivalent of a zero-carbon requirement, as it is as close to zero
18 emissions as possible that can be achieved. If the Province were to limit the emissions target
19 further than EL-4, electricity emissions would exceed the emissions target.

20 RNG is not currently listed as a compliance pathway in the BCBC and there is a risk that
21 necessary amendments to add RNG are delayed or not made. FEI understands the intention of
22 the ZCSC is to be fuel agnostic and the permanence of FEI's RNG voluntary tariff was the primary
23 concern, which FEI is seeking to address through its Stage 2 Comprehensive Review and
24 Application for a Revised Renewable Gas Program Application (Revised Renewable Gas
25 Program Application). The Province has indicated that it is awaiting a decision on FEI's Revised
26 Renewable Gas Program Application to determine how future updates of the BC Building Code
27 can incorporate RNG. Please refer to the slide extract below¹⁰:

⁸ https://free.bcpublishings.ca/civix/document/id/public/bcbc2018/bcbc_2018dbs103r5

⁹ See tab, "BC Stationary Fuel Combustion", bottom of the table.
https://www2.gov.bc.ca/assets/gov/environment/climate-change/cng/guidance-documents/emission_factors_catalogue.xlsx 0.0002665 kgCO₂e/MJ = 0.2665 kg/GJ = 0.001 kg/kWh, as of Oct 16, 2023.

¹⁰ [BC Building Code proposals for cleaner, more energy efficient Part 9 buildings \(2022\) - YouTube](#), Episode 4.

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 10 |

Modelling for renewable natural gas and district energy

Emissions factors

- Priority: stability, predictability
- Based on City of Vancouver Energy Modelling Guidelines (CoV EMG)
- Applies to the entire province, regardless of electricity grid
 - Use the Integrated grid figures for Fort Nelson grid for energy modelling purposes
- More detailed modelling ruleset in development

Renewable natural gas (RNG)

- Code proposal accommodates renewable natural gas (RNG), other innovative fuel sources as they become available
- BC Utilities Commission decision about RNG is pending as of August 2022

District energy systems

- Emissions factors to be decided between the Authority Having Jurisdiction (AHJ) and the utility provider, consistent with the City of Vancouver Energy Modelling Guidelines

1
2 Below is an extract of the presenter notes accompanying this slide:

3 On the gas side, there are also big efforts to reduce carbon intensity. There is
4 significant interest in renewable natural gas, or RNG, as a way to decarbonize the
5 conventional natural gas supply. Also known as biomethane, it is a refined form of
6 biogas, which comes from landfills, oil production, agriculture, sewage treatment,
7 and other activities where biogas would otherwise be released into the atmosphere
8 and contribute to climate change.

9 As of August 2022, a proposal from FortisBC to introduce RNG at scale is currently
10 before the BC Utilities Commission (or BCUC), which is an independent agency of
11 the provincial government responsible for regulating British Columbia's energy
12 utilities. The BCUC has not issued a decision on the proposal yet. Given these
13 variables, this draft code language is written to include future energy options, and
14 terms like "decarbonized fuels" were chosen specifically to account for the breadth
15 of possibilities.

16 However, given the urgency of climate change, we are choosing to issue a Code
17 proposal now so builders and local governments can start using it at scale, and
18 when a decision is released, we will read it closely and assess if and how it affects
19 the Code language.

20
21

22
23 2.5 Please explain whether gas as a back-up heating option for peak periods only
24 would be permissible in new buildings under EL-4 of the ZCSC, and a future zero
25 carbon requirement for new buildings in the BCBC.
26

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 11 |

1 **Response:**

2 Conventional natural gas as a back-up or emergency heating option, such as a fireplace, would
3 meet the prescriptive path requirements of EL-4 (which requires all primary heating load be met
4 using energy with an emissions factor of 0.011 kgCO₂e/GJ or less). In contrast, under the
5 performance path, gas as a back-up heating option is unlikely to meet EL-4 of the ZCSC, except
6 in some larger homes. Please also refer to the response to BCUC Panel IR2 2.4.1 regarding FEI's
7 understanding of a future zero carbon requirement.

8
9

10

11 2.6 Please confirm, or explain otherwise, that ancillary appliances (e.g.
12 cooktops/dryers, outdoor appliances such as barbeques and patio heaters, and
13 fireplaces) have a minor impact on peak day demand.

14

15 **Response:**

16 FEI estimates that the impact of end uses such as fireplaces, cooking, pool and spa, drying, and
17 others currently contribute approximately 10 percent of peak day demand for FEI's core
18 customers in the Southern Interior.

19 However, this trend may change and potentially increase in the future depending on how new
20 customers' energy decisions change in relation to these new policies, codes and standards. For
21 example, the use of backup or emergency heating appliances, such as fireplaces, in new buildings
22 could change in response to policies like the ZCSC. For instance, in colder climates like the
23 Southern Interior, customers using heat pumps require a backup source of heating. Under the
24 ZCSC, backup heating equipment, whether gas or electric, is excluded from the calculation of
25 emission performance in a building that uses electricity as its primary energy source to meet
26 space and water heating load. As such, customers in new buildings may install and use a gas
27 fireplace to provide backup or emergency heating during winter peak periods to a greater degree
28 than they do today. In this case, although the peak may not increase above that forecast by FEI
29 for the area served by the OCU Project, the ancillary uses described may contribute a greater
30 proportion of that peak demand than they do today.

31

32

33

34 2.7 Please confirm, or explain otherwise, that FEI's Supplementary Filing Forecast
35 does not account for zero carbon requirements for new buildings in the BCBC in
36 2030.

37

38

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 12 |

1 **Response:**

2 FEI's Supplementary Filing Forecast was created in accordance with the traditional method as
3 described in the response to BCUC Supplementary IR1 1.1 and embeds trends inherent in energy
4 use at the time of its preparation. FEI has not altered its methodology to include any special
5 assumptions before or beyond 2030 regarding the impact that zero carbon new building
6 requirements may have on peak demand growth on FEI's system. While FEI understands that
7 the BCBC (Zero Carbon Step Code) will ultimately impact energy use, it is premature to change
8 peak demand forecasting methods or defer infrastructure needed to serve customers today as
9 this policy has not yet begun to influence peak gas demand and may not do so for several years
10 for the following reasons:

- 11 • While municipalities are required to achieve the top step of the BCBC Zero Carbon Step
12 Code by 2030, none of the municipalities in the ITS Region have adopted the Zero Carbon
13 Step Code at this time;
- 14 • Expanding the electric system to support increased peak winter heating demand that is
15 currently served by gas infrastructure is challenging and will take time;
- 16 • The role of renewable gases within the BCBC (Zero Carbon Step Code) has not yet been
17 determined, making it premature to assume that new gas connections will be precluded
18 by the BCBC; and
- 19 • As discussed in the response to BCUC Panel IR2 2.6 the BCBC does not preclude the
20 installation of gas fireplaces in new buildings. Gas fireplaces are likely to be used as a
21 backup source of heating during peak demand conditions.

22 Therefore, FEI's Supplementary Filing Forecast remains valid. Please also refer to the responses
23 to BCUC Panel IR2 2.1 and 2.3 for a discussion of the potential impact of the BCBC and ZCSC
24 under different future conditions that are yet to be determined.

25
26

27

28 2.8 Please explain the expected impact on FEI's ability to attach new residential and
29 commercial customers if FEI's proposed Permanent Low Carbon rate schedules
30 (as applied for in the Stage Two Application are (i) approved by the BCUC and (ii)
31 denied by the BCUC, in each of the following circumstances:

- 32 a) Municipalities implement EL-2 between now and 2030;
- 33 b) Municipalities implement EL-3 between now and 2030;
- 34 c) Municipalities implement EL-4 between now and 2030; and
- 35 d) the BCBC requires all new buildings to be zero carbon in 2030.

36 Please quantify the estimated impact on peak demand in the ITS in each case.

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 13 |

1

2 **Response:**

3 Please refer to the response to BCUC Panel IR2 2.3.

4

5

6

7 2.9 In a circumstance where FEI's proposed Permanent Low Carbon rate schedules
8 are denied by the BCUC, please explain and estimate the expected impact on peak
9 demand prior to 2030.

10

11 **Response:**

12 Please refer to the response to BCUC Panel IR2 2.3.

13

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 14 |

1 **3.0 Reference: ALTERNATIVES ANALYSIS**
2 **Exhibit B-1-2 (Updated Application), p. 45**
3 **Exhibit B-2, BCUC IR 2.6.1; 11.4**
4 **Exhibit B-36, BCUC IR 48.1**
5 **Project Alternatives to Meet Lower Demand Forecasts**

6 On page 45 of the Updated Application, FEI states:

7 As discussed in Section 4.1.1, measures such as CNG [compressed natural gas]
8 injection, which can be used to mitigate a small, short-term capacity shortfall such
9 as the shortfall projected for 2021/2022 and 2022/2023, are costly and inefficient
10 in the long term when compared to standard gas supply methods such as
11 pipelines.

12 In response to BCUC IR 2.6.1, FEI stated:

13 FEI considered alternatives to address the forecast capacity shortfall at a local
14 level in the communities of West Kelowna, Lavington, and Lumby. However, these
15 alternatives are not viable long-term solutions for the ITS and do not provide the
16 reliability, resiliency, and operational benefits to the ITS outside of these local
17 areas. The capacity shortfall at a local level could be managed in two ways: by
18 supplementing the supply deficit locally with compressed natural gas (CNG) or
19 liquefied natural gas (LNG), or by curtailing local load to match the available
20 supply.

21 BCUC IR 48.1 asked:

22 IR 48.1 - For CNG/LNG Trucking, please provide a high-level estimate of:

- 23 • The costs to install infrastructure, complete necessary site upgrades, and
24 purchase/rent required equipment;
25 • the operational costs in the first year of implementation; and
26 • the incremental operational costs (if different from the above) associated
27 with peak demand increases that are forecasted to occur each year.

28 In response to BCUC IR 48.1, FEI stated:

29 FEI has not completed a detailed analysis of the costs which would be associated
30 with implementing CNG supplementation in this specific instance, but has
31 previously produced estimates for purchasing and operating its own CNG injection
32 equipment for other uses on its system. These costs have been scaled to represent
33 FEI's best approximation of costs associated with implementing CNG
34 supplementation in the Kelowna region beginning in the winter of 2023/2024. A
35 high-level summary of the costs is provided below for the years 2023 to 2028.

1 Costs would continue to rise as demand on the system, and consequently the
 2 CNG/LNG requirement, increases over time. These costs are based on the
 3 following assumptions:

- 4 • The CNG tanker filling point is at Oliver;
- 5 • The CNG injection point is near Kelowna;
- 6 • The Savona delivery pressure from Enbridge is 600 psig;
- 7 • Each CNG tanker has a capacity of 350 GJ per truck;
- 8 • Trucks are purchased rather than rented due to the uncertainty surrounding
 9 rental/lease contracts;
- 10 • The majority of civil work to be completed in year 1 to accommodate
 11 compression upgrades in subsequent years;
- 12 • Loading and offloading sites are manned by FEI operations personnel; and
- 13 • A 15 percent contingency is included in all estimates.

| | # of Trucks/Peak Day | Capital Costs (\$millions) | O&M Costs (\$millions) | Total Year Cost (\$millions) | Total Cumulative Costs (\$millions) |
|-----------------------|----------------------------|-------------------------------|---------------------------|------------------------------------|---|
| Year 1 (2023/2024) | 16 | 26.1 | 1.3 | 27.4 | 27.4 |
| Year 2 (2024/2025) | 36 | 8.5 | 3.3 | 11.7 | 39.1 |
| Year 3 (2025/2026) | 45 | 5.7 | 4.6 | 10.3 | 49.4 |
| Year 4 (2026/2027) | 54 | 3.3 | 6.7 | 10.0 | 59.5 |
| Year 5 (2027/2028) | 63 | 3.3 | 9.3 | 12.6 | 72.0 |

14
 15
 16 3.1 Please provide an updated high-level cost estimate (capital and O&M) for a CNG
 17 project that was designed to meet the forecasted ITS peak demand until 2030 only,
 18 based upon the trajectory of the Supplementary Filing Forecast. Please produce
 19 estimates for facilities assuming Savona tap pressure at (i) 600 psig and (ii) 650
 20 psig, and include a discussion of any key assumptions or uncertainties associated
 21 with the cost estimates.

22
 23 **Response:**

24 Please refer to the two tables below for FEI’s updated high-level cost estimate for a CNG project
 25 to meet the 2030 peak demand based on the Supplementary Filing Forecast. The updated
 26 analysis has been provided for Savona tap pressures of 600 psig and 650 psig. Please refer to

1 the response to BCUC IR2 48.1 for a list of key assumptions made in the analysis. Please refer
 2 to the response to BCUC Panel IR2 3.1.2 for an explanation of why FEI does not consider such
 3 projects to be feasible.

4 **Table 1: Savona at 600 psig¹¹**

| | # of Trucks/Peak Day | Capital Costs (\$ millions) | O&M Costs (\$ millions) | Total Year Cost (\$ millions) | Total Cumulative Costs (\$ millions) |
|---------------------------|----------------------|-----------------------------|-------------------------|-------------------------------|--------------------------------------|
| Year 1 (2026/2027) | 18 | 20.7 | 1.9 | 22.6 | 22.6 |
| Year 2 (2027/2028) | 23 | 1.8 | 2.5 | 4.4 | 26.9 |
| Year 3 (2028/2029) | 28 | 5.1 | 3.5 | 8.6 | 35.6 |
| Year 4 (2029/2030) | 34 | 3.6 | 4.2 | 7.8 | 43.3 |
| Year 5 (2030/2031) | 39 | 1.5 | 5.7 | 7.2 | 50.5 |

5

6

Table 2: Savona at 650 psig

| | # of Trucks/Peak Day | Capital Costs (\$ millions) | O&M Costs (\$ millions) | Total Year Cost (\$ millions) | Total Cumulative Costs (\$ millions) |
|---------------------------|----------------------|-----------------------------|-------------------------|-------------------------------|--------------------------------------|
| Year 1 (2026/2027) | 1 | 15.5 | 0.8 | 16.2 | 16.2 |
| Year 2 (2027/2028) | 6 | 0.7 | 1.1 | 1.9 | 18.1 |
| Year 3 (2028/2029) | 11 | 2.6 | 1.6 | 4.3 | 22.4 |
| Year 4 (2029/2030) | 17 | 3.2 | 2.1 | 5.3 | 27.7 |
| Year 5 (2030/2031) | 22 | 1.1 | 3.0 | 4.1 | 31.8 |

7

8

9

10 3.1.1 Please also estimate the number of truckloads per day that would be
 11 required in 2030 in either scenario.

¹¹ Estimated CNG injection requirements are a best approximation as it is difficult to accurately model the capacity benefits of CNG injection.

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 17 |

1

2 **Response:**

3 Please refer to the response to BCUC Panel IR2 3.1 for the estimated number of truckloads per
4 day that would be required in 2030 in either scenario.

5

6

7

8 3.1.2 Please discuss whether FEI considers such projects would be technically
9 feasible.

10

11 **Response:**

12 FEI does not consider this approach to meeting the longer-term capacity needs of the region to
13 be technically feasible.

14 As noted in the response to BCUC IR1 11.1, there is a point where the number of daily and hourly
15 truckloads required to maintain capacity during peak demand becomes logistically unfeasible.
16 While the number of trucks per peak day has reduced based on the Supplementary Filing
17 Forecast (see the response to BCUC Panel IR2 3.1), by Year 3 (2028/2029) the requirement for
18 28 Trucks/Peak Day exceeds what FEI considers to be feasible (somewhere between 16 – 36
19 Trucks/Peak Day as established in the response to BCUC IR1 11.1).

20 Please refer to the responses to BCUC IR1 11.1 and BCUC IR2 48.1 for a discussion of the
21 logistical challenges associated with using a high number of CNG trucks. The key challenges are
22 as follows:

- 23
- 24 • The high number of CNG trucks required would create severe space constraints at the fill
and injection sites;
 - 25 • Increased demand on FEI's operational resources at the compression and decompression
26 sites; and
 - 27 • The need to rely on and organize contracted resources to operate the virtual pipeline and
28 haul the CNG trailers.

29 In addition to these challenges, FEI notes that for an operation of this size, it would need access
30 to a large amount of equipment which would sit idle until needed. When the cold weather
31 conditions were identified, FEI would have to mobilize the personnel required to operate the
32 system, which would likely include contractors to drive the CNG trailers to and from the fill and
33 injection sites. Relying on contractors and idle equipment to mobilize quickly in severe winter
34 conditions creates an additional challenge that further reduces the reliability of the CNG system
35 as a long-term peaking resource.

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 18 |

1 FEI notes that the required number of trucks per day under the Supplementary Filing Forecast
2 with Savona at 650 psig may remain logistically feasible in Year 5 (2030/2031). However, as
3 noted in the Supplementary Filing, there is no firm contractual obligation for Westcoast Energy
4 Inc. to provide FEI with 650 psig at the Savona tap. As such, FEI is unable to rely on the Savona
5 tap pressure being at 650 psig over the long-term. As a prudent operator, FEI would, therefore,
6 need to plan for the lower tap pressure, making this option logistically unfeasible.

7 FEI views CNG trucking as a useful tool for certain initiatives such as emergency response, but
8 due to the noted challenges finds that it is not ideal for longer term peak shaving applications of
9 this size, especially when a superior alternative, such as the proposed OCU Project, is available.

10
11

12

13 3.1.3 Please estimate the lead time required for such facilities.

14

15 **Response:**

16 At a high level, FEI estimates it would take 3 years to establish CNG injection. This estimate is
17 based on 12 months of project development, 6 months of design, and 18 months for
18 procurement¹² and installation. As noted in the response to BCUC IR2 48.1, FEI expects there to
19 be permitting and land acquisition challenges associated with a CNG injection project. Together,
20 these challenges would create a schedule risk.

21

22

23

24 3.2 Please discuss any other alternatives besides CNG that could be available to FEI
25 to meet the forecasted ITS peak demand until 2030 only, based upon the trajectory
26 of the Supplementary Filing Forecast. To the extent FEI is able to, please provide
27 a high-level overview of the magnitude of expected costs, risks, and service life
28 associated with such alternatives.

29

30 **Response:**

31 For the reasons described in the response to BCUC Panel IR2 2.1, FEI does not consider it
32 prudent to only plan to meet forecast ITS peak demand until 2030. However, to be responsive,
33 FEI has developed the following two alternatives to meet the 2030 ITS peak demand under the
34 Supplementary Filing Forecast. One alternative is a reduced length to Alternative 3, and the other

¹² FEI's current understanding is that the lead time for most of the major equipment for the CNG project is approximately 52 weeks after the issuance of a purchase order.

1 is to implement a virtual pipeline through LNG trucking. Each alternative is discussed in more
2 detail below.

3 **Reduced Alternative 3 Pipeline Length**

4 For Alternative 3 to provide sufficient capacity for the 2030 Supplementary Filing Forecast load,
5 an approximately 16 km pipeline¹³ would be required. FEI has not completed any detailed cost
6 estimating for the reduced length pipeline. Due to the large change in project scope between the
7 proposed OCU Project and this scenario, FEI is unable to provide an updated cost estimate. FEI
8 notes that in the response to BCUC Supplementary IR1 13.2.2, a potential cost savings per
9 kilometre was provided. However, as noted in that response, the value is only applicable to
10 reductions of relatively short segments (i.e., less than 5 km), and as such cannot be applied to
11 this scenario. The risks and service life associated with this alternative would be aligned with
12 Alternative 3.

13 As shown in the Supplementary Filing Forecast, demand is expected to increase beyond 2030.
14 As such, FEI would need to extend this alternative prior to Winter 2031/32 to meet the demand.
15 A cost premium would be expected from constructing the pipeline in this manner and having to
16 re-site, relocate or reconstruct the pressure control station at the tie-in location.

17 **Virtual Pipeline via LNG Trucking**

18 FEI considered a virtual pipeline project using LNG trucking to meet the 2030 peak demand based
19 on the Supplementary Filing Forecast with the quantity of trucks per day shown below in Table 1.

20 **Table 1: LNG Trailers per Peak Day from Delta to Kelowna by Year**

| | # of Trucks/Peak Day, Savona 650 psi minimum | # of Trucks/Peak Day, Savona 600 psi minimum |
|---------------------------|--|--|
| Year 1 (2026/2027) | 1 | 7 |
| Year 2 (2027/2028) | 3 | 9 |
| Year 3 (2028/2029) | 5 | 11 |
| Year 4 (2029/2030) | 7 | 13 |
| Year 5 (2030/2031) | 9 | 15 |

21
22 Under this scenario, FEI assumed that the LNG tankers would be filled at the Tilbury LNG facility
23 in Delta, BC and transported to Kelowna, BC for vaporization. FEI expects that overall costs for a

¹³ FEI notes that this length is derived solely from the capacity requirement and does not consider constructability. As such, the actual end-point may need to be adjusted.

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 20 |

1 temporary LNG virtual pipeline solution would be of a similar magnitude to the temporary CNG
2 virtual pipeline, however, the mix of capital versus operating costs would be different. FEI expects
3 that there would be less capital expenditures due to fewer trailers being required but higher
4 operating expenditures due to the longer distances the vehicles would need to travel, resulting in
5 correspondingly higher drive times.

6 Further risks and challenges associated with an LNG virtual pipeline alternative can be found in
7 the responses to BCUC IR1 11.1 and 11.4. Compared to the CNG virtual pipeline, the LNG option
8 is more logistically feasible due to the reduced number of trucks. However, this comes at a cost
9 as there are increased concerns with reliability due to the winter driving through high mountain
10 passes that would occur with the LNG option. Due to the risks and challenges and the quantity of
11 trucks required to support the system, FEI does not consider this to be a feasible option for this
12 scenario.

13 Further, as shown in the Supplementary Filing Forecast, demand is expected to increase beyond
14 2030. As such, the required equipment would continue to increase after 2030 to meet the demand.
15 In a hypothetical scenario where demand fully stops growing after 2030, FEI would still need to
16 operate the virtual pipeline indefinitely to address the capacity shortfall between the 2030 peak
17 demand and the current ITS capacity. That is, FEI would need to operate the virtual pipeline in
18 perpetuity, at a cost to the ratepayer, or until the demand reduced to the existing ITS capacity.

19 FEI views LNG trucking as a useful tool for certain initiatives such as emergency response, but
20 due to the noted challenges finds that it is not ideal for longer term peak shaving applications,
21 especially when compared to the proposed OCU Project.

22

23

24

25 3.3 Please discuss the alternatives that could be available to FEI to meet ITS peak
26 demand which is lower than the 20-year Supplementary Filing Forecast, besides
27 shortening the length of the OCU pipeline. For example, if the 20-year demand
28 were 25%, 50%, or 75% of the forecasted demand outlined in the Supplementary
29 Filing Forecast. To the extent FEI is able to, please provide a high-level overview
30 of the magnitude of expected costs, and risks associated with such alternatives.

31

32 **Response:**

33 FEI has proposed and discussed a variety of alternatives throughout the proceeding. At a high-
34 level, the alternatives consist of:

- 35 • Increasing the flow of gas from the south (Alternatives 1, 2, and 3);
- 36 • Increasing the flow of gas from the north (Alternative 4);
- 37 • A peak shaving facility (Alternative 5); and

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 21 |

- 1 • A virtual pipeline through CNG/LNG trucking.

2 The challenges associated with each of the above alternatives are described in the Updated
3 Application and in the response to BCUC Supplementary IR1 11.1.1, and these challenges persist
4 regardless of the hypothetical reduction of the 20-year demand growth rate. The factors that
5 support Alternative 3 as the preferred and superior solution to Alternatives 1, 2, 4, and 5 are still
6 valid in the hypothetical reduced demand scenarios referenced in this IR. Additionally, the
7 challenges associated with a virtual pipeline are described in the responses to BCUC Panel IR2
8 3.1 and 3.2.

9 As such, FEI considers the only alternative to meet the hypothetical reduced demand to be
10 Alternative 3 with a reduced length pipeline. To meet the 75 percent scenario, roughly half the
11 length of the proposed Project would need to be built. Due to the large change in project scope
12 between the proposed Project and this hypothetical scenario, FEI is unable to provide an updated
13 cost estimate. FEI notes that in the response to BCUC Supplementary IR1 13.2.2, a potential cost
14 savings per kilometre was provided. However, as noted in that response, the value is only
15 applicable to reductions of relatively short segments (i.e., less than 5 km), and as such cannot be
16 applied to the hypothetical 75 percent scenario. Please also refer to the response to BCUC Panel
17 IR2 2.1.

18

19

20

21 In response to BCUC IR 11.4, FEI stated:

22 Truck transportation is far more likely to be disrupted by events such as inclement
23 weather (which FEI would expect to be a significant factor should CNG be used to
24 supplement supply during peak winter conditions), traffic accidents, mechanical
25 breakdowns, road closures, heavy traffic, or dispatching issues. Traffic accidents
26 and road closures are frequent in the British Columbia Interior during winter
27 conditions due to heavy snowfall and ice causing dangerous driving conditions and
28 poor visibility.

29 3.4 Please further discuss the extent to which heavy snowfall and/or ice would be
30 expected to coincide with the design day temperatures.

31

32 **Response:**

33 Snowfall can occur when the ambient temperature is below the freezing point (0 degrees Celsius),
34 even at extremely cold temperatures. Because relative humidity of the air drops proportionally
35 with temperature, it is less likely for heavy snowfall to coincide with the design day temperatures
36 and more likely to occur before or after the design day temperature.

| | |
|---|--------------------------------------|
| FortisBC Energy Inc. (FEI or the Company) Application for a CPCN for the Okanagan Capacity Upgrade (OCU) Project (Application) | Submission Date: October 25, 2023 |
| Response to British Columbia Utilities Commission (BCUC) Panel Information Request (IR) No.2 | Page 22 |

- 1 • On December 27, 2021 (the coldest day recorded by Environment Canada in Kelowna¹⁴),
2 snow accumulation on the ground was 20 cm with no new snow recorded on that day.
3 However, approximately 7 cm of new snow was recorded on the days before and
4 approximately 3 cm on the days following. The same trend was observed in Vernon¹⁵ with
5 16 cm of snow falling on the days before and approximately 4 cm falling on the days
6 following.
- 7 • On December 22, 2022 (the coldest day recorded by Environment Canada in Kelowna¹⁶),
8 snow accumulation on the ground was 17 cm with no new snow recorded on that day.
9 However, approximately 9 cm of new snow was recorded on the days before and
10 approximately 12 cm on the days following. The same trend was observed in Vernon¹⁷
11 with 12 cm of snow falling on the days before and approximately 18 cm falling in the days
12 following.

13 This demonstrates that snowfall, ice and challenging conditions for truck transportation exist
14 during the periods of high demand on the gas system. As an example, the Government of British
15 Columbia provided an advisory to avoid non-essential travel because of the potential for
16 dangerous road conditions during the recent cold temperatures experienced in the Southern
17 Interior in December 2022¹⁸, coinciding with near design day temperatures.

18 Therefore, FEI considers that supply via a virtual pipeline utilizing truck transportation is far more
19 likely to be disrupted by events such as inclement weather, traffic accidents, mechanical
20 breakdowns, road closures, heavy traffic, or dispatching issues compared to a conventional
21 pipeline solution.

22

¹⁴ Refer to: https://climate.weather.gc.ca/climate_data/daily_data_e.html?StationID=51117&timeframe=2&StartYear=1840&EndYear=2023&Day=20&Year=2021&Month=12#.

¹⁵ Refer to: https://climate.weather.gc.ca/climate_data/daily_data_e.html?StationID=46987&timeframe=2&StartYear=1840&EndYear=2023&Day=20&Year=2021&Month=12#.

¹⁶ Refer to: https://climate.weather.gc.ca/climate_data/daily_data_e.html?StationID=51117&timeframe=2&StartYear=1840&EndYear=2023&Day=20&Year=2022&Month=12#.

¹⁷ Refer to: https://climate.weather.gc.ca/climate_data/daily_data_e.html?StationID=46987&timeframe=2&StartYear=1840&EndYear=2023&Day=20&Year=2021&Month=12#.

¹⁸ Refer to: <https://news.gov.bc.ca/releases/2022EMCR0070-001940>.