

Furnace commissioning sheet

Note: The new furnace must undergo commissioning to ensure it's installed and operating according to best practice. A copy of the completed commissioning sheet must be made available upon request.

Applicant instructions:

- Ask your contractor to complete this sheet. Your contractor will run a series of tests on your new high-efficiency furnace to gather the required data.
- Submit a copy of this sheet with the rest of your rebate application package to receive your rebate.
- Keep a copy with your furnace. This sheet will provide valuable information when your furnace is serviced in the future.

Why is commissioning important?

Commissioning of a high-efficiency furnace helps to ensure it's installed and operating correctly. The benefits of a properly commissioned furnace include lower operating costs, potentially greater equipment longevity, and less maintenance over its lifetime. Additional benefits include improved home comfort, and a furnace that will run smoothly and quietly.

| | | | |
|---|--|---|--|
| Contractor business name | Furnace installation date (Yr/Mth/Day) | | |
| Installation address | City | Province BC | Postal code |
| Furnace make and model | Furnace serial number | | |
| 1. Inlet gas pressure (at high fire) _____ inches W.C. | 2. Measure/set manifold gas pressure Type of furnace: <input type="checkbox"/> Modulating Skip to section 3 <input type="checkbox"/> Single stage High fire _____ inches W.C. <input type="checkbox"/> Two stage High fire _____ inches W.C. Low fire _____ inches W.C. | 3. Clocking the meter (at high fire) CALCULATE BTU INPUT: _____ BTU/H | |
| 4. External Static Pressures (at high fire) Supply ductwork _____ inches W.C. Return ductwork _____ inches W.C. | 5. Temperature rise (at low and high fire) HIGH FIRE: Supply air _____ °F Return air - _____ °F Total rise = _____ °F | LOW FIRE: Supply air _____ °F Return air - _____ °F Total rise = _____ °F | RISE RANGE (as per manufacturer): High fire _____ °F to _____ °F Low fire _____ °F to _____ °F |
| 6. Filter Media type _____ Measurements _____ MERV rating _____ | | | |

